

Received
State of Indiana

AUG 20 2021

Dept of Environmental Management
Office of Air Quality



Cokenergy, LLC

3210 Watling Street
Mail Code 2-991
East Chicago, Indiana 46312

August 18, 2021

Chief, Environmental Enforcement Section
Environment and Natural Resources Division
U.S. Department of Justice
Box 7611, Ben Franklin Station
Washington, DC 20044-7611
Re: DOJ No. 90-5-2-1-08555/1

Compliance Tracker
Air Enforcement and Compliance Assurance Branch
U.S. Environmental Protection Agency – Region 5
77 West Jackson Blvd. AE-18J
Chicago, IL 60604-3590

Including an electronic copy to:
R5airenforcement@epa.gov

Phil Perry
Indiana Department of Environmental Management
Chief, Air Compliance and Enforcement Branch
100 North Senate Avenue
MC-61-53, IGCN 1003
Indianapolis, IN 46204-2251

Subject: Consent Decree, United States, et al. v. Indiana Harbor Coke Company, et al.
Cokenergy, LLC (Part 70 Permit No. T089-41033-00383)
Termination

To Whom It May Concern:

In accordance with Section XIX (Termination), Paragraph 113. of the consent decree (18-cv-35), Cokenergy, LLC is seeking termination of the consent decree as we have satisfactorily completed the requirements specified in subparagraphs b-f. Details on the specific requirements and our Certification of Completion as specified in Paragraph 114 are provided below.

Details on the compliance provisions from Paragraph 113.b, including Paragraphs 113.c-f and 114 are detailed in the following paragraphs.

Air Enforcement Division Director
U.S. Environmental Protection Agency
Office of Civil Enforcement
Air Enforcement Division
U.S. Environmental Protection Agency
1200 Pennsylvania Ave, NW Mail Code: 2242A
Washington, DC 20460

Susan Tennenbaum
U.S. Environmental Protection Agency
Region 5
C-14J
77 West Jackson Blvd
Chicago, IL 60640

Including an electronic copy to:
tennenbaum.susan@epa.gov

Elizabeth A. Zlatos
Indiana Department of Environmental Management
Office of Legal Counsel
100 North Senate Avenue
MC-60-01, IGCN 1307
Indianapolis, IN 46204-2251

Including an electronic copy to:
bzlatos@idem.in.gov

Paragraph 113.c – Cokenergy has paid all penalties and other monetary obligations due under the terms of the consent decree.

Paragraph 113.d – Cokenergy completed the SEP, as specified in Section VII. The completion report was submitted to the government by Cokenergy on December 16, 2020. Cokenergy was notified by the government on January 21, 2021, that the Lead Hazard Reduction SEP project was satisfactorily performed.

Paragraph 113.e – Cokenergy has incorporated the annual Bypass Venting limits in Paragraph 14.; and the requirement to operate and maintain a permanent flow monitor in Paragraph 19 into the Indiana Environmental Rules Board's site-specific SIP revisions and Title V operating permits.

Cokenergy formally submitted our request to modify the SIP on December 18, 2018, within the ninety (90) day requirement specified in the CD. IDEM developed the draft rule LSA Document #19-388 which was posted on August 14, 2019, for public comment. The initial public hearing was held on November 13, 2019. There were no public comments during the comment period or initial public hearing. The final public hearing was completed on January 8, 2020. The rule was approved and published in the Indiana Register on April 25, 2020.

IDEM issued the Significant Source Modification (089-40905-00383) and Significant Permit Modification (089-41033-00383) for Public Comment on March 4, 2019. The Public Comment period ended on April 3, 2019. The approved Significant Source Modification was issued by IDEM on April 18, 2019, and the approved Significant Permit Modification was issued by IDEM on May 8, 2019.

Paragraph 113.f – Cokenergy has operated more than (18) months in satisfactory compliance with the emission limits established in Paragraph 14, 15 and 16.

Paragraph 14. - Annual Bypass Venting

- Bypass venting for the period of January 1, 2017 – December 31, 2017, was 7.72% versus the limit of 12%.
- Bypass venting for the period of January 1, 2018 – December 31, 2018, was 6.00% versus the limit of 12%.
- Bypass venting for the period of January 1, 2019 – December 31, 2019, was 5.26% versus the limit of 12%.
- Bypass venting for the period of January 1, 2020 – December 31, 2020, was 7.00% versus the limit of 13%.
- Bypass venting for the period of January 1, 2021 – July 31, 2021, was 2.81% versus the limit of 13%.

Paragraph 15. – Daily Bypass Venting

- During the period of effective date of the consent decree of October 25, 2018, and July 31, 2021 (more than 33 months), there have been no incidents of exceedance of the Daily Bypass Venting Limit of 19%. Details of the daily bypass venting are provided in Attachment I.

Paragraph 16. – SO₂ Daily Limit

- During the period of effective date of the consent decree of October 25, 2018, and July 31, 2021 (more than 33 months), there have been no incidents of exceedance of the Daily SO₂ limit of 1,656 lbs/hr for a twenty-four (24) hour average. Details of the daily SO₂ averages are provided in Attachment 2.

Certification of Completion

Paragraph 114.a – Prior to moving for termination as provided in Paragraph 113, a Defendant shall certify completion of the requirements in Paragraph 113. Cokenergy's certification statement is included as the closing of this report.

Paragraph 114.b. – The Defendant seeking termination shall submit a written report to the United States and Indiana describing activities undertaken to comply with the requirements of this Consent Decree and certifying that the permits are issued in final form. Details on the satisfactory completion of conditions for termination set forth in Paragraph 113 are provided above and details on other activities undertaken to comply with the Consent Decree are provided in the following paragraphs as well as in previously submitted semiannual reports that have been entered by Cokenergy, which are incorporated herein by reference.

Enhanced Monitoring

Paragraph 19. – Permanent Flow Monitor

- Cokenergy installed a permanent flow monitor on the Main Stack and the initial certification testing was completed on September 14, 2018. The initial certification testing included a 7-day drift test and a Relative Accuracy Test Audit (RATA). Cokenergy submitted the initial certification report to the government and East Chicago Public Libraries on October 17, 2018. IDEM notified Cokenergy on November 16, 2018, that the monitor successfully demonstrated compliance with the requirements of Performance Specification (PS) 6 of 40 CFR 60, Appendix B.

Paragraph 21. – ETS Updates

- The Main Stack flow monitor was incorporated into ETS on November 27, 2018, to allow for the calculation of SO₂ emissions from the Main Stack using the actual stack volumetric flow rate. ETS continues to utilize in its emission calculations a monthly average of Sulfur Content and moisture content.

Paragraph 22. – Bypass Vent Stack and Main Stack Testing

- Cokenergy completed lead and VOC testing on the Main Stack in accordance with the applicable requirements of 40 C.F.R Part 60, Appendix A over the period of December 4-6, 2019. Cokenergy submitted a Test Protocol to IDEM on October 8, 2019. The final report was submitted on January 20, 2020.
- Cokenergy completed the second lead stack test on June 9, 2021, for which the Test Protocol was submitted to IDEM on April 27, 2021. The final report for the second test was submitted on July 19, 2021.

Paragraph 22a. – Lead Testing

- Cokenergy completed the lead stack testing on December 5 and 6, 2019. The results from the lead emission testing averaged 0.014 lbs/hr, which is well below IHCC's lead emission limit of 0.19 lbs/hr.
- Cokenergy completed the second lead stack test on June 9, 2021. The results from the lead emission testing averaged 0.00202 lbs/hr, which is well below IHCC's lead emission limit of 0.19 lbs/hr.

Paragraph 22b. – VOC Testing

- Cokenergy completed the VOC stack testing on December 4, 2019. The results from the VOC emission testing averaged 1.47 lbs/hr, which is well below IHCC's VOC emission limit of 2.28 lbs/hr.

Preventive Maintenance and Operation Plans

Paragraphs 23 and 23.b. – Cokenergy PMO Plan for HRSGs and FGD

- Cokenergy submitted our PMO plan to the government on June 28, 2018. The government provided notification of their conditional approval of the PMO plan on August 24, 2018. Cokenergy provided our response to the government's comments on December 12, 2018, and the government provided final approval of the PMO plan on February 12, 2019.

Paragraph 23.c. – Compliance Assurance

- The CAP is addressed in Section 9.0 of Cokenergy's PMO Plan. IHCC has not reported production levels in excess of rates included in 23. c. i. during the effective period starting on October 25, 2018.

Paragraph 23.d. – *Defendants shall comply with the PMO Plans at all times, including periods of startup, shutdown, and malfunction of the HRSG and FGD.*

- Cokenergy has fully implemented our PMO plan and is following the requirements of the PMO plan.

Mitigation Measures

Paragraph 24 – Dual SDA Operation


- Cokenergy has successfully operated the SDAs in dual operation mode prior to the effective date of the CD, except during periods of planned maintenance as referenced in the PMO Plan.
- SO₂ emissions for the effective period of 10/25/18 through 12/31/18 was 1,135.7 tons versus the limit of 1,148.5 tons (6,165 tons prorated for 68 days).
- SO₂ emissions for 2019 were 5,484 tons.
- SO₂ emissions for 2020 were 6,019 tons.
- SO₂ emissions for the period of 1/1/21 – 7/31/21 are 3,503 tons, which projects to be below the limit of 6,665 tons.

If you have any questions or require additional information regarding our termination request, please contact me at (219) 397-4626 or email at lford@primaryenergy.com.

Certification

To the best of my knowledge, after appropriate investigation, I certify that the information contained in or accompanying this submission is true, accurate and complete. I am aware that there are penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,



Luke E. Ford
Director EH&S
Primary Energy

cc: East Chicago Public Library
2401 E. Columbus Drive
East Chicago, Indiana 46312

East Chicago Public Library
1008 W. Chicago Avenue
East Chicago, Indiana 46312

File: X://675

Attachment 1 – Daily Bypass Venting Data

Date	Daily Bypass Venting %
10/25/2018	10.13
10/26/2018	15.42
10/27/2018	16.18
10/28/2018	16.18
10/29/2018	12.16
10/30/2018	8.91
10/31/2018	3.68
11/1/2018	3.68
11/2/2018	3.69
11/3/2018	3.68
11/4/2018	3.68
11/5/2018	3.68
11/6/2018	3.68
11/7/2018	3.68
11/8/2018	6.62
11/9/2018	7.18
11/10/2018	13.64
11/11/2018	5.15
11/12/2018	5.88
11/13/2018	5.88
11/14/2018	5.88
11/15/2018	5.88
11/16/2018	5.88
11/17/2018	5.88
11/18/2018	5.88
11/19/2018	7.53
11/20/2018	5.88
11/21/2018	5.88
11/22/2018	5.88
11/23/2018	5.88
11/24/2018	5.88
11/25/2018	7.35
11/26/2018	8.27
11/27/2018	8.82
11/28/2018	8.82
11/29/2018	6.86
11/30/2018	2.57
12/1/2018	2.57
12/2/2018	2.57
12/3/2018	2.61
12/4/2018	4.33

Date	Daily Bypass Venting %
12/5/2018	2.57
12/6/2018	4.51
12/7/2018	2.59
12/8/2018	2.57
12/9/2018	2.75
12/10/2018	2.57
12/11/2018	4.78
12/12/2018	2.57
12/13/2018	2.57
12/14/2018	2.57
12/15/2018	2.57
12/16/2018	2.57
12/17/2018	2.59
12/18/2018	2.57
12/19/2018	2.57
12/20/2018	4.77
12/21/2018	2.57
12/22/2018	2.57
12/23/2018	2.57
12/24/2018	2.57
12/25/2018	2.57
12/26/2018	2.57
12/27/2018	2.57
12/28/2018	2.57
12/29/2018	2.57
12/30/2018	2.57
12/31/2018	2.57
1/1/2019	2.57
1/2/2019	2.57
1/3/2019	2.57
1/4/2019	2.57
1/5/2019	2.57
1/6/2019	2.77
1/7/2019	2.57
1/8/2019	2.57
1/9/2019	2.77
1/10/2019	2.57
1/11/2019	2.59
1/12/2019	2.57
1/13/2019	2.57
1/14/2019	2.57

Date	Daily Bypass Venting %
1/15/2019	2.57
1/16/2019	2.57
1/17/2019	2.57
1/18/2019	1.84
1/19/2019	1.47
1/20/2019	1.10
1/21/2019	1.15
1/22/2019	0.74
1/23/2019	0.00
1/24/2019	0.16
1/25/2019	3.82
1/26/2019	0.20
1/27/2019	0.00
1/28/2019	0.02
1/29/2019	0.36
1/30/2019	9.77
1/31/2019	0.74
2/1/2019	0.25
2/2/2019	0.00
2/3/2019	0.13
2/4/2019	0.00
2/5/2019	0.00
2/6/2019	0.00
2/7/2019	0.00
2/8/2019	0.00
2/9/2019	0.00
2/10/2019	0.00
2/11/2019	0.00
2/12/2019	0.04
2/13/2019	0.00
2/14/2019	0.00
2/15/2019	0.00
2/16/2019	0.02
2/17/2019	0.06
2/18/2019	0.01
2/19/2019	0.00
2/20/2019	0.09
2/21/2019	1.03
2/22/2019	0.00
2/23/2019	0.01
2/24/2019	0.23

Date	Daily Bypass Venting %
2/25/2019	0.00
2/26/2019	0.04
2/27/2019	1.96
2/28/2019	0.00
3/1/2019	0.27
3/2/2019	0.15
3/3/2019	0.12
3/4/2019	0.44
3/5/2019	0.00
3/6/2019	0.53
3/7/2019	1.08
3/8/2019	0.52
3/9/2019	2.81
3/10/2019	7.07
3/11/2019	6.44
3/12/2019	7.57
3/13/2019	9.09
3/14/2019	6.76
3/15/2019	6.25
3/16/2019	6.25
3/17/2019	6.36
3/18/2019	6.25
3/19/2019	6.25
3/20/2019	4.30
3/21/2019	5.20
3/22/2019	6.25
3/23/2019	6.25
3/24/2019	6.25
3/25/2019	6.25
3/26/2019	6.63
3/27/2019	4.60
3/28/2019	5.14
3/29/2019	6.25
3/30/2019	6.25
3/31/2019	6.25
4/1/2019	6.25
4/2/2019	8.00
4/3/2019	7.42
4/4/2019	6.25
4/5/2019	3.77
4/6/2019	0.00

Date	Daily Bypass Venting %
4/7/2019	0.00
4/8/2019	0.81
4/9/2019	0.68
4/10/2019	0.00
4/11/2019	1.90
4/12/2019	4.69
4/13/2019	4.69
4/14/2019	5.68
4/15/2019	4.73
4/16/2019	4.86
4/17/2019	4.69
4/18/2019	5.03
4/19/2019	4.69
4/20/2019	4.69
4/21/2019	4.69
4/22/2019	4.82
4/23/2019	4.89
4/24/2019	4.69
4/25/2019	10.01
4/26/2019	11.26
4/27/2019	11.06
4/28/2019	10.94
4/29/2019	11.17
4/30/2019	11.01
5/1/2019	12.37
5/2/2019	10.97
5/3/2019	7.45
5/4/2019	4.69
5/5/2019	4.91
5/6/2019	4.69
5/7/2019	4.69
5/8/2019	4.69
5/9/2019	8.99
5/10/2019	10.94
5/11/2019	11.08
5/12/2019	10.94
5/13/2019	10.94
5/14/2019	10.94
5/15/2019	8.99
5/16/2019	10.40
5/17/2019	10.94

Date	Daily Bypass Venting %
5/18/2019	11.01
5/19/2019	11.80
5/20/2019	11.03
5/21/2019	11.04
5/22/2019	10.94
5/23/2019	7.77
5/24/2019	4.70
5/25/2019	4.69
5/26/2019	4.82
5/27/2019	11.30
5/28/2019	4.69
5/29/2019	4.69
5/30/2019	12.88
5/31/2019	4.69
6/1/2019	4.69
6/2/2019	3.91
6/3/2019	3.91
6/4/2019	3.91
6/5/2019	3.91
6/6/2019	3.91
6/7/2019	3.91
6/8/2019	3.91
6/9/2019	6.45
6/10/2019	3.91
6/11/2019	4.17
6/12/2019	3.91
6/13/2019	4.37
6/14/2019	3.52
6/15/2019	3.52
6/16/2019	3.52
6/17/2019	3.65
6/18/2019	3.71
6/19/2019	3.80
6/20/2019	4.11
6/21/2019	2.73
6/22/2019	1.56
6/23/2019	1.56
6/24/2019	2.19
6/25/2019	0.00
6/26/2019	0.23
6/27/2019	0.00

Date	Daily Bypass Venting %
6/28/2019	0.03
6/29/2019	0.00
6/30/2019	0.00
7/1/2019	0.47
7/2/2019	2.37
7/3/2019	0.00
7/4/2019	0.00
7/5/2019	0.00
7/6/2019	0.41
7/7/2019	2.94
7/8/2019	4.90
7/9/2019	5.19
7/10/2019	5.45
7/11/2019	9.03
7/12/2019	11.54
7/13/2019	13.97
7/14/2019	14.71
7/15/2019	14.71
7/16/2019	14.95
7/17/2019	15.58
7/18/2019	12.00
7/19/2019	6.25
7/20/2019	6.25
7/21/2019	6.90
7/22/2019	6.25
7/23/2019	6.87
7/24/2019	11.12
7/25/2019	12.52
7/26/2019	12.28
7/27/2019	12.13
7/28/2019	12.13
7/29/2019	12.20
7/30/2019	12.13
7/31/2019	12.44
8/1/2019	10.22
8/2/2019	6.25
8/3/2019	6.58
8/4/2019	6.81
8/5/2019	6.32
8/6/2019	9.46
8/7/2019	3.36

Date	Daily Bypass Venting %
8/8/2019	0.00
8/9/2019	0.00
8/10/2019	0.74
8/11/2019	1.47
8/12/2019	1.84
8/13/2019	5.68
8/14/2019	8.09
8/15/2019	8.09
8/16/2019	8.15
8/17/2019	8.14
8/18/2019	8.09
8/19/2019	8.09
8/20/2019	8.09
8/21/2019	9.72
8/22/2019	8.09
8/23/2019	8.28
8/24/2019	8.09
8/25/2019	8.09
8/26/2019	7.31
8/27/2019	8.04
8/28/2019	9.15
8/29/2019	9.16
8/30/2019	7.51
8/31/2019	6.25
9/1/2019	6.25
9/2/2019	6.25
9/3/2019	6.25
9/4/2019	6.34
9/5/2019	6.32
9/6/2019	6.95
9/7/2019	6.25
9/8/2019	6.25
9/9/2019	4.30
9/10/2019	2.15
9/11/2019	5.15
9/12/2019	5.15
9/13/2019	4.46
9/14/2019	0.52
9/15/2019	1.10
9/16/2019	1.17
9/17/2019	1.10

Date	Daily Bypass Venting %
9/18/2019	1.10
9/19/2019	4.81
9/20/2019	7.46
9/21/2019	7.35
9/22/2019	7.35
9/23/2019	16.16
9/24/2019	13.60
9/25/2019	13.60
9/26/2019	13.60
9/27/2019	13.60
9/28/2019	13.60
9/29/2019	10.47
9/30/2019	9.57
10/1/2019	7.35
10/2/2019	7.35
10/3/2019	7.38
10/4/2019	7.18
10/5/2019	5.87
10/6/2019	7.35
10/7/2019	8.32
10/8/2019	10.07
10/9/2019	9.70
10/10/2019	9.76
10/11/2019	9.93
10/12/2019	12.50
10/13/2019	10.00
10/14/2019	9.51
10/15/2019	13.08
10/16/2019	9.86
10/17/2019	9.79
10/18/2019	11.05
10/19/2019	9.70
10/20/2019	9.70
10/21/2019	13.71
10/22/2019	12.70
10/23/2019	9.70
10/24/2019	7.66
10/25/2019	3.45
10/26/2019	3.46
10/27/2019	3.45
10/28/2019	4.53

Date	Daily Bypass Venting %
10/29/2019	3.45
10/30/2019	4.62
10/31/2019	6.18
11/1/2019	6.18
11/2/2019	6.18
11/3/2019	6.18
11/4/2019	5.59
11/5/2019	3.55
11/6/2019	1.28
11/7/2019	2.05
11/8/2019	1.13
11/9/2019	1.10
11/10/2019	1.45
11/11/2019	1.12
11/12/2019	2.61
11/13/2019	3.30
11/14/2019	4.42
11/15/2019	2.04
11/16/2019	1.17
11/17/2019	1.10
11/18/2019	1.10
11/19/2019	1.10
11/20/2019	1.30
11/21/2019	1.10
11/22/2019	1.10
11/23/2019	1.10
11/24/2019	1.18
11/25/2019	1.11
11/26/2019	2.93
11/27/2019	1.61
11/28/2019	1.10
11/29/2019	2.23
11/30/2019	2.94
12/1/2019	2.94
12/2/2019	2.94
12/3/2019	2.94
12/4/2019	2.94
12/5/2019	2.94
12/6/2019	8.82
12/7/2019	2.94
12/8/2019	2.94

Date	Daily Bypass Venting %
12/9/2019	2.94
12/10/2019	7.06
12/11/2019	8.82
12/12/2019	10.95
12/13/2019	9.60
12/14/2019	9.19
12/15/2019	9.27
12/16/2019	9.19
12/17/2019	9.19
12/18/2019	9.19
12/19/2019	7.46
12/20/2019	6.35
12/21/2019	6.25
12/22/2019	6.25
12/23/2019	6.25
12/24/2019	6.25
12/25/2019	6.25
12/26/2019	6.25
12/27/2019	6.25
12/28/2019	5.04
12/29/2019	0.00
12/30/2019	1.96
12/31/2019	9.51
1/1/2020	11.35
1/2/2020	11.35
1/3/2020	7.62
1/4/2020	6.25
1/5/2020	6.25
1/6/2020	6.25
1/7/2020	6.25
1/8/2020	6.25
1/9/2020	6.32
1/10/2020	6.27
1/11/2020	6.25
1/12/2020	6.25
1/13/2020	6.25
1/14/2020	6.27
1/15/2020	6.25
1/16/2020	6.25
1/17/2020	6.25
1/18/2020	6.25

Date	Daily Bypass Venting %
1/19/2020	5.33
1/20/2020	0.00
1/21/2020	4.56
1/22/2020	6.64
1/23/2020	6.26
1/24/2020	6.31
1/25/2020	6.29
1/26/2020	6.25
1/27/2020	6.25
1/28/2020	6.25
1/29/2020	6.26
1/30/2020	6.25
1/31/2020	6.25
2/1/2020	6.32
2/2/2020	6.25
2/3/2020	6.34
2/4/2020	6.25
2/5/2020	6.38
2/6/2020	6.29
2/7/2020	4.57
2/8/2020	0.00
2/9/2020	0.00
2/10/2020	4.66
2/11/2020	6.25
2/12/2020	6.25
2/13/2020	6.25
2/14/2020	6.25
2/15/2020	6.25
2/16/2020	6.25
2/17/2020	6.25
2/18/2020	6.25
2/19/2020	6.25
2/20/2020	6.25
2/21/2020	6.36
2/22/2020	6.25
2/23/2020	6.25
2/24/2020	6.25
2/25/2020	6.25
2/26/2020	6.25
2/27/2020	6.36
2/28/2020	6.25

Date	Daily Bypass Venting %
2/29/2020	6.25
3/1/2020	6.25
3/2/2020	6.25
3/3/2020	9.54
3/4/2020	12.50
3/5/2020	12.53
3/6/2020	12.50
3/7/2020	11.81
3/8/2020	6.29
3/9/2020	6.25
3/10/2020	6.27
3/11/2020	6.25
3/12/2020	6.25
3/13/2020	6.25
3/14/2020	6.27
3/15/2020	6.25
3/16/2020	6.25
3/17/2020	6.37
3/18/2020	6.25
3/19/2020	6.31
3/20/2020	12.32
3/21/2020	12.50
3/22/2020	12.50
3/23/2020	12.50
3/24/2020	11.72
3/25/2020	11.72
3/26/2020	15.89
3/27/2020	12.68
3/28/2020	6.28
3/29/2020	6.25
3/30/2020	6.25
3/31/2020	6.25
4/1/2020	6.26
4/2/2020	3.91
4/3/2020	0.00
4/4/2020	0.00
4/5/2020	0.00
4/6/2020	3.36
4/7/2020	6.25
4/8/2020	6.25
4/9/2020	6.25

Date	Daily Bypass Venting %
4/10/2020	6.25
4/11/2020	6.25
4/12/2020	6.26
4/13/2020	6.25
4/14/2020	6.25
4/15/2020	4.47
4/16/2020	0.00
4/17/2020	0.00
4/18/2020	0.00
4/19/2020	0.00
4/20/2020	0.00
4/21/2020	0.55
4/22/2020	0.00
4/23/2020	0.00
4/24/2020	0.00
4/25/2020	0.02
4/26/2020	0.12
4/27/2020	0.14
4/28/2020	0.01
4/29/2020	1.79
4/30/2020	0.26
5/1/2020	0.00
5/2/2020	0.00
5/3/2020	0.00
5/4/2020	0.00
5/5/2020	0.04
5/6/2020	0.24
5/7/2020	0.09
5/8/2020	0.00
5/9/2020	0.00
5/10/2020	0.00
5/11/2020	0.00
5/12/2020	0.18
5/13/2020	0.01
5/14/2020	0.00
5/15/2020	0.00
5/16/2020	0.00
5/17/2020	0.00
5/18/2020	0.16
5/19/2020	0.00
5/20/2020	0.72

Date	Daily Bypass Venting %
5/21/2020	3.19
5/22/2020	0.01
5/23/2020	0.00
5/24/2020	0.00
5/25/2020	0.00
5/26/2020	0.07
5/27/2020	0.00
5/28/2020	0.30
5/29/2020	0.00
5/30/2020	0.07
5/31/2020	0.00
6/1/2020	0.04
6/2/2020	0.00
6/3/2020	0.00
6/4/2020	0.00
6/5/2020	0.19
6/6/2020	0.02
6/7/2020	0.00
6/8/2020	4.65
6/9/2020	5.89
6/10/2020	6.42
6/11/2020	5.88
6/12/2020	6.29
6/13/2020	5.88
6/14/2020	5.88
6/15/2020	6.33
6/16/2020	5.88
6/17/2020	5.88
6/18/2020	6.02
6/19/2020	5.88
6/20/2020	5.88
6/21/2020	5.88
6/22/2020	5.88
6/23/2020	5.88
6/24/2020	5.88
6/25/2020	10.52
6/26/2020	12.13
6/27/2020	12.13
6/28/2020	12.13
6/29/2020	12.15
6/30/2020	12.85

Date	Daily Bypass Venting %
7/1/2020	12.13
7/2/2020	10.84
7/3/2020	12.14
7/4/2020	12.13
7/5/2020	12.13
7/6/2020	12.78
7/7/2020	12.16
7/8/2020	14.57
7/9/2020	13.40
7/10/2020	9.01
7/11/2020	6.33
7/12/2020	6.25
7/13/2020	6.25
7/14/2020	6.29
7/15/2020	6.25
7/16/2020	8.68
7/17/2020	5.88
7/18/2020	5.88
7/19/2020	5.88
7/20/2020	5.52
7/21/2020	5.52
7/22/2020	5.52
7/23/2020	10.60
7/24/2020	9.84
7/25/2020	6.25
7/26/2020	6.25
7/27/2020	6.51
7/28/2020	6.66
7/29/2020	6.25
7/30/2020	4.21
7/31/2020	0.00
8/1/2020	0.00
8/2/2020	0.01
8/3/2020	0.00
8/4/2020	0.00
8/5/2020	0.00
8/6/2020	1.73
8/7/2020	0.87
8/8/2020	0.00
8/9/2020	1.43
8/10/2020	3.14

Date	Daily Bypass Venting %
8/11/2020	0.61
8/12/2020	0.88
8/13/2020	7.93
8/14/2020	8.65
8/15/2020	11.34
8/16/2020	11.77
8/17/2020	11.77
8/18/2020	11.77
8/19/2020	9.16
8/20/2020	10.46
8/21/2020	9.37
8/22/2020	6.25
8/23/2020	6.36
8/24/2020	6.25
8/25/2020	6.25
8/26/2020	6.25
8/27/2020	3.78
8/28/2020	0.62
8/29/2020	0.00
8/30/2020	0.00
8/31/2020	0.00
9/1/2020	0.00
9/2/2020	0.12
9/3/2020	0.00
9/4/2020	0.00
9/5/2020	2.47
9/6/2020	6.25
9/7/2020	6.35
9/8/2020	6.27
9/9/2020	6.25
9/10/2020	6.26
9/11/2020	6.25
9/12/2020	6.25
9/13/2020	6.25
9/14/2020	6.25
9/15/2020	6.25
9/16/2020	6.25
9/17/2020	6.25
9/18/2020	6.25
9/19/2020	4.23
9/20/2020	0.00

Date	Daily Bypass Venting %
9/21/2020	0.37
9/22/2020	0.00
9/23/2020	0.00
9/24/2020	1.62
9/25/2020	0.00
9/26/2020	0.00
9/27/2020	0.00
9/28/2020	0.04
9/29/2020	3.52
9/30/2020	0.04
10/1/2020	5.27
10/2/2020	6.25
10/3/2020	6.25
10/4/2020	6.25
10/5/2020	10.54
10/6/2020	12.13
10/7/2020	10.14
10/8/2020	8.88
10/9/2020	6.00
10/10/2020	5.52
10/11/2020	5.52
10/12/2020	5.52
10/13/2020	4.02
10/14/2020	0.00
10/15/2020	5.27
10/16/2020	6.25
10/17/2020	6.25
10/18/2020	7.40
10/19/2020	6.25
10/20/2020	6.25
10/21/2020	4.30
10/22/2020	5.34
10/23/2020	6.25
10/24/2020	6.25
10/25/2020	6.25
10/26/2020	6.25
10/27/2020	6.25
10/28/2020	3.41
10/29/2020	0.00
10/30/2020	0.10
10/31/2020	0.09

Date	Daily Bypass Venting %
11/1/2020	0.00
11/2/2020	0.00
11/3/2020	2.11
11/4/2020	0.54
11/5/2020	0.00
11/6/2020	0.01
11/7/2020	0.00
11/8/2020	0.00
11/9/2020	0.78
11/10/2020	2.15
11/11/2020	0.00
11/12/2020	0.00
11/13/2020	0.00
11/14/2020	0.00
11/15/2020	0.00
11/16/2020	0.00
11/17/2020	0.00
11/18/2020	0.00
11/19/2020	0.04
11/20/2020	0.00
11/21/2020	0.00
11/22/2020	0.00
11/23/2020	0.00
11/24/2020	0.00
11/25/2020	0.02
11/26/2020	0.00
11/27/2020	0.02
11/28/2020	0.04
11/29/2020	0.00
11/30/2020	0.00
12/1/2020	0.00
12/2/2020	0.00
12/3/2020	0.15
12/4/2020	0.82
12/5/2020	0.00
12/6/2020	0.00
12/7/2020	0.06
12/8/2020	0.00
12/9/2020	0.00
12/10/2020	0.00
12/11/2020	0.11

Date	Daily Bypass Venting %
12/12/2020	0.00
12/13/2020	0.00
12/14/2020	0.00
12/15/2020	0.20
12/16/2020	0.10
12/17/2020	0.37
12/18/2020	0.01
12/19/2020	0.06
12/20/2020	0.00
12/21/2020	0.07
12/22/2020	0.00
12/23/2020	0.02
12/24/2020	0.01
12/25/2020	0.00
12/26/2020	0.00
12/27/2020	0.00
12/28/2020	0.00
12/29/2020	2.14
12/30/2020	0.17
12/31/2020	0.00
1/1/2021	0.00
1/2/2021	0.00
1/3/2021	0.00
1/4/2021	0.00
1/5/2021	0.00
1/6/2021	0.00
1/7/2021	0.00
1/8/2021	0.00
1/9/2021	0.00
1/10/2021	0.00
1/11/2021	0.10
1/12/2021	0.05
1/13/2021	0.00
1/14/2021	0.10
1/15/2021	0.01
1/16/2021	0.06
1/17/2021	0.04
1/18/2021	0.01
1/19/2021	0.00
1/20/2021	0.04
1/21/2021	0.00

Date	Daily Bypass Venting %
1/22/2021	1.84
1/23/2021	0.09
1/24/2021	0.00
1/25/2021	0.00
1/26/2021	0.00
1/27/2021	0.12
1/28/2021	0.32
1/29/2021	0.00
1/30/2021	0.00
1/31/2021	0.00
2/1/2021	0.00
2/2/2021	0.00
2/3/2021	0.00
2/4/2021	0.14
2/5/2021	0.30
2/6/2021	0.23
2/7/2021	0.39
2/8/2021	2.51
2/9/2021	3.36
2/10/2021	0.37
2/11/2021	0.39
2/12/2021	0.48
2/13/2021	0.59
2/14/2021	0.55
2/15/2021	1.28
2/16/2021	0.47
2/17/2021	0.25
2/18/2021	0.66
2/19/2021	0.01
2/20/2021	0.06
2/21/2021	0.01
2/22/2021	0.00
2/23/2021	0.02
2/24/2021	0.21
2/25/2021	0.18
2/26/2021	0.18
2/27/2021	0.13
2/28/2021	0.13
3/1/2021	3.26
3/2/2021	6.29
3/3/2021	6.73

Date	Daily Bypass Venting %
3/4/2021	4.82
3/5/2021	0.00
3/6/2021	0.02
3/7/2021	0.01
3/8/2021	3.33
3/9/2021	10.10
3/10/2021	6.25
3/11/2021	6.25
3/12/2021	3.04
3/13/2021	0.00
3/14/2021	0.06
3/15/2021	6.91
3/16/2021	6.25
3/17/2021	6.25
3/18/2021	6.27
3/19/2021	6.25
3/20/2021	4.15
3/21/2021	0.00
3/22/2021	3.70
3/23/2021	6.16
3/24/2021	5.88
3/25/2021	3.67
3/26/2021	0.19
3/27/2021	0.00
3/28/2021	0.00
3/29/2021	0.26
3/30/2021	5.69
3/31/2021	0.00
4/1/2021	0.00
4/2/2021	0.00
4/3/2021	0.00
4/4/2021	0.00
4/5/2021	4.99
4/6/2021	6.25
4/7/2021	6.25
4/8/2021	6.25
4/9/2021	3.97
4/10/2021	0.02
4/11/2021	0.00
4/12/2021	4.65
4/13/2021	5.88

Date	Daily Bypass Venting %
4/14/2021	5.90
4/15/2021	9.72
4/16/2021	6.71
4/17/2021	6.25
4/18/2021	6.51
4/19/2021	17.22
4/20/2021	15.14
4/21/2021	14.20
4/22/2021	12.50
4/23/2021	7.44
4/24/2021	0.00
4/25/2021	0.48
4/26/2021	0.14
4/27/2021	0.00
4/28/2021	0.08
4/29/2021	0.00
4/30/2021	0.09
5/1/2021	0.00
5/2/2021	0.00
5/3/2021	0.00
5/4/2021	0.00
5/5/2021	0.45
5/6/2021	0.04
5/7/2021	0.00
5/8/2021	0.00
5/9/2021	0.16
5/10/2021	0.00
5/11/2021	0.00
5/12/2021	0.62
5/13/2021	2.09
5/14/2021	0.00
5/15/2021	0.00
5/16/2021	0.00
5/17/2021	0.00
5/18/2021	0.04
5/19/2021	0.00
5/20/2021	0.00
5/21/2021	0.00
5/22/2021	0.00
5/23/2021	0.00
5/24/2021	0.00

Date	Daily Bypass Venting %
5/25/2021	0.00
5/26/2021	0.00
5/27/2021	0.00
5/28/2021	1.72
5/29/2021	0.00
5/30/2021	0.00
5/31/2021	0.04
6/1/2021	0.12
6/2/2021	0.00
6/3/2021	0.03
6/4/2021	0.18
6/5/2021	0.00
6/6/2021	0.14
6/7/2021	0.00
6/8/2021	0.09
6/9/2021	0.00
6/10/2021	4.69
6/11/2021	6.37
6/12/2021	6.38
6/13/2021	6.25
6/14/2021	11.13
6/15/2021	12.50
6/16/2021	10.42
6/17/2021	8.07
6/18/2021	6.25
6/19/2021	6.25
6/20/2021	6.25
6/21/2021	6.25
6/22/2021	6.25
6/23/2021	3.58
6/24/2021	4.69
6/25/2021	6.56
6/26/2021	6.25
6/27/2021	6.25
6/28/2021	7.51
6/29/2021	6.96
6/30/2021	7.06
7/1/2021	5.41
7/2/2021	1.10
7/3/2021	2.80
7/4/2021	5.99

Date	Daily Bypass Venting %
7/5/2021	0.74
7/6/2021	1.86
7/7/2021	2.01
7/8/2021	5.48
7/9/2021	6.62
7/10/2021	6.62
7/11/2021	6.62
7/12/2021	6.62
7/13/2021	6.62
7/14/2021	3.76
7/15/2021	5.21
7/16/2021	6.62
7/17/2021	6.62
7/18/2021	6.62
7/19/2021	7.41
7/20/2021	7.45
7/21/2021	5.86
7/22/2021	5.74
7/23/2021	6.31
7/24/2021	6.28
7/25/2021	6.67
7/26/2021	7.00
7/27/2021	6.67
7/28/2021	6.63
7/29/2021	8.42
7/30/2021	6.99
7/31/2021	6.99

Attachment 2 – Daily SO₂ Averages

Date	Daily SO2 Emissions, 24-hr Average
10/25/2018	1,565
10/26/2018	1,567
10/27/2018	1,621
10/28/2018	1,499
10/29/2018	1,551
10/30/2018	1,548
10/31/2018	1,530
11/1/2018	1,514
11/2/2018	1,548
11/3/2018	1,509
11/4/2018	1,489
11/5/2018	1,515
11/6/2018	1,543
11/7/2018	1,562
11/8/2018	1,534
11/9/2018	1,575
11/10/2018	1,650
11/11/2018	1,557
11/12/2018	1,559
11/13/2018	1,558
11/14/2018	1,550
11/15/2018	1,519
11/16/2018	1,534
11/17/2018	1,501
11/18/2018	1,555
11/19/2018	1,524
11/20/2018	1,510
11/21/2018	1,531
11/22/2018	1,515
11/23/2018	1,507
11/24/2018	1,500
11/25/2018	1,529
11/26/2018	1,518
11/27/2018	1,401
11/28/2018	1,345
11/29/2018	1,262
11/30/2018	1,311
12/1/2018	1,274
12/2/2018	1,302
12/3/2018	1,245

Date	Daily SO2 Emissions, 24-hr Average
12/4/2018	1,260
12/5/2018	1,251
12/6/2018	1,299
12/7/2018	1,235
12/8/2018	1,261
12/9/2018	1,253
12/10/2018	1,290
12/11/2018	1,308
12/12/2018	1,324
12/13/2018	1,312
12/14/2018	1,246
12/15/2018	1,306
12/16/2018	1,282
12/17/2018	1,292
12/18/2018	1,326
12/19/2018	1,330
12/20/2018	1,315
12/21/2018	1,292
12/22/2018	1,291
12/23/2018	1,284
12/24/2018	1,331
12/25/2018	1,299
12/26/2018	1,322
12/27/2018	1,299
12/28/2018	1,330
12/29/2018	1,338
12/30/2018	1,316
12/31/2018	1,323
1/1/2019	1,285
1/2/2019	1,269
1/3/2019	1,188
1/4/2019	1,289
1/5/2019	1,295
1/6/2019	1,322
1/7/2019	1,331
1/8/2019	1,291
1/9/2019	1,283
1/10/2019	1,273
1/11/2019	1,283
1/12/2019	1,254

Date	Daily SO2 Emissions, 24-hr Average
1/13/2019	1,291
1/14/2019	1,317
1/15/2019	1,310
1/16/2019	1,297
1/17/2019	1,275
1/18/2019	1,295
1/19/2019	1,295
1/20/2019	1,285
1/21/2019	1,309
1/22/2019	1,296
1/23/2019	1,135
1/24/2019	1,302
1/25/2019	1,257
1/26/2019	1,286
1/27/2019	1,277
1/28/2019	1,307
1/29/2019	1,292
1/30/2019	1,091
1/31/2019	462
2/1/2019	870
2/2/2019	1,170
2/3/2019	1,240
2/4/2019	1,247
2/5/2019	1,331
2/6/2019	1,252
2/7/2019	1,233
2/8/2019	1,308
2/9/2019	1,317
2/10/2019	1,293
2/11/2019	1,277
2/12/2019	1,253
2/13/2019	1,300
2/14/2019	1,300
2/15/2019	1,340
2/16/2019	1,292
2/17/2019	1,287
2/18/2019	1,301
2/19/2019	1,303
2/20/2019	1,299
2/21/2019	1,264

Date	Daily SO2 Emissions, 24-hr Average
2/22/2019	1,318
2/23/2019	1,282
2/24/2019	1,120
2/25/2019	1,223
2/26/2019	1,267
2/27/2019	1,231
2/28/2019	1,334
3/1/2019	1,297
3/2/2019	1,278
3/3/2019	1,246
3/4/2019	1,315
3/5/2019	1,246
3/6/2019	1,314
3/7/2019	1,277
3/8/2019	1,313
3/9/2019	1,228
3/10/2019	1,339
3/11/2019	1,248
3/12/2019	1,289
3/13/2019	1,254
3/14/2019	1,311
3/15/2019	1,228
3/16/2019	1,263
3/17/2019	1,275
3/18/2019	1,269
3/19/2019	1,345
3/20/2019	1,283
3/21/2019	1,319
3/22/2019	1,299
3/23/2019	1,317
3/24/2019	1,289
3/25/2019	1,267
3/26/2019	1,290
3/27/2019	1,301
3/28/2019	1,283
3/29/2019	1,274
3/30/2019	1,277
3/31/2019	1,286
4/1/2019	1,281
4/2/2019	1,281

Date	Daily SO2 Emissions, 24-hr Average
4/3/2019	1,285
4/4/2019	1,160
4/5/2019	1,317
4/6/2019	1,279
4/7/2019	1,263
4/8/2019	1,323
4/9/2019	1,325
4/10/2019	1,276
4/11/2019	1,252
4/12/2019	1,306
4/13/2019	1,260
4/14/2019	1,276
4/15/2019	1,249
4/16/2019	1,319
4/17/2019	1,255
4/18/2019	1,220
4/19/2019	1,239
4/20/2019	1,219
4/21/2019	1,223
4/22/2019	1,240
4/23/2019	1,259
4/24/2019	1,263
4/25/2019	1,291
4/26/2019	1,296
4/27/2019	1,336
4/28/2019	1,313
4/29/2019	1,326
4/30/2019	1,274
5/1/2019	1,214
5/2/2019	1,284
5/3/2019	1,246
5/4/2019	1,287
5/5/2019	1,301
5/6/2019	1,294
5/7/2019	1,321
5/8/2019	1,286
5/9/2019	1,238
5/10/2019	1,310
5/11/2019	1,285
5/12/2019	1,250

Date	Daily SO2 Emissions, 24-hr Average
5/13/2019	1,214
5/14/2019	1,269
5/15/2019	1,282
5/16/2019	1,288
5/17/2019	1,277
5/18/2019	1,331
5/19/2019	1,279
5/20/2019	1,330
5/21/2019	1,296
5/22/2019	1,273
5/23/2019	1,188
5/24/2019	1,341
5/25/2019	1,343
5/26/2019	1,341
5/27/2019	1,517
5/28/2019	1,295
5/29/2019	1,232
5/30/2019	1,391
5/31/2019	1,227
6/1/2019	1,192
6/2/2019	1,222
6/3/2019	1,222
6/4/2019	1,213
6/5/2019	1,187
6/6/2019	1,195
6/7/2019	1,256
6/8/2019	1,275
6/9/2019	1,181
6/10/2019	1,220
6/11/2019	1,272
6/12/2019	1,240
6/13/2019	1,312
6/14/2019	1,333
6/15/2019	1,340
6/16/2019	1,352
6/17/2019	1,300
6/18/2019	1,188
6/19/2019	1,244
6/20/2019	1,202
6/21/2019	1,227

Date	Daily SO2 Emissions, 24-hr Average
6/22/2019	1,176
6/23/2019	1,271
6/24/2019	1,191
6/25/2019	881
6/26/2019	767
6/27/2019	725
6/28/2019	705
6/29/2019	698
6/30/2019	879
7/1/2019	1,200
7/2/2019	1,093
7/3/2019	1,267
7/4/2019	1,271
7/5/2019	1,247
7/6/2019	1,079
7/7/2019	1,205
7/8/2019	1,058
7/9/2019	899
7/10/2019	908
7/11/2019	1,277
7/12/2019	1,236
7/13/2019	1,043
7/14/2019	1,311
7/15/2019	1,343
7/16/2019	1,308
7/17/2019	1,275
7/18/2019	1,309
7/19/2019	1,285
7/20/2019	1,172
7/21/2019	1,238
7/22/2019	1,228
7/23/2019	1,236
7/24/2019	1,282
7/25/2019	1,348
7/26/2019	1,332
7/27/2019	1,290
7/28/2019	1,275
7/29/2019	1,172
7/30/2019	1,304
7/31/2019	1,331

Date	Daily SO2 Emissions, 24-hr Average
8/1/2019	1,233
8/2/2019	1,284
8/3/2019	1,233
8/4/2019	1,299
8/5/2019	1,284
8/6/2019	1,253
8/7/2019	1,320
8/8/2019	1,259
8/9/2019	1,323
8/10/2019	1,308
8/11/2019	1,200
8/12/2019	1,323
8/13/2019	1,298
8/14/2019	1,360
8/15/2019	1,325
8/16/2019	1,290
8/17/2019	1,311
8/18/2019	1,295
8/19/2019	1,313
8/20/2019	1,301
8/21/2019	1,260
8/22/2019	1,317
8/23/2019	1,327
8/24/2019	1,228
8/25/2019	1,308
8/26/2019	1,241
8/27/2019	1,365
8/28/2019	1,306
8/29/2019	1,321
8/30/2019	1,313
8/31/2019	1,287
9/1/2019	1,267
9/2/2019	1,219
9/3/2019	1,309
9/4/2019	1,290
9/5/2019	1,268
9/6/2019	1,279
9/7/2019	1,210
9/8/2019	1,231
9/9/2019	1,316

Date	Daily SO2 Emissions, 24-hr Average
9/10/2019	1,264
9/11/2019	1,227
9/12/2019	1,310
9/13/2019	1,337
9/14/2019	1,279
9/15/2019	1,278
9/16/2019	1,337
9/17/2019	1,304
9/18/2019	1,266
9/19/2019	1,353
9/20/2019	1,322
9/21/2019	1,265
9/22/2019	1,318
9/23/2019	1,314
9/24/2019	1,275
9/25/2019	1,331
9/26/2019	1,263
9/27/2019	1,194
9/28/2019	1,313
9/29/2019	1,261
9/30/2019	1,234
10/1/2019	1,319
10/2/2019	1,322
10/3/2019	1,317
10/4/2019	1,308
10/5/2019	1,340
10/6/2019	1,311
10/7/2019	1,296
10/8/2019	1,296
10/9/2019	1,327
10/10/2019	1,292
10/11/2019	1,273
10/12/2019	1,250
10/13/2019	1,302
10/14/2019	1,268
10/15/2019	1,254
10/16/2019	1,298
10/17/2019	1,370
10/18/2019	1,361
10/19/2019	1,261

Date	Daily SO2 Emissions, 24-hr Average
10/20/2019	1,293
10/21/2019	1,365
10/22/2019	1,345
10/23/2019	1,311
10/24/2019	1,312
10/25/2019	1,307
10/26/2019	1,282
10/27/2019	1,274
10/28/2019	1,237
10/29/2019	1,272
10/30/2019	1,320
10/31/2019	1,337
11/1/2019	1,343
11/2/2019	1,322
11/3/2019	1,283
11/4/2019	1,320
11/5/2019	1,239
11/6/2019	1,296
11/7/2019	1,292
11/8/2019	1,281
11/9/2019	1,239
11/10/2019	1,167
11/11/2019	1,279
11/12/2019	1,332
11/13/2019	1,319
11/14/2019	1,305
11/15/2019	1,302
11/16/2019	1,358
11/17/2019	1,288
11/18/2019	1,276
11/19/2019	1,349
11/20/2019	1,345
11/21/2019	1,350
11/22/2019	1,357
11/23/2019	1,292
11/24/2019	1,326
11/25/2019	1,257
11/26/2019	1,226
11/27/2019	1,307
11/28/2019	1,208

Date	Daily SO2 Emissions, 24-hr Average
11/29/2019	1,303
11/30/2019	1,330
12/1/2019	1,377
12/2/2019	1,313
12/3/2019	1,321
12/4/2019	1,364
12/5/2019	1,314
12/6/2019	1,414
12/7/2019	1,284
12/8/2019	1,330
12/9/2019	1,295
12/10/2019	1,373
12/11/2019	1,343
12/12/2019	1,356
12/13/2019	1,345
12/14/2019	1,391
12/15/2019	1,347
12/16/2019	1,372
12/17/2019	1,336
12/18/2019	1,384
12/19/2019	1,320
12/20/2019	1,381
12/21/2019	1,308
12/22/2019	1,337
12/23/2019	1,304
12/24/2019	1,335
12/25/2019	1,349
12/26/2019	1,327
12/27/2019	1,318
12/28/2019	1,337
12/29/2019	1,348
12/30/2019	1,288
12/31/2019	1,401
1/1/2020	1,387
1/2/2020	1,435
1/3/2020	1,410
1/4/2020	1,432
1/5/2020	1,462
1/6/2020	1,478
1/7/2020	1,377

Date	Daily SO2 Emissions, 24-hr Average
1/8/2020	1,311
1/9/2020	1,333
1/10/2020	1,336
1/11/2020	1,300
1/12/2020	1,339
1/13/2020	1,337
1/14/2020	1,377
1/15/2020	1,328
1/16/2020	1,336
1/17/2020	1,359
1/18/2020	1,361
1/19/2020	1,357
1/20/2020	1,328
1/21/2020	1,379
1/22/2020	1,380
1/23/2020	1,342
1/24/2020	1,303
1/25/2020	1,296
1/26/2020	1,328
1/27/2020	1,316
1/28/2020	1,330
1/29/2020	1,352
1/30/2020	1,311
1/31/2020	1,313
2/1/2020	1,344
2/2/2020	1,329
2/3/2020	1,358
2/4/2020	1,374
2/5/2020	1,343
2/6/2020	1,334
2/7/2020	1,299
2/8/2020	1,343
2/9/2020	1,334
2/10/2020	1,362
2/11/2020	1,364
2/12/2020	1,342
2/13/2020	1,283
2/14/2020	1,347
2/15/2020	1,335
2/16/2020	1,348

Date	Daily SO2 Emissions, 24-hr Average
2/17/2020	1,277
2/18/2020	1,353
2/19/2020	1,351
2/20/2020	1,359
2/21/2020	1,371
2/22/2020	1,361
2/23/2020	1,363
2/24/2020	1,370
2/25/2020	1,364
2/26/2020	1,373
2/27/2020	1,372
2/28/2020	1,338
2/29/2020	1,364
3/1/2020	1,343
3/2/2020	1,379
3/3/2020	1,369
3/4/2020	1,383
3/5/2020	1,387
3/6/2020	1,404
3/7/2020	1,386
3/8/2020	1,384
3/9/2020	1,384
3/10/2020	1,383
3/11/2020	1,380
3/12/2020	1,382
3/13/2020	1,378
3/14/2020	1,387
3/15/2020	1,395
3/16/2020	1,380
3/17/2020	1,388
3/18/2020	1,399
3/19/2020	1,383
3/20/2020	1,381
3/21/2020	1,381
3/22/2020	1,394
3/23/2020	1,387
3/24/2020	1,372
3/25/2020	1,384
3/26/2020	1,388
3/27/2020	1,387

Date	Daily SO2 Emissions, 24-hr Average
3/28/2020	1,386
3/29/2020	1,365
3/30/2020	1,374
3/31/2020	1,378
4/1/2020	1,389
4/2/2020	1,389
4/3/2020	1,381
4/4/2020	1,383
4/5/2020	1,388
4/6/2020	1,371
4/7/2020	1,399
4/8/2020	1,374
4/9/2020	1,390
4/10/2020	1,384
4/11/2020	1,383
4/12/2020	1,383
4/13/2020	1,397
4/14/2020	1,385
4/15/2020	1,378
4/16/2020	1,376
4/17/2020	1,368
4/18/2020	1,378
4/19/2020	1,375
4/20/2020	1,380
4/21/2020	1,394
4/22/2020	1,402
4/23/2020	1,378
4/24/2020	1,380
4/25/2020	1,382
4/26/2020	1,395
4/27/2020	1,386
4/28/2020	1,382
4/29/2020	1,392
4/30/2020	1,370
5/1/2020	1,374
5/2/2020	1,381
5/3/2020	1,376
5/4/2020	1,375
5/5/2020	1,389
5/6/2020	1,386

Date	Daily SO2 Emissions, 24-hr Average
5/7/2020	1,376
5/8/2020	1,393
5/9/2020	1,357
5/10/2020	1,386
5/11/2020	1,354
5/12/2020	1,386
5/13/2020	1,264
5/14/2020	1,389
5/15/2020	1,322
5/16/2020	1,304
5/17/2020	1,388
5/18/2020	1,383
5/19/2020	1,395
5/20/2020	1,388
5/21/2020	1,359
5/22/2020	1,372
5/23/2020	1,347
5/24/2020	1,381
5/25/2020	1,367
5/26/2020	1,384
5/27/2020	1,384
5/28/2020	1,364
5/29/2020	1,374
5/30/2020	1,365
5/31/2020	1,381
6/1/2020	1,375
6/2/2020	1,376
6/3/2020	1,362
6/4/2020	1,376
6/5/2020	1,376
6/6/2020	1,390
6/7/2020	1,384
6/8/2020	1,388
6/9/2020	1,381
6/10/2020	1,383
6/11/2020	1,383
6/12/2020	1,377
6/13/2020	1,240
6/14/2020	1,386
6/15/2020	1,321

Date	Daily SO2 Emissions, 24-hr Average
6/16/2020	1,381
6/17/2020	1,392
6/18/2020	1,390
6/19/2020	1,393
6/20/2020	1,374
6/21/2020	1,377
6/22/2020	1,395
6/23/2020	1,386
6/24/2020	1,391
6/25/2020	1,387
6/26/2020	1,374
6/27/2020	1,387
6/28/2020	1,382
6/29/2020	1,367
6/30/2020	1,323
7/1/2020	1,387
7/2/2020	1,376
7/3/2020	1,370
7/4/2020	1,380
7/5/2020	1,381
7/6/2020	1,382
7/7/2020	1,408
7/8/2020	1,398
7/9/2020	1,379
7/10/2020	1,376
7/11/2020	1,375
7/12/2020	1,380
7/13/2020	1,384
7/14/2020	1,381
7/15/2020	1,381
7/16/2020	1,387
7/17/2020	1,386
7/18/2020	1,386
7/19/2020	1,381
7/20/2020	1,392
7/21/2020	1,379
7/22/2020	1,379
7/23/2020	1,393
7/24/2020	1,384
7/25/2020	1,380

Date	Daily SO2 Emissions, 24-hr Average
7/26/2020	1,377
7/27/2020	1,376
7/28/2020	1,357
7/29/2020	1,384
7/30/2020	1,376
7/31/2020	1,388
8/1/2020	1,379
8/2/2020	1,388
8/3/2020	1,374
8/4/2020	1,379
8/5/2020	1,379
8/6/2020	1,379
8/7/2020	1,365
8/8/2020	1,385
8/9/2020	1,386
8/10/2020	1,377
8/11/2020	1,380
8/12/2020	1,390
8/13/2020	1,377
8/14/2020	1,389
8/15/2020	1,367
8/16/2020	1,367
8/17/2020	1,364
8/18/2020	1,376
8/19/2020	1,393
8/20/2020	1,388
8/21/2020	1,373
8/22/2020	1,383
8/23/2020	1,389
8/24/2020	1,385
8/25/2020	1,422
8/26/2020	1,373
8/27/2020	1,396
8/28/2020	1,401
8/29/2020	1,381
8/30/2020	1,390
8/31/2020	1,378
9/1/2020	1,375
9/2/2020	1,380
9/3/2020	1,377

Date	Daily SO2 Emissions, 24-hr Average
9/4/2020	1,386
9/5/2020	1,390
9/6/2020	1,394
9/7/2020	1,374
9/8/2020	1,368
9/9/2020	1,384
9/10/2020	1,387
9/11/2020	1,384
9/12/2020	1,381
9/13/2020	1,383
9/14/2020	1,383
9/15/2020	1,382
9/16/2020	1,376
9/17/2020	1,389
9/18/2020	1,380
9/19/2020	1,379
9/20/2020	1,387
9/21/2020	1,378
9/22/2020	1,394
9/23/2020	1,391
9/24/2020	1,362
9/25/2020	1,375
9/26/2020	1,382
9/27/2020	1,384
9/28/2020	1,385
9/29/2020	1,343
9/30/2020	1,374
10/1/2020	1,265
10/2/2020	1,381
10/3/2020	1,386
10/4/2020	1,384
10/5/2020	1,385
10/6/2020	1,381
10/7/2020	1,372
10/8/2020	1,390
10/9/2020	1,388
10/10/2020	1,392
10/11/2020	1,388
10/12/2020	1,373
10/13/2020	1,380

Date	Daily SO2 Emissions, 24-hr Average
10/14/2020	1,391
10/15/2020	1,384
10/16/2020	1,381
10/17/2020	1,384
10/18/2020	1,441
10/19/2020	1,402
10/20/2020	1,380
10/21/2020	1,392
10/22/2020	1,391
10/23/2020	1,387
10/24/2020	1,384
10/25/2020	1,378
10/26/2020	1,393
10/27/2020	1,384
10/28/2020	1,383
10/29/2020	1,379
10/30/2020	1,389
10/31/2020	1,385
11/1/2020	1,380
11/2/2020	1,386
11/3/2020	1,387
11/4/2020	1,375
11/5/2020	1,378
11/6/2020	1,371
11/7/2020	1,383
11/8/2020	1,381
11/9/2020	1,381
11/10/2020	1,316
11/11/2020	862
11/12/2020	401
11/13/2020	1,215
11/14/2020	1,385
11/15/2020	1,386
11/16/2020	1,383
11/17/2020	1,368
11/18/2020	1,380
11/19/2020	1,378
11/20/2020	1,380
11/21/2020	1,392
11/22/2020	1,388

Date	Daily SO2 Emissions, 24-hr Average
11/23/2020	1,382
11/24/2020	1,373
11/25/2020	1,374
11/26/2020	1,388
11/27/2020	1,386
11/28/2020	1,383
11/29/2020	1,381
11/30/2020	1,374
12/1/2020	1,395
12/2/2020	1,384
12/3/2020	1,381
12/4/2020	1,385
12/5/2020	1,385
12/6/2020	1,383
12/7/2020	1,374
12/8/2020	1,388
12/9/2020	1,385
12/10/2020	1,377
12/11/2020	1,390
12/12/2020	1,380
12/13/2020	1,388
12/14/2020	1,380
12/15/2020	1,383
12/16/2020	1,282
12/17/2020	1,388
12/18/2020	1,386
12/19/2020	1,387
12/20/2020	1,387
12/21/2020	1,386
12/22/2020	1,380
12/23/2020	1,378
12/24/2020	1,386
12/25/2020	1,391
12/26/2020	1,383
12/27/2020	1,383
12/28/2020	1,384
12/29/2020	1,388
12/30/2020	1,388
12/31/2020	1,384
1/1/2021	1,385

Date	Daily SO2 Emissions, 24-hr Average
1/2/2021	1,386
1/3/2021	1,385
1/4/2021	1,386
1/5/2021	1,386
1/6/2021	1,382
1/7/2021	1,382
1/8/2021	1,376
1/9/2021	1,377
1/10/2021	1,386
1/11/2021	1,389
1/12/2021	1,382
1/13/2021	1,388
1/14/2021	1,366
1/15/2021	1,389
1/16/2021	1,382
1/17/2021	1,398
1/18/2021	1,374
1/19/2021	1,353
1/20/2021	1,382
1/21/2021	1,384
1/22/2021	1,375
1/23/2021	1,388
1/24/2021	1,382
1/25/2021	1,382
1/26/2021	1,393
1/27/2021	1,395
1/28/2021	1,387
1/29/2021	1,375
1/30/2021	1,380
1/31/2021	1,383
2/1/2021	1,385
2/2/2021	1,379
2/3/2021	1,377
2/4/2021	1,385
2/5/2021	1,372
2/6/2021	1,381
2/7/2021	1,384
2/8/2021	1,384
2/9/2021	1,388
2/10/2021	1,383

Date	Daily SO2 Emissions, 24-hr Average
2/11/2021	1,385
2/12/2021	1,380
2/13/2021	1,381
2/14/2021	1,389
2/15/2021	1,399
2/16/2021	1,435
2/17/2021	1,393
2/18/2021	1,384
2/19/2021	1,388
2/20/2021	1,384
2/21/2021	1,373
2/22/2021	1,387
2/23/2021	1,392
2/24/2021	1,385
2/25/2021	1,385
2/26/2021	1,389
2/27/2021	1,378
2/28/2021	1,385
3/1/2021	1,377
3/2/2021	1,382
3/3/2021	1,363
3/4/2021	1,387
3/5/2021	1,378
3/6/2021	1,383
3/7/2021	1,389
3/8/2021	1,269
3/9/2021	1,364
3/10/2021	1,387
3/11/2021	1,372
3/12/2021	1,387
3/13/2021	1,384
3/14/2021	1,390
3/15/2021	1,394
3/16/2021	1,386
3/17/2021	1,388
3/18/2021	1,381
3/19/2021	1,383
3/20/2021	1,378
3/21/2021	1,379
3/22/2021	1,372

Date	Daily SO2 Emissions, 24-hr Average
3/23/2021	1,379
3/24/2021	1,380
3/25/2021	1,386
3/26/2021	1,388
3/27/2021	1,400
3/28/2021	1,386
3/29/2021	1,382
3/30/2021	1,377
3/31/2021	1,394
4/1/2021	1,379
4/2/2021	1,389
4/3/2021	1,386
4/4/2021	1,371
4/5/2021	1,389
4/6/2021	1,399
4/7/2021	1,387
4/8/2021	1,389
4/9/2021	1,383
4/10/2021	1,386
4/11/2021	1,379
4/12/2021	1,389
4/13/2021	1,381
4/14/2021	1,384
4/15/2021	1,381
4/16/2021	1,379
4/17/2021	1,382
4/18/2021	1,396
4/19/2021	1,360
4/20/2021	1,386
4/21/2021	1,391
4/22/2021	1,387
4/23/2021	1,383
4/24/2021	1,384
4/25/2021	1,395
4/26/2021	1,382
4/27/2021	1,390
4/28/2021	1,385
4/29/2021	1,383
4/30/2021	1,389
5/1/2021	1,393

Date	Daily SO2 Emissions, 24-hr Average
5/2/2021	1,387
5/3/2021	1,391
5/4/2021	1,385
5/5/2021	1,363
5/6/2021	1,393
5/7/2021	1,393
5/8/2021	1,388
5/9/2021	1,377
5/10/2021	1,381
5/11/2021	1,373
5/12/2021	1,372
5/13/2021	1,387
5/14/2021	1,360
5/15/2021	1,356
5/16/2021	1,388
5/17/2021	1,380
5/18/2021	1,358
5/19/2021	1,373
5/20/2021	1,381
5/21/2021	1,386
5/22/2021	1,322
5/23/2021	1,382
5/24/2021	1,378
5/25/2021	1,389
5/26/2021	1,396
5/27/2021	1,378
5/28/2021	1,382
5/29/2021	1,329
5/30/2021	1,318
5/31/2021	1,357
6/1/2021	1,196
6/2/2021	1,377
6/3/2021	1,381
6/4/2021	1,381
6/5/2021	1,381
6/6/2021	1,381
6/7/2021	1,385
6/8/2021	1,340
6/9/2021	1,277
6/10/2021	1,380

Date	Daily SO2 Emissions, 24-hr Average
6/11/2021	1,385
6/12/2021	1,393
6/13/2021	1,387
6/14/2021	1,382
6/15/2021	1,386
6/16/2021	1,386
6/17/2021	1,388
6/18/2021	1,387
6/19/2021	1,377
6/20/2021	1,380
6/21/2021	1,425
6/22/2021	1,392
6/23/2021	1,376
6/24/2021	1,389
6/25/2021	1,394
6/26/2021	1,378
6/27/2021	1,364
6/28/2021	1,314
6/29/2021	1,354
6/30/2021	1,341
7/1/2021	1,164
7/2/2021	1,383
7/3/2021	1,371
7/4/2021	1,370
7/5/2021	1,360
7/6/2021	1,379
7/7/2021	1,374
7/8/2021	1,345
7/9/2021	1,343
7/10/2021	1,377
7/11/2021	1,382
7/12/2021	1,397
7/13/2021	1,394
7/14/2021	1,366
7/15/2021	1,380
7/16/2021	1,387
7/17/2021	1,389
7/18/2021	1,388
7/19/2021	1,365
7/20/2021	1,360

Date	Daily SO2 Emissions, 24-hr Average
7/21/2021	1,375
7/22/2021	1,363
7/23/2021	1,343
7/24/2021	1,335
7/25/2021	1,355
7/26/2021	1,398
7/27/2021	1,386
7/28/2021	1,342
7/29/2021	1,364
7/30/2021	1,371
7/31/2021	1,376

View/Print Label

1. Ensure there are no other shipping or tracking labels attached to your package. Select the Print button on the print dialogue box that appears. Note: If your browser does not support this function, select Print from the File menu to print the label.

2. Fold the printed label at the solid line below. Place the label in a UPS Shipping Pouch. If you do not have a pouch, affix the folded label using clear plastic shipping tape over the entire label.

3. GETTING YOUR SHIPMENT TO UPS

Customers with a scheduled Pickup

- Your driver will pickup your shipment(s) as usual.

Customers without a scheduled Pickup

- Schedule a Pickup on ups.com to have a UPS driver pickup all of your packages.
- Take your package to any location of The UPS Store®, UPS Access Point(TM) location, UPS Drop Box, UPS Customer Center, Staples® or Authorized Shipping Outlet near you. To find the location nearest you, please visit the 'Locations' Quick link at ups.com.

UPS Access Point™
CORNEJOS VIDEO

4609 INDIANAPOLIS BLVD
EAST CHICAGO IN 46312-3228





UPS Access Point™
ADVANCE AUTO PARTS STORE
#7708

1200 W CHICAGO AVE
EAST CHICAGO IN 46312-3315

UPS Access Point™
CVS STORE # 10943

1301 119TH ST
WHITING IN 46394-1602

FOLD HERE

<p>LUKE FORD 219-397-4626 COKENERGY 3210 WATLING STREET EAST CHICAGO IN 46312</p> <p>SHIP TO: PHIL PERRY IN. DEPT. OF ENVIRONMENTAL MANAGEMEME CHIEF AIR COMPLAINT AND ENFORCEMENT BRA MC-61-53, IGCN 1003 100 NORTH SENATE AVENUE INDIANAPOLIS IN 46204</p>	<p>1 LBS</p> <p>1 OF 1</p>	<p>IN 461 9-01</p>  	<p>UPS GROUND</p> <p>TRACKING #: 1Z F34 9F8 03 9400 6389</p> 	<p>BILLING: P/P</p>  <p>XCL 21-07-05 NV45 34-0A 08/2021*</p>
--	--	---	--	--