

Appendix P

Lone Star Industries, Inc. dba Buzzi Unicem USA - Greencastle Responses to the FLMs Comments

This page intentionally left blank

Boling, Jean

From: Press, Miriam <Miriam.Press@buzziunicemusa.com>
Sent: Thursday, September 02, 2021 5:15 PM
To: Boling, Jean; Menke, Timothy; Paul Schell; Ferguson, Michelle
Subject: RE: Federal Land Managers Comments Associated with the Buzzi Unicem Greencastle Plant
Attachments: Appendix D - Greencastle Cost Effectiveness Analysis 082021 UPDATE.xlsx; SNCR controlcostmanual_costcalculationspreadsheetvf_march_2021 BUUSA Greencastle.pdf; Attachment_5-5_dsi_cost_development_methodology Sargent & Lundy for.pdf

**** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ****

Jean,

The following is the additional information requested to follow-up on the FLM comments pertaining to our facility:

- First regarding the FLM's comment concerning the use of a 15 year life expectancy. This is consistent with, and actually more conservative than, the life expectancy that Buzzi Unicem USA typically uses when determining the capital recovery factor for emission control equipment. At yearend 2020, Buzzi Unicem USA would have used a 10 year life time for emission control equipment due to the typically harsh conditions in a cement plant and an interest rate of 5.75%. The capital recovery factor has been calculated using the company's 5.75% interest rate and using the 15 year life for emission control equipment. The Capital Recovery Factor has been updated to reflect this change in the attached Appendix D in the SNCR- UPDATED column. As an additional note to FLM's comment, the life expectancy is for the control equipment itself, not for the plant's operations. The control equipment would be expected to need to be replaced in 15 years, requiring additional capital investment.
- For the SNCR cost estimate, Buzzi Unicem USA believes the capital cost represented are valid within 30% estimate. However, as our previous comments expressed, we believe the cost for reagent are grossly under estimated based on our experience operating SNCR at five of our cement plants. To provide a better estimate, we have used the EPA SNCR Control Cost Manual cost calculation spreadsheet to estimate an annual reagent cost. The calculation spreadsheet is attached, with notes regarding the Buzzi Unicem USA's inputs. Based on the spreadsheet, the estimated annual reagent cost is \$589,391/yr for 19% ammonia. This estimate is consistent with the average annual ammonia per plant budgeted for 2021 cost based on our 5 plants operating SNCR. The cost was estimated using the average per gallon cost of the facilities currently operating SNCR. [Note, because of our internal IT restrictions, we are not able to e-mail a file with macros. Therefore, we are attaching a pdf printout of the information calculated using the spreadsheet.]
- Regarding DSI costs, Buzzi Unicem USA had previously stated uncertainty regarding performance of the ESP with the addition of DSI. Based on a recent search, it appears that DSI is compatible with an ESP in power generating facilities, however, the control efficiency is expected to be only 30% reduction using hydrated lime. See the attached IPM Model – Updates to Cost and Performance for APC Technologies, Dry Sorbent Injection for SO₂/HCl Control Cost Development Methodology, April 2017, Sargent & Lundy. Buzzi Unicem USA has not solicited engineering cost estimates for a DSI system. However, as with SNCR, we feel the reagent cost used in the prior estimate are very low, again based on our experience operating DSI systems at 5 cement plants. Buzzi Unicem USA used a ratio approach to estimate annual hydrated lime costs for the Greencastle plant based on the estimate provided in Table 5 of IPM document. From the IPM document, Table 5 which estimates cost for DSI with ESP, the model facility SO₂ emission are 9,500 lbs SO₂/hr, and the hourly hydrated lime feed rate is estimated to be 10.85 tons/hr. The Greencastle SO₂ emissions are approximately 80 lb SO₂/hr. Assuming a linear relationship, Greencastle would require a sorbent feed

rate of 0.09 tons/hr. Using the average 2021 budget cost for hydrated lime at our five cement plants of \$159.34 ton lime, and assuming the kiln operates 85% of the year (7446 hours/yr), the annual sorbent cost is estimated at \$108,404/yr. This is comparatively lower than the average annual budget for lime at the five plants currently operating DSI systems, however, considering the low emissions at the Greencastle plant it is likely much more reasonable than the \$11,804 used in the original estimate.


Please let us know if you have any questions or need additional information from us.

Sincerely,

Miriam Press
Environmental Engineer

Buzzi Unicem USA
Greencastle Plant
3301 S. County Road 150 W.
Greencastle, IN 46135

Phone: 765-653-8816 x3122
Mobile: 314-910-8427
e-mail: miriam.press@buzziunicemusa.com



From: Boling, Jean <JBoling@idem.IN.gov>
Sent: Thursday, July 29, 2021 10:41 AM
To: Menke, Timothy <Timothy.Menke@buzziunicemusa.com>; Press, Miriam <Miriam.Press@buzziunicemusa.com>; Schell, Paul <Paul.Schell@Buzziunicemusa.com>
Subject: Federal Land Managers Comments Associated with the Buzzi UnicemGreencastle Plant

This email originated from outside the Company. DO NOT CLICK ANY LINKS or OPEN ANY ATTACHMENTS unless you trust the sender. If you are not sure please contact the IT Helpdesk before proceeding.

Good morning all,

IDEM received the Federal Land Manager's (FLMs) comments on July 23, 2021, as expected, so we are now in the process of drafting Indiana's response to comments that will be incorporated into the draft RH SIP that will go out on public notice. As stated in the email I sent out on July 15, 2021, your timely response is needed to provide the additional information the FLMs have requested to address their comments related to the four-factor analysis conducted for the Greencastle cement plant.

The FLMs reviewed the four-factor analysis provided for the Greencastle cement plant and offered the following comments and request for additional information: "We disagree with the use of a 15-year expected lifetime for the facility, as there is no federally enforceable requirement for the facility to shut down in that time. We also disagree with the use of a 7% interest rate for the reasons discussed earlier. Nonetheless, the estimated cost for adding SNCR is clearly cost effective at \$873/ton of NO_x removed and should be required as part of the state's long-term strategy. The analysis

for dry sorbent injection only summarized the costs; we request that IDEM provide a detailed cost analysis so that we may complete our review.”

Since the RH program is an iterative program that provides states with the flexibility to develop a cohesive strategy that demonstrates reasonable progress over time toward natural visibility by 2064, Indiana offered a weight of evidence demonstration consistent with this overarching principle to support the state’s decision not to require additional control measures for the selected sources. The state continues to stand behind this decision, however, it is important to address the FLMs comments as thoroughly as possible to show that Indiana has seriously evaluated the selected sources in accordance with the RH Rule and section 169A(g)(1) of the CAA which lists four factors that must be taken into consideration in determining reasonable progress.

Please forward the information requests to me by close of business August 27, 2021 and if either one of you have any questions about the FLMs comments or would like to discuss any of them with us, we would be happy to make ourselves available. Thank you, in advance, for your cooperation and assistance.

Jean Boling

Senior Environmental Engineer
Indiana Department of Environmental Management
Office of Air Quality, Air Programs Branch
100 North Senate Avenue, MC 61-53 IGCN 1003
Indianapolis, IN 46204-2251
Phone: 317-232-8228
Fax: 317-233-5967
E-mail: jboling@idem.IN.gov

Help us improve!

IDEM values your feedback



Cement Kiln BART Controls Cost Effectiveness Analysis

Operating company
Facility
State

Lone Star Industry, Inc dba Buzzi Unicem
Greencastle Plant
IN

Proposed BART Control Option for Greencastle Long, Semi-Wet Process Kiln

Current Emissions (ton/yr)
Control Effectiveness
New Emission Rate (tons/yr)
Emission Reductions (tons/yr)
Capital Cost
O&M Cost
Total Annual Cost
Cost-Effectiveness (\$/ton)

NOx Controls (Original)	NOx Controls (Updated)	SO2 Controls (Original)	SO2 Controls (Updated)
SNCR	SNCR	DSI	DSI
1,713	1,713	104	104
40%	40%	45%	45%
1,028	1,028	57	57
685	685	47	47
\$ 1,724,229	\$ 1,724,230	\$ 908,461	\$ 908,462
\$ 408,822	\$ 975,807	\$ 282,403	\$ 379,001
\$ 598,142	\$ 1,150,449	\$ 382,152	\$ 471,017
\$ 873	\$ 1,679	\$ 8,142	\$ 10,035

Cement Kiln BART Controls Cost Estimate

Lone Star Industries Greencastle Plant

pre-heater/pre-calcliner semi-dry kiln

Cost Detail Description	SNCR	SNCR UPDATED	DSI	DSI UPDATED	Reference
Total Direct Capital Cost (DCC)	766,324	766,324	412,937	412,937	
Total Indirect Capital Cost (IOC)	957,905	957,905	495,524	495,524	
Total Capital Cost (TCC)	1,724,229	1,724,229	908,461	908,461	
Capital Recovery Factor	10.98%	10.13%	10.98%	10.13%	
Total Annualized Capital Cost (7%, 15 yrs)	189,320	174,643	99,749	92,016	
Direct Operating Costs (DOC)					
Operating and Maintenance Labor	90,000	90,000	90,000	90,000	EPA Cost Control Manual
Supervision @20 Hours of Operating Labor	18,000	18,000	18,000	18,000	EPA Cost Control Manual
Maintenance Materials 5% of DCC	38,316	38,316	20,647	20,647	
Reagent	22,406	589,391	11,805.00	108,403.00	
Energy Penalty	3,700	3,700	1,950.00	1,950.00	
Electricity	42,126	42,126	22,195.00	22,195.00	
Gas Reheat and Heat Recovery	82,942	82,942	43,700.00	43,700.00	
Total Direct Operating Costs	279,490	846,475	190,297	286,895	
Indirect Operating Costs (IOC)					
Payroll Overhead (30% Oper/Labor/Sup)	27,000	27,000	27,000	27,000	
Plant Overhead (26% Total Labor/Material)	33,362	33,362	28,768	28,768	
Property Tax (1%TCC)	17,242	17,242	9,085	9,085	
Insurance (1%TCC)	17,242	17,242	9,085	9,085	
Administration (2% ICC)	34,485	34,485	18,169	18,169	
Total Indirect Operating Costs	129,331	129,331	92,107	92,107	
Total Annual Operating Costs	408,822	975,807	282,403	379,001	
Total Annual Cost (Capital and Operating)	598,142	1,150,449	382,152	471,017	

conversion factor gal/cu ft

lb/cu ft for 29% ammonia

7.4805

56

Air Pollution Control Cost Estimation Spreadsheet For Selective Non-Catalytic Reduction (SNCR)

U.S. Environmental Protection Agency
Air Economics Group
Health and Environmental Impacts Division
Office of Air Quality Planning and Standards
(March 2021)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Non-Catalytic Reduction (SNCR) control device. SNCR is a post-combustion control technology for reducing NO_x emissions by injecting an ammonia-base reagent (urea or ammonia) into the furnace at a location where the temperature is in the appropriate range for ammonia radicals to react with NO_x to form nitrogen and water.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SNCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SNCR control technology and the cost methodologies, see Section 4, Chapter 1 of the Air Pollution Control Cost Manual (as updated April 2019). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-reports-and-guidance-air-pollution>.

The spreadsheet can be used to estimate capital and annualized costs for applying SNCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM version 6). The size and costs of the SNCR are based primarily on four parameters: the boiler size or heat input, the type of fuel burned, the required level of NO_x reduction, and the reagent consumption. This approach provides study-level estimates (±30%) of SNCR capital and annual costs. Default data in the spreadsheet is taken from the SNCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions, such as the boiler configuration and fuel type. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at <http://www.epa.gov/airmarkets/power-sector-modeling>. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the *Data Inputs* tab and click on the *Reset Form* button. This will reset the NSR, plant elevation, estimated equipment life, desired dollar year, cost index (to match desired dollar year), annual interest rate, unit costs for fuel, electricity, reagent, water and ash disposal, and the cost factors for maintenance cost and administrative charges. All other data entry fields will be blank.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SNCR is for new construction or retrofit of an existing boiler. If the SNCR will be installed on an existing boiler, enter a retrofit factor equal to or greater than 0.84. Use 1 for retrofits with an average level of difficulty. For more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you selected coal, select the type of coal burned from the drop down menu. The NO_x emissions rate, weight percent coal ash and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided.

Step 4: Complete all of the cells highlighted in yellow. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2016 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.015 and 0.03, respectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the *SNCR Design Parameters* tab to see the calculated design parameters and the *Cost Estimate* tab to view the calculated cost data for the installation and operation of the SNCR.

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

Utility

Is the SNCR for a new boiler or retrofit of an existing boiler?

Retrofit

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

1

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

MW

What is the higher heating value (HHV) of the fuel?

Btu/lb

What is the estimated actual annual MWh output?

MWh

Is the boiler a fluid-bed boiler?

No

Enter the net plant heat input rate (NPHR)

MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

What type of fuel does the unit burn?

Coal

Provide the following information for coal-fired boilers:

Type of coal burned:

Coal blend

Enter the sulfur content (%S) =

1.13 percent by weight

or

Select the appropriate SO₂ emission rate:

Not Applicable

*The sulfur content of 1.125% is a default value. See below for data source. Enter actual value, if known.

Ash content (%Ash):

7.535 percent by weight

*The ash content of 7.535% is a default value. See below for data source. Enter actual value, if known.

For units burning coal blends:

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Blend Composition Table

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0.5	1.84	9.23	12,000	2.4
Sub-bituminous	0.5	0.41	5.84	9,000	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

Enter the following design parameters for the proposed SNCR:

If you used your own site-specific values, please enter the value used and the reference source . . .

Reagent Cost	\$1.66/gallon of 50% urea solution	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model, Updates to the Cost and Performance for APC Technologies, SNCR Cost Development Methodology; Chapter 5, Attachment 5-4, January 2017. Available at: https://www.epa.gov/sites/production/files/2018-05/documents/attachment_5-4_snrcr_cost_development_methodology.pdf .	Used \$0.57/gallon for 19% ammonia based on average BUUSA 2021 budgeted cost per ton/ammonia at 5 plants currently using SNCR. Converted to cost per gallon from cost per ton.
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf).	
Electricity Cost (\$/kWh)	0.0361	U.S. Energy Information Administration. Electric Power Annual 2016. Table 8.4. Published December 2017. Available at: https://www.eia.gov/electricity/annual/pdf/epa.pdf .	
Fuel Cost (\$/MMBtu)	2.15	Weighted average cost based on average 2014 fuel cost data for power plants compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, "Power Plant Operations Report." Available at http://www.eia.gov/electricity/data/eia923/ .	
Ash Disposal Cost (\$/ton)	48.8	Waste Business Journal. The Cost to Landfill MSW Continues to Rise Despite Soft Demand. July 11, 2017. Available at: http://www.wastebusinessjournal.com/news/wbj20170711A.htm .	
Percent sulfur content for Coal (% weight)	1.13	Weighted average sulfur content based on U.S. coal data for 2016 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	
Percent ash content for Coal (% weight)	7.54	Weighted average ash content based on U.S. coal data for 2016 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/ .	
Higher Heating Value (HHV) (Btu/lb)	10,334	Weighted average HHV based on 2014 HHV coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, "Power Plant Operations Report." Available at http://www.eia.gov/electricity/data/eia923/ .	

SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q_h) =	$Bmw \times NPHR =$	160	MMBtu/hour
Maximum Annual MWh Output =	$Bmw \times 8760 =$	0	MWh
Estimated Actual Annual MWh Output (Boutput) =		0	MWh
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.00	
Total System Capacity Factor (CF_{total}) =	$(Boutput/Bmw) \times (tsncr/tpplant) =$	0.900	fraction
Total operating time for the SNCR (t_{op}) =	$CF_{total} \times 8760 =$	7884	hours
NOx Removal Efficiency (EF) =	$(NOx_{in} - NOx_{out})/NOx_{in} =$	40	percent
NOx removed per hour =	$NOx_{in} \times EF \times Q_h =$	192.00	lb/hour
Total NO _x removed per year =	$(NOx_{in} \times EF \times Q_h \times t_{op})/2000 =$	756.86	tons/year
Coal Factor ($Coal_F$) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.03	
SO ₂ Emission rate =	$(\%S/100) \times (64/32) \times (1 \times 10^5)/HHV =$	#DIV/0!	lbs/MMBtu
Elevation Factor (ELEV _F) =	$14.7 \text{ psia}/P =$	1.03	
Atmospheric pressure at 843 feet above sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7)/518.6]^{5.256} \times (1/144) =$	14.3	psia
Retrofit Factor (RF) =	Retrofit to existing boiler	1.00	

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html>.

Reagent Data:

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole
Density = 56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ($m_{reagent}$) =	$(NOx_{in} \times Q_h \times NSR \times MW_R)/(MW_{NOx} \times SR) =$ (where SR = 1 for NH ₃ ; 2 for Urea)	187	lb/hour
Reagent Usage Rate (m_{sol}) =	$m_{reagent}/C_{sol} =$ ($m_{sol} \times 7.4805$)/Reagent Density =	982	lb/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24 \text{ hours/day})/\text{Reagent Density} =$	131.2	gal/hour
	Density =	44,100	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1 =$ Where n = Equipment Life and i= Interest Rate	0.0854

Parameter	Equation	Calculated Value	Units
Electricity Usage: Electricity Consumption (P) =	$(0.47 \times \text{NOx}_{\text{in}} \times \text{NSR} \times \text{O}_2) / \text{NPHR} =$	#DIV/0!	kw/hour
Water Usage: Water consumption (q_w) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	0	gallons/hour
Fuel Data: Additional Fuel required to evaporate water in injected reagent (ΔFuel) =	$\text{Hv} \times m_{\text{reagent}} \times ((1 / C_{\text{inj}}) - 1) =$	0.72	MMBtu/hour
Ash Disposal: Additional ash produced due to increased fuel consumption (Δash) =	$(\Delta \text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	#DIV/0!	lb/hour

Cost Estimate

Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ($SNCR_{cost}$) =		\$0 in 2016 dollars
Air Pre-Heater Costs (APH_{cost})* =	#DIV/0!	in 2016 dollars
Balance of Plant Costs (BOP_{cost}) =		\$0 in 2016 dollars
Total Capital Investment (TCI) =	#DIV/0!	in 2016 dollars

#DIV/0!

SNCR Capital Costs ($SNCR_{cost}$)

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times ELEVF \times RF$$

SNCR Capital Costs ($SNCR_{cost}$) =	\$0 in 2016 dollars
----------------------------------------	---------------------

Air Pre-Heater Costs (APH_{cost})*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

Air Pre-Heater Costs (APH_{cost}) =	#DIV/0!	in 2016 dollars
-----------------------------------------	---------	-----------------

#DIV/0!

Balance of Plant Costs (BOP_{cost})

For Coal-Fired Utility Boilers:

$$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x \text{ Removed/hr})^{0.12} \times BTF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (NO_x \text{ Removed/hr})^{0.12} \times RF$$

For Coal-Fired Industrial Boilers:

$$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x \text{ Removed/hr})^{0.12} \times BTF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (NO_x \text{ Removed/hr})^{0.12} \times RF$$

Balance of Plant Costs (BOP_{cost}) =	\$0 in 2016 dollars
-------------------------------------------	---------------------

Annual Costs

Total Annual Cost (TAC)

$$TAC = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

Direct Annual Costs (DAC) =	#DIV/0!	in 2016 dollars
Indirect Annual Costs (IDAC) =	#DIV/0!	in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	#DIV/0!	in 2016 dollars

Direct Annual Costs (DAC)

$$DAC = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Water Cost}) + (\text{Annual Fuel Cost}) + (\text{Annual Ash Cost})$$

Annual Maintenance Cost =	$0.015 \times TCI =$	#DIV/0!	in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times \text{Cost}_{reag} \times t_{op} =$	\$589,391	in 2016 dollars
Annual Electricity Cost =	$P \times \text{Cost}_{elect} \times t_{op} =$	#DIV/0!	in 2016 dollars
Annual Water Cost =	$q_{water} \times \text{Cost}_{water} \times t_{op} =$	\$0	in 2016 dollars
Additional Fuel Cost =	$\Delta \text{Fuel} \times \text{Cost}_{fuel} \times t_{op} =$	\$0	in 2016 dollars
Additional Ash Cost =	$\Delta \text{Ash} \times \text{Cost}_{ash} \times t_{op} \times (1/2000) =$	#DIV/0!	in 2016 dollars
Direct Annual Cost =		#DIV/0!	in 2016 dollars

Indirect Annual Cost (IDAC)

$$IDAC = \text{Administrative Charges} + \text{Capital Recovery Costs}$$

Administrative Charges (AC) =	$0.03 \times \text{Annual Maintenance Cost} =$	#DIV/0!	in 2016 dollars
Capital Recovery Costs (CR) =	$CRF \times TCI =$	#DIV/0!	in 2016 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	#DIV/0!	in 2016 dollars

Cost Effectiveness

$$\text{Cost Effectiveness} = \text{Total Annual Cost} / \text{NOx Removed/year}$$

Total Annual Cost (TAC) =	#DIV/0!	per year in 2016 dollars
NOx Removed =		757 tons/year
Cost Effectiveness =	#DIV/0!	per ton of NOx removed in 2016 dollars

IPM Model – Updates to Cost and Performance for APC Technologies

Dry Sorbent Injection for SO₂/HCl Control Cost Development Methodology

Final

April 2017

Project 13527-001

Eastern Research Group, Inc.

Prepared by

Sargent & Lundy ^{L L C}

55 East Monroe Street • Chicago, IL 60603 USA • 312-269-2000

LEGAL NOTICE

This analysis ("Deliverable") was prepared by Sargent & Lundy, L.L.C. ("S&L"), expressly for the sole use of Eastern Research Group, Inc. ("Client") in accordance with the agreement between S&L and Client. This Deliverable was prepared using the degree of skill and care ordinarily exercised by engineers practicing under similar circumstances. Client acknowledges: (1) S&L prepared this Deliverable subject to the particular scope limitations, budgetary and time constraints, and business objectives of the Client; (2) information and data provided by others may not have been independently verified by S&L; and (3) the information and data contained in this Deliverable are time sensitive and changes in the data, applicable codes, standards, and acceptable engineering practices may invalidate the findings of this Deliverable. Any use or reliance upon this Deliverable by third parties shall be at their sole risk.

This work was funded by the U.S. Environmental Protection Agency (EPA) through Eastern Research Group, Inc. (ERG) as a contractor and reviewed by ERG and EPA personnel.

IPM Model – Updates to Cost and Performance for
APC Technologies

Project No. 13527-001
April 2017

DSI Cost Methodology

Purpose of Cost Algorithms for the IPM Model

The primary purpose of the cost algorithms is to provide generic order-of-magnitude costs for various air quality control technologies that can be applied to the electric power generating industry on a system-wide basis, not on an individual unit basis. Cost algorithms developed for the IPM model are based primarily on a statistical evaluation of cost data available from various industry publications as well as Sargent & Lundy's proprietary database and do not take into consideration site-specific cost issues. By necessity, the cost algorithms were designed to require minimal site-specific information and were based only on a limited number of inputs such as unit size, gross heat rate, baseline emissions, removal efficiency, fuel type, and a subjective retrofit factor.

The outputs from these equations represent the "average" costs associated with the "average" project scope for the subset of data utilized in preparing the equations. The IPM cost equations do not account for site-specific factors that can significantly affect costs, such as flue gas volume and temperature, and do not address regional labor productivity, local workforce characteristics, local unemployment and labor availability, project complexity, local climate, and working conditions. In addition, the indirect capital costs included in the IPM cost equations do not account for all project-related indirect costs, such as project contingency, that a facility would incur to install a retrofit control.

Technology Description

Dry sorbent injection (DSI) is a viable technology for moderate SO₂/HCl reduction on coal-fired boilers. Demonstrations and utility testing have shown SO₂/HCl removals greater than 80% for systems using sodium-based sorbents. The most commonly used sodium-based sorbent is Trona. However, if the goal is only HCl removal, the amount of sorbent injection will be significantly lower. In this case, Trona may still be the most commonly used reagent, but hydrated lime also has been employed in some situations. Because of Trona's high reactivity with SO₂, when this sorbent is used, significant SO₂ removal must occur before high levels of HCl removal can be achieved. Studies show, however, that hydrated lime is quite effective for HCl removal because the need for simultaneous SO₂ removal is much reduced. In either case, actual testing must be carried out before the permanent DSI system for SO₂ or HCl removal is designed.

The level of removal for Trona can vary from 0 to 90% depending on the Normalized Stoichiometric Ratio (NSR) and particulate capture device. NSR is defined as follows:

$$\frac{\text{(moles of Na injected)}}{\text{(moles of SO}_2 \text{ in flue gas)}} \div \text{(theoretical moles of Na required)}$$

DSI Cost Methodology

The required injection rate for alkali sorbents can vary depending on the required removal efficiency, NSR, and particulate capture device. The costs for an SO₂ mitigation system are primarily dependent on sorbent feed rate. This rate is a function of NSR and the required SO₂ removal (the latter is set by the utility and is not a function of unit size). Therefore, the required SO₂ removal is determined by the user-specified SO₂ emission limit, and the cost estimation is based on sorbent feed rate and not unit size. Because HCl concentrations are low compared with SO₂ concentrations, any unused reagent for SO₂ removal is assumed to be used for HCl removal, resulting in a very small change in the NSR used for SO₂ removal when HCl removal is the main goal.

The sorbent solids can be collected in either an ESP or a baghouse. Baghouses generally achieve greater SO₂ removal efficiencies than ESPs because the presence of filter cake on the bags allows for a longer reaction time between the sorbent solids and the flue gas. Thus, for a given Trona removal efficiency, the NSR is reduced when a baghouse is used for particulate capture.

The dry-sorbent capture ability is also a function of particle surface area. To increase the particle surface area, the sorbent must be injected into a relatively hot flue gas. Heating the solids produces micropores on the particle surface, which greatly improve the sulfur capture ability. For Trona, the sorbent should be injected into flue gas at temperatures above 275°F to maximize the micropore structure. However, if the flue gas is too hot (greater than 800°F), the solids may sinter, reducing their surface area and thus lowering the SO₂ removal efficiency of the sorbent.

Another way to increase surface area is to mechanically reduce the particle size by grinding the sorbent. Typically, Trona is delivered unmilled. The ore is ground such that the unmilled product has an average particle size of approximately 30 µm. Commercial testing has shown that the reactivity of the Trona can be increased when the sorbent is ground to produce particles smaller than 30 µm. In the cost estimation methodology, the Trona is assumed to be delivered in the unmilled state only. To mill the Trona, in-line mills are continuously used during the Trona injection process. Therefore, the delivered cost of Trona will not change; only the reactivity of the sorbent and amount used change when Trona is milled.

Ultimately, the NSR required for a given removal is a function of Trona particle size and particulate capture equipment. In the cost program, the user can choose either as-delivered Trona (approximately 30 µm average size) or in-line milled Trona (approximately 15 µm average size) for injection. The average Trona particle size and the type of particulate removal equipment both contribute to the predicted Trona feed rate.

IPM Model – Updates to Cost and Performance for
APC Technologies

Project No. 13527-001
April 2017

DSI Cost Methodology

Establishment of the Cost Basis

For wet or dry FGD systems, sulfur removal is generally specified at the maximum achievable level. With those systems, costs are primarily a function of plant size and target sulfur removal rate. However, DSI systems are quite different. The major cost for the DSI system is the sorbent itself. The sorbent feed rate is a function of sulfur generation rate, particulate collection device, and removal efficiency. To account for all of the variables, the capital cost was established based on a sorbent feed rate, which is calculated from user input variables. Cost data for several DSI systems were reviewed and a relationship was developed for the capital costs of the system on a sorbent feed-rate basis.

Methodology

Inputs

Several input variables are required in order to predict future retrofit costs. The sulfur feed rate and NSR are the major variables for the cost estimate. The NSR is a function of the following:

- Removal efficiency,
- Sorbent particle size, and
- Particulate capture device.

A retrofit factor that equates to difficulty in construction of the system must be defined. The gross unit size and gross heat rate will factor into the amount of sulfur generated.

Based on commercial testing, removal efficiencies with DSI are limited by the particulate capture device employed. Trona, when captured in an ESP, typically removes 40 to 50% of SO₂ without an increase in particulate emissions, whereas hydrated lime may remove an even lower percentage of SO₂. A baghouse used with sodium-based sorbents generally achieves a higher SO₂ removal efficiency (70 to 90%) than that of an ESP. DSI technology, however, should not be applied to fuels with sulfur content greater than 2 lb SO₂/MMBtu.

Units with a baghouse and limited NO_x control that target a high SO₂ removal efficiency with sodium sorbents may experience a brown plume resulting from the conversion of NO to NO₂. The formation of NO₂ would then have to be addressed by adding an adsorbent, such as activated carbon, into the flue gas. However, many coal-fired units control NO_x to a sufficiently low level that a brown plume should not be an issue with sodium-based DSI. Therefore, this algorithm does not incorporate any additional costs to control NO₂.

IPM Model – Updates to Cost and Performance for
APC Technologies

Project No. 13527-001
April 2017

DSI Cost Methodology

The equations provided in the cost methodology spreadsheet allow the user to input the required removal efficiency, within the limits of the technology. To simplify the correlation between efficiency and technology, SO₂ removal should be set at 50% with an ESP and 70% with a baghouse. The simplified sorbent NSR would then be calculated as follows:

For an ESP at the target 50% removal —

Unmilled Trona NSR = 2.00

Milled Trona NSR = 1.40

For a baghouse at the target 70% removal —

Unmilled Trona NSR = 1.90

Milled Trona NSR = 1.50

The algorithm identifies the maximum expected HCl removal based on SO₂ removal. The HCl removal should be limited to achieve 0.002 lb HCl/MBtu to meet the Mercury Air Toxics (MATS) regulation. The hydrated lime algorithm should be used only for the HCl removal requirement. For hydrated lime injection systems, the SO₂ removal should be limited to 20% to achieve maximum HCl removal.

The correlation could be further simplified by assuming that only milled Trona is used. The current trend in the industry is to use in-line milling of the Trona to improve its utilization. For a minor increase in capital, milling can greatly reduce the variable operating expenses, thus it is recommended that only milled Trona be considered in the simplified algorithm.

Outputs

Total Project Costs (TPC)

First, the base installed cost for the complete DSI system is calculated (BM). The base installed cost includes the following:

- All equipment,
- Installation.
- Buildings,
- Foundations,
- Electrical, and
- Average retrofit difficulty.

The base module cost is adjusted by the selection of in-line milling equipment. The base installed cost is then increased by the following:

IPM Model – Updates to Cost and Performance for
APC Technologies

Project No. 13527-001
April 2017

DSI Cost Methodology

- Engineering and construction management costs at 10% of the BM cost;
- Labor adjustment for 6 x 10-hour shift premium, per diem, etc., at 5% of the BM cost; and
- Contractor profit and fees at 5% of the BM cost.

A capital, engineering, and construction cost subtotal (CECC) is established as the sum of the BM and the additional engineering and construction fees.

Additional costs and financing expenditures for the project are computed based on the CECC. Financing and additional project costs include the following:

- Owner's home office costs (owner's engineering, management, and procurement) are added at 5% of the CECC.
- Allowance for Funds Used During Construction (AFUDC) is added at 0% of the CECC and owner's costs because these projects are expected to be completed in less than a year.

The total project cost is based on a multiple lump-sum contract approach. Should a turnkey engineering procurement construction (EPC) contract be executed, the total project cost could be 10 to 15% higher than what is currently estimated.

Escalation is not included in the estimate. The total project cost (TPC) is the sum of the CECC and the additional costs and financing expenditures.

Fixed O&M (FOM)

The fixed operating and maintenance (O&M) cost is a function of the additional operations staff (FOMO), maintenance labor and materials (FOMM), and administrative labor (FOMA) associated with the DSI installation. The FOM is the sum of the FOMO, FOMM, and FOMA.

The following factors and assumptions underlie calculations of the FOM:

- All of the FOM costs are tabulated on a per-kilowatt-year (kW-yr) basis.
- In general, 2 additional operators are required for a DSI system. The FOMO is based on the number of additional operations staff required.
- The fixed maintenance materials and labor is a direct function of the process capital cost (BM).
- The administrative labor is a function of the FOMO and FOMM.

DSI Cost Methodology

Variable O&M (VOM)

Variable O&M is a function of the following:

- Reagent use and unit costs,
- Waste production and unit disposal costs, and
- Additional power required and unit power cost.

The following factors and assumptions underlie calculations of the VOM:

- All of the VOM costs are tabulated on a per megawatt-hour (MWh) basis.
- The additional power required includes increased fan power to account for the added DSI system and, as applicable, air blowers and transport-air drying equipment for the SO₂ mitigation system.
- The additional power is reported as a percentage of the total unit gross production. In addition, a cost associated with the additional power requirements can be included in the total variable costs.
- The reagent usage is a function of NSR and the required SO₂ removal. The estimated NSR is a function of the removal efficiency required. The basis for total reagent rate purity is 95% for hydrated lime and 98% for Trona.
- The waste-generation rate, which is based on the reaction of Trona or hydrated lime with SO₂, is a function of the sorbent feed rate. The waste-generation rate is also adjusted for excess sorbent fed. The reaction products in the waste for hydrated lime and Trona mainly contain CaSO₄ and Na₂SO₄ and unreacted dry sorbent such as Ca(OH)₂ and Na₂CO₃, respectively.
- The user can remove fly ash disposal volume from the waste disposal cost to reflect the situation where the unit has separate particulate capture devices for fly ash and dry sorbent.
- If Trona is the selected sorbent, the fly ash captured with this sodium sorbent in the same particulate control device must be landfilled. Typical ash content for each fuel is used to calculate a total fly ash production rate. The fly ash production is added to the sorbent waste to account for a total waste stream in the O&M analysis.

DSI Cost Methodology

Input options are provided for the user to adjust the variable O&M costs per unit. Average default values are included in the base estimate. The variable O&M costs per unit options are as follows:

- Reagent cost in \$/ton.
- Waste disposal costs in \$/ton that should vary with the type of waste being disposed.
- Auxiliary power cost in \$/kWh; no noticeable escalation has been observed for auxiliary power cost since 2012.
- Operating labor rate (including all benefits) in \$/hr.

The variables that contribute to the overall VOM are:

VOMR = Variable O&M costs for reagent

VOMW = Variable O&M costs for waste disposal

VOMP = Variable O&M costs for additional auxiliary power

The total VOM is the sum of VOMR, VOMW, and VOMP. The additional auxiliary power requirement is also reported as a percentage of the total gross power of the unit. Table 1 contains an example of the complete capital and O&M cost estimate worksheet for a DSI installation with milled Trona injection ahead of an ESP. Table 2 contains an example of the complete capital and O&M cost estimate worksheet for a DSI installation with milled Trona injection ahead of a baghouse. Table 3 contains an example of the complete capital and O&M cost estimate worksheet for a DSI installation with unmilled Trona injection ahead of an ESP. Table 4 contains an example of the complete capital and O&M cost estimate worksheet for a DSI installation with unmilled Trona ahead of a baghouse. Table 5 contains an example of the complete capital and O&M cost estimate worksheet for a DSI installation with hydrated lime injection ahead of an ESP. Table 6 contains an example of the complete capital and O&M cost estimate worksheet for a DSI installation with hydrated lime ahead of a baghouse.

IPM Model – Updates to Cost and Performance for
APC Technologies

Project No. 13527-001
April 2017

DSI Cost Methodology

Table 1. Example of a Complete Cost Estimate for a Milled Trona DSI System with an ESP

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	500	← User Input
Retrofit Factor	B		1	← User Input (An "average" retrofit has a factor = 1.0)
Gross Heat Rate	C	(Btu/kWh)	9500	← User Input
SO ₂ Rate	D	(lb/MMBtu)	2	← User Input
Type of Coal	E		Bituminous	← User Input
Particulate Capture	F		ESP	← User Input
Sorbent	G		Milled Trona	← User Input
Removal Target	H	(%)	50	Maximum Removal Targets: Unmilled Trona with an ESP = 65% Milled Trona with an ESP = 80% Unmilled Trona with an BGH = 80% Milled Trona with an BGH = 90% Hydrated Lime with an ESP = 30% Hydrated Lime with a BGH = 50%
Heat Input	J	(Btu/hr)	4.76E+09	A*C*1000
NSR	K		1.43	Unmilled Trona with an ESP = if (H<40,0.0350*H,0.352e*(0.0316*H)) Milled Trona with an ESP = if (H<40,0.0270*H,0.353e*(0.0280*H)) Unmilled Trona with a BGH = if (H<40,0.0215*H,0.295e*(0.0267*H)) Milled Trona with a BGH = if (H<40,0.0180*H,0.208e*(0.0281*H)) Hydrated Lime with an ESP = 0.004*H*0.3505 Hydrated Lime with a BGH = 0.0067*H*0.3505
Sorbent Feed Rate	M	(ton/hr)	16.33	Trona = (1.2011 x 10^-08)*K*A*C*D Hydrated Lime = (6.0025 x 10^-07)*K*A*C*D
Estimated HCl Removal	V	(%)	93	Milled or Unmilled Trona with an ESP = 60.89*H*0.1051, or 0.002 lb/MMBtu Milled or Unmilled Trona with a BGH = 84.598*H*0.0346 or 0.002 lb/MMBtu Hydrated Lime with an ESP = 54.92*H*0.167 or 0.002 lb/MMBtu Hydrated Lime with a BGH = 0.0085*H*0.12 or 0.002 lb/MMBtu
Sorbent Waste Rate	N	(ton/hr)	13.12	Trona = (0.7987 + 0.00185*H)*K*M Lime = (1.03 + 0.00777*H)*K*M Waste product adjusted for a maximum inert content of 8% for Trona and 2% for Hydrated Lime.
Fly Ash Waste Rate Include in VOM? <input checked="" type="checkbox"/>	P	(ton/hr)	20.73	(A*C)/Ash in Coal*(1-Boiler Ash Removal)/(2*HHV) For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2; HHV = 11000 For PRB Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2; HHV = 8400 For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2; HHV = 8400 ⇒ Milled Trona M*20/A else M*18/A
Aux Power Include in VOM? <input checked="" type="checkbox"/>	Q	(%)	0.65	
Sorbent Cost	R	(\$/ton)	170	← User Input (Trona = \$170, Hydrated Lime = \$160)
Waste Disposal Cost	S	(\$/ton)	50	← User Input (Disposal cost with fly ash = \$50. Without fly ash, the sorbent waste alone will be more difficult to dispose = \$100)
Aux Power Cost	T	(\$/kWh)	0.05	← User Input
Operating Labor Rate	U	(\$/hr)	60	← User Input (Labor cost including all benefits)

Costs are all based on 2016 dollars

Capital Cost Calculation	Example	Comments
Includes - Equipment, installation, buildings, foundations, electrical, and retrofit difficulty		
BM (\$) = Unmilled Trona or Hydrated Lime if (M>25 then (745,000*B*M) else 7,500,000*B*(M^0.284)) Milled Trona if (M>25 then (820,000*B*M) else 8,300,000*B*(M^0.284))	\$ 18,348,000	Base module for un-milled sorbent includes all equipment from unloading to injection, including dehumidification system
BM (\$/kW) =	37	Base module cost per kW
Total Project Cost		
A1 = 10% of BM	\$ 1,835,000	Engineering and Construction Management costs
A2 = 5% of BM	\$ 917,500	Labor adjustment for 8 x 10 hour shift premium, per diem, etc...
A3 = 5% of BM	\$ 917,500	Contractor profit and fees
CECC (\$) - Excludes Owner's Costs = BM+A1+A2+A3	\$ 22,017,000	Capital, engineering and construction cost subtotal
CECC (\$/kW) - Excludes Owner's Costs =	44	Capital, engineering and construction cost subtotal per kW
B1 = 5% of CECC	\$ 1,101,000	Owners costs including all "home office" costs (owners engineering, management, and procurement activities)
TPC' (\$) - Includes Owner's Costs = CECC + B1	\$ 23,118,000	Total project cost without AFUDC
TPC' (\$/kW) - Includes Owner's Costs =	46	Total project cost per kW without AFUDC
B2 = 0% of (CECC + B1)	\$ -	AFUDC (Zero for less than 1 year engineering and construction cycle)
TPC (\$) = CECC + B1 + B2	\$ 23,118,000	Total project cost
TPC (\$/kW) =	46	Total project cost per kW
Fixed O&M Cost		
FOMM (\$/kW yr) = (2 additional operator)*2080*U/(A*1000)	\$ 0.50	Fixed O&M additional operating labor costs
FOMM (\$/kW yr) = BM*0.01/(B*A*1000)	\$ 0.37	Fixed O&M additional maintenance material and labor costs
FOMA (\$/kW yr) = 0.03*(FOMM+0.4*FOMM)	\$ 0.02	Fixed O&M additional administrative labor costs
FOM (\$/kW yr) = FOMM + FOMM + FOMA	\$ 0.89	Total Fixed O&M costs
Variable O&M Cost		
VOMR (\$/MWh) = M*R/A	\$ 5.55	Variable O&M costs for sorbent
VOMW (\$/MWh) = (N*P)/S/A	\$ 3.39	Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection
VOMP (\$/MWh) = Q*T*10	\$ 0.39	Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above)
VOM (\$/MWh) = VOMR + VOMW + VOMP	\$ 9.33	

IPM Model – Updates to Cost and Performance for
APC Technologies

Project No. 13527-001
April 2017

DSI Cost Methodology

Table 2. Example of a Complete Cost Estimate for a Milled Trona DSI System with a Baghouse

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	500	← User Input
Retrofit Factor	B		1	← User Input (An "average" retrofit has a factor = 1.0)
Gross Heat Rate	C	(Btu/kWh)	9500	← User Input
SO ₂ Rate	D	(lb/MMBtu)	2	← User Input
Type of Coal	E		Bituminous	← User Input
Particulate Capture	F		Baghouse	← User Input
Sorbent	G		Milled Trona	← User Input
Removal Target	H	(%)	80	Maximum Removal Targets: Unmilled Trona with an ESP = 85% Milled Trona with an ESP = 80% Unmilled Trona with an BSH = 80% Milled Trona with an BSH = 60% Hydrated Lime with an ESP = 50% Hydrated Lime with a BSH = 50%
Heat Input	J	(Btu/hr)	4.75E+00	A/C*1000
NSR	K		0.85	Unmilled Trona with an ESP = if (H<40, 0.0350*H, 0.3525*(0.0348*H)) Milled Trona with an ESP = if (H<40, 0.0270*H, 0.3535*(0.0280*H)) Unmilled Trona with a BSH = if (H<40, 0.0215*H, 0.2655*(0.0287*H)) Milled Trona with a BSH = if (H<40, 0.0180*H, 0.2085*(0.0281*H)) Hydrated Lime with an ESP = 0.504*H*0.3505 Hydrated Lime with a BSH = 0.0067*H*0.8505
Sorbent Feed Rate	M	(ton/hr)	9.87	Trona = (1.2011 x 10 ⁻⁰⁸)*K*A*C/D Hydrated Lime = (8.0055 x 10 ⁻⁰⁷)*K*A*C/D
Estimated HCl Removal	V	(%)	87	Milled or Unmilled Trona with an ESP = 80.66*H*0.1091, or 0.002 lb/MMBtu Milled or Unmilled Trona with a BSH = 84.598*H*0.0346 or 0.002 lb/MMBtu Hydrated Lime with an ESP = 54.92*H*0.197 or 0.002 lb/MMBtu Hydrated Lime with a BSH = 0.0025*H*99.12 or 0.002 lb/MMBtu
Sorbent Waste Rate	N	(ton/hr)	8.20	Trona = (0.7387 + 0.00185*H/K)*M Lime = (1.00 + 0.00777*H/K)*M Waste product adjusted for a maximum inert content of 5% for Trona and 2% for Hydrated Lime.
Fly Ash Waste Rate Include in VOM? <input checked="" type="checkbox"/>	P	(ton/hr)	20.73	(A/C)*Ash in Coal*(1-Boiler Ash Removal)/(2*HHV) For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2; HHV = 11000 For PRB Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2; HHV = 8400 For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2 Milled Trona M*20/A else M*18/A
Aux Power Include in VOM? <input checked="" type="checkbox"/>	Q	(%)	0.39	
Sorbent Cost	R	(\$/ton)	170	← User Input (Trona = \$170, Hydrated Lime = \$150)
Waste Disposal Cost	S	(\$/ton)	60	← User Input (Disposal cost with fly ash = \$50. Without fly ash, the sorbent waste alone will be more difficult to dispose = \$100)
Aux Power Cost	T	(\$/kWh)	0.08	← User Input
Operating Labor Rate	U	(\$/hr)	60	← User Input (Labor cost including all benefits)

Costs are all based on 2016 dollars

Capital Cost Calculation	Example	Comments
Includes - Equipment, installation, buildings, foundations, electrical, and retrofit difficulty		
BM (\$) = Unmilled Trona or Hydrated Lime if (M>25 then (745,000*B/M) else 7,600,000*B*(M*0.264) Milled Trona if (M>25 then (820,000*B/M) else 8,300,000*B*(M*0.264)	\$ 16,812,000	Base module for un-milled sorbent includes all equipment from unloading to injection, including dehumidification system
BM (\$/kW) =	32	Base module cost per kW
Total Project Cost		
A1 = 10% of BM	\$ 1,581,000	Engineering and Construction Management costs
A2 = 5% of BM	\$ 791,000	Labor adjustment for 6 x 10 hour shift premium, per diem, etc...
A3 = 5% of BM	\$ 791,000	Contractor profit and fees
CECC (\$) - Excludes Owner's Costs = BM+A1+A2+A3	\$ 18,975,000	Capital, engineering and construction cost subtotal
CECC (\$/kW) - Excludes Owner's Costs =	38	Capital, engineering and construction cost subtotal per kW
B1 = 5% of CECC	\$ 940,000	Owners costs including all "home office" costs (owners' engineering, management, and procurement activities)
TPC' (\$) - Includes Owner's Costs = CECC + B1	\$ 19,924,000	Total project cost without AFUDC
TPC' (\$/kW) - Includes Owner's Costs =	40	Total project cost per kW without AFUDC
B2 = 0% of (CECC + B1)	\$ -	AFUDC (Zero for less than 1 year engineering and construction cycle)
TPC (\$) = CECC + B1 + B2	\$ 19,924,000	Total project cost
TPC (\$/kW) =	40	Total project cost per kW
Fixed O&M Cost		
FOMO (\$/kW yr) = (2 additional operator)*2080*U/(A*1000)	\$ 0.60	Fixed O&M additional operating labor costs
FOMM (\$/kW yr) = BM*0.01/(B*A*1000)	\$ 0.32	Fixed O&M additional maintenance material and labor costs
FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	\$ 0.02	Fixed O&M additional administrative labor costs
FOM (\$/kW yr) = FOMO + FOMM + FOMA	\$ 0.83	Total Fixed O&M costs
Variable O&M Cost		
VOMR (\$/MWh) = M'/R/A	\$ 3.29	Variable O&M costs for sorbent
VOMW (\$/MWh) = (N+P)*S/A	\$ 2.69	Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection
VOMP (\$/MWh) = Q*T*10	\$ 0.23	Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above)
VOM (\$/MWh) = VOMR + VOMW + VOMP	\$ 6.11	

IPM Model – Updates to Cost and Performance for
APC Technologies

Project No. 13527-001
April 2017

DSI Cost Methodology

Table 3. Example of a Complete Cost Estimate for an Unmilled Trona DSI System with an ESP

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(ft ³ /hr)	500	<-- User Input
Retrofit Factor	B		1	<-- User Input (An "average" retrofit has a factor = 1.0)
Gross Heat Rate	C	(Btu/kWh)	9500	<-- User Input
SO ₂ Rate	D	(lb/MMBtu)	2	<-- User Input
Type of Coal	E		Bituminous	<-- User Input
Particulate Capture	F		LSP	<-- User Input
Sorbent	G		Unmilled Trona	<-- User Input
Removal Target	H	(%)	50	Maximum Removal Targets: Unmilled Trona with an ESP = 65% Milled Trona with an ESP = 80% Unmilled Trona with a BGH = 80% Milled Trona with a BGH = 90% Hydrated Lime with an ESP = 30% Hydrated Lime with a BGH = 50%
Heat Input	J	(Btu/hr)	4.76E+09	A*C*1000
NSR	K		1.99	Unmilled Trona with an ESP = if (H<40, 0.0350*H, 0.352e*(0.0345*H)) Milled Trona with an ESP = if (H<40, 0.0270*H, 0.353e*(0.0280*H)) Unmilled Trona with a BGH = if (H<40, 0.0215*H, 0.295e*(0.0267*H)) Milled Trona with a BGH = if (H<40, 0.0160*H, 0.208e*(0.0281*H)) Hydrated Lime with an ESP = 0.604*H*0.3905 Hydrated Lime with a BGH = 0.0087*H+0.6505
Sorbent Feed Rate	M	(ton/hr)	22.54	Trona = (1.2011 x 10 ⁻⁰⁶)*K*A*C*D Hydrated Lime = (6.0055 x 10 ⁻⁰⁷)*K*A*C*D
Estimated HCl Removal	V	(%)	93	Milled or Unmilled Trona with an ESP = 60.86*H*0.1081, or 0.002 lb/MMBtu Milled or Unmilled Trona with a BGH = 84.598*H*0.0348 or 0.002 lb/MMBtu Hydrated Lime with an ESP = 54.52*H*0.197 or 0.002 lb/MMBtu Hydrated Lime with a BGH = 0.0085*H+99.12 or 0.002 lb/MMBtu
Sorbent Waste Rate	N	(ton/hr)	17.71	Trona = (0.7387 + 0.00195*H)*M Lime = (1.00 + 0.00777*H)*M Waste product adjusted for a maximum inert content of 5% for Trona and 2% for Hydrated Lime.
Fly Ash Waste Rate Include in WOM? <input checked="" type="checkbox"/>	P	(ton/hr)	20.73	(A/C)*Ash in Coal*(1-Boiler Ash Removal)/(2*HHV) For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2; HHV = 11000 For PRB Coal: Ash in Coal = 0.06; Boiler Ash Removal = 0.2; HHV = 8400 For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2
Aux Power Include in WOM? <input checked="" type="checkbox"/>	Q	(%)	0.81	= if Milled Trona M*20/A else M*18/A
Sorbent Cost	R	(\$/ton)	225	<-- User Input (Trona = \$170, Hydrated Lime = \$150)
Waste Disposal Cost	S	(\$/ton)	50	<-- User Input (Disposal cost with fly ash = \$50. Without fly ash, the sorbent waste alone will be more difficult to dispose = \$100)
Aux Power Cost	T	(\$/kWh)	0.06	<-- User Input
Operating Labor Rate	U	(\$/hr)	60	<-- User Input (Labor cost including all benefits)

Costs are all based on 2016 dollars

Capital Cost Calculation

Includes - Equipment, installation, buildings, foundations, electrical, and retrofit difficulty

BM (\$) = Unmilled Trona or Hydrated Lime if (M>25 then (745,000*B*M) else 7,500,000*B*(M*0.284)
Milled Trona if (M>25 then (820,000*B*M) else 8,300,000*B*(M*0.284)

BM (\$/kW) =

Total Project Cost

A1 = 10% of BM

A2 = 5% of BM

A3 = 5% of BM

CECC (\$) - Excludes Owner's Costs = BM+A1+A2+A3

CECC (\$/kW) - Excludes Owner's Costs =

B1 = 5% of CECC

TPC (\$) - Includes Owner's Costs = CECC + B1

TPC (\$/kW) - Includes Owner's Costs =

B2 = 0% of (CECC + B1)

TPC (\$) = CECC + B1 + B2

TPC (\$/kW) =

Fixed O&M Cost

FOMO (\$/kW yr) = (2 additional operator)*2080*U/(A*1000)

FOMM (\$/kW yr) = BM*0.01/(B*A*1000)

FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)

FOM (\$/kW yr) = FOMO + FOMM + FOMA

Variable O&M Cost

VOMR (\$/MWh) = M*R/A

VOMW (\$/MWh) = (N+P)*S/A

VOMP (\$/MWh) = Q*T*10

VOM (\$/MWh) = VOMR + VOMW + VOMP

Example

Comments

\$	18,168,000	Base module for unmillied sorbent includes all equipment from unloading to injection, including dehumidification system
	36	Base module cost per kW
\$	1,817,000	Engineering and Construction Management costs
\$	908,000	Labor adjustment for 6 x 10 hour shift premium, per diem, etc...
\$	908,000	Contractor profit and fees
\$	21,891,000	Capital, engineering and construction cost subtotal
	44	Capital, engineering and construction cost subtotal per kW
\$	1,050,000	Owners costs including all "home office" costs (owners engineering, management, and procurement activities)
\$	22,891,000	Total project cost without AFUDC
	46	Total project cost per kW without AFUDC
\$	-	AFUDC (Zero for less than 1 year engineering and construction cycle)
\$	22,891,000	Total project cost
	46	Total project cost per kW
\$	0.50	Fixed O&M additional operating labor costs
\$	0.36	Fixed O&M additional maintenance material and labor costs
\$	0.02	Fixed O&M additional administrative labor costs
\$	0.88	Total Fixed O&M costs
\$	10.14	Variable O&M costs for sorbent
\$	3.84	Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection
\$	0.49	Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above)
\$	14.47	

IPM Model – Updates to Cost and Performance for
APC Technologies

Project No. 13527-001
April 2017

DSI Cost Methodology

Table 4. Example of a Complete Cost Estimate for an Unmilled Trona DSI System with a Baghouse

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	500	← User Input
Retrofit Factor	B		1	← User Input (An "average" retrofit has a factor = 1.0)
Gross Heat Rate	C	(Btu/kWh)	9500	← User Input
SO ₂ Rate	D	(lb/MMBtu)	2	← User Input
Type of Coal	E		Bituminous	← User Input
Particulate Capture	F		Baghouse	← User Input
Sorbent	G		Unmilled Trona	← User Input
Removal Target	H	(%)	50	Maximum Removal Targets: Unmilled Trona with an ESP = 65% Milled Trona with an ESP = 80% Unmilled Trona with an BGH = 80% Milled Trona with an BGH = 90% Hydrated Lime with an ESP = 50% Hydrated Lime with a BGH = 50%
Heat Input	J	(Btu/hr)	4.76E+09	A*C*1000
NSR	K		1.12	Unmilled Trona with an ESP = if (H<40,0.0350*H,0.352e*(0.0345*H)) Milled Trona with an ESP = if (H<40,0.0270*H,0.363e*(0.0280*H)) Unmilled Trona with a BGH = if (H<40,0.0215*H,0.285e*(0.0267*H)) Milled Trona with a BGH = if (H<40,0.0160*H,0.208e*(0.0281*H)) Hydrated Lime with an ESP = 0.604*H*0.3405 Hydrated Lime with a BGH = 0.0057*H*0.6505
Sorbent Feed Rate	M	(ton/hr)	12.79	Trona = (1.2011 x 10 ⁻⁶)*K*A*C*D Hydrated Lime = (6.0055 x 10 ⁻⁶)*K*A*C*D
Estimated HCl Removal	V	(%)	97	Milled or Unmilled Trona with an ESP = 0.66*H*0.1031, or 0.002 lb/MMBtu Milled or Unmilled Trona with a BGH = 0.6459*H*0.0348 or 0.002 lb/MMBtu Hydrated Lime with an ESP = 0.6462*H*0.197 or 0.002 lb/MMBtu Hydrated Lime with a BGH = 0.0085*H*0.12 or 0.002 lb/MMBtu
Sorbent Waste Rate	N	(ton/hr)	10.50	Trona = (0.7367 + 0.00185*H)*M Lime = (1.00 + 0.0377*H)*M Waste product adjusted for a maximum in-ash content of 5% for Trona and 2% for Hydrated Lime.
Fly Ash Waste Rate Include in VOM? <input checked="" type="checkbox"/>	P	(ton/hr)	20.73	(A*C)*Ash in Coal*((1-Boiler Ash Removal)/(2*HHV)) For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2; HHV = 11000 For PRB Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2; HHV = 9400 For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2 =if Milled Trona M/20A else M*18A
Aux Power Include in VOM? <input checked="" type="checkbox"/>	Q	(%)	0.46	← User Input (Trona = \$170, Hydrated Lime = \$150)
Sorbent Cost	R	(\$/ton)	225	← User Input (Disposal cost with fly ash = \$50. Without fly ash, the sorbent waste alone will be more difficult to dispose = \$100)
Waste Disposal Cost	S	(\$/ton)	50	← User Input
Aux Power Cost	T	(\$/kWh)	0.05	← User Input
Operating Labor Rate	U	(\$/hr)	60	← User Input (Labor cost including all benefits)

Costs are all based on 2016 dollars

Capital Cost Calculation	Example	Comments
Includes - Equipment, installation, buildings, foundations, electrical, and retrofit difficulty		
BM (\$) = Unmilled Trona or Hydrated Lime if (M>25 then (745,000*B*M) else 7,600,000*B*(M^0.284)) Milled Trona if (M>25 then (620,000*B*M) else 8,300,000*B*(M^0.284))	\$ 16,469,000	Base module for unimilled sorbent includes all equipment from unloading to injection, including dehumidification system
BM (\$/kW) =	31	Base module cost per kW
Total Project Cost		
A1 = 10% of BM	\$ 1,647,000	Engineering and Construction Management costs
A2 = 5% of BM	\$ 773,000	Labor adjustment for 6 x 10 hour shift premium, per dlem, etc...
A3 = 5% of BM	\$ 773,000	Contractor profit and fees
CECC (\$) - Excludes Owner's Costs = BM+A1+A2+A3	\$ 18,561,000	Capital, engineering and construction cost subtotal
CECC (\$/kW) - Excludes Owner's Costs =	37	Capital, engineering and construction cost subtotal per kW
B1 = 5% of CECC	\$ 928,000	Owners costs including all "home office" costs (owners engineering, management, and procurement activities)
TPC (\$) - Includes Owner's Costs = CECC + B1	\$ 19,489,000	Total project cost without AFUDC
TPC (\$/kW) - Includes Owner's Costs =	39	Total project cost per kW without AFUDC
B2 = 0% of (CECC + B1)	\$ -	AFUDC (Zero for less than 1 year engineering and construction cycle)
TPC (\$) = CECC + B1 + B2	\$ 19,489,000	Total project cost
TPC (\$/kW) =	39	Total project cost per kW
Fixed O&M Cost		
FOMO (\$/kW yr) = (2 additional operator)*(2080*Li/(A*1000))	\$ 0.50	Fixed O&M additional operating labor costs
FOMM (\$/kW yr) = BM*0.01/(B*A*1000)	\$ 0.31	Fixed O&M additional maintenance material and labor costs
FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	\$ 0.02	Fixed O&M additional administrative labor costs
FOM (\$/kW yr) = FOMO + FOMM + FOMA	\$ 0.83	Total Fixed O&M costs
Variable O&M Cost		
VOMR (\$/MWh) = M*R/A	\$ 5.76	Variable O&M costs for sorbent
VOMW (\$/MWh) = (N+P)*S/A	\$ 3.12	Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection
VOMP (\$/MWh) = Q*T*10	\$ 0.28	Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above)
VOM (\$/MWh) = VOMR + VOMW + VOMP	\$ 9.16	

IPM Model – Updates to Cost and Performance for
APC Technologies

Project No. 13527-001
April 2017

DSI Cost Methodology

Table 5. Example of a Complete Cost Estimate for a Hydrated Lime DSI System with an ESP

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	500	<— User Input
Retrofit Factor	B		1	<— User Input (An "average" retrofit has a factor = 1.0)
Gross Heat Rate	C	(Btu/kWh)	9600	<— User Input
SO ₂ Rate	D	(lb/MMBtu)	2	<— User Input
Type of Coal	E		Bituminous	<— User Input
Particulate Capture	F		ESP	<— User Input
Sorbent	G		Hydrated Lime	<— User Input
Removal Target	H	(%)	30	Maximum Removal Targets: Unmilled Trona with an ESP = 65% Milled Trona with an ESP = 80% Unmilled Trona with an BGH = 80% Milled Trona with an BGH = 90% Hydrated Lime with an ESP = 30% Hydrated Lime with a BGH = 50%
Heat Input	J	(Btu/hr)	4.78E+09	A*C*1000
NSR	K		1.00	Unmilled Trona with an ESP = if (H<40, 0.0360*H, 0.352e*(0.0346*H)) Milled Trona with an ESP = if (H<40, 0.0270*H, 0.353e*(0.0280*H)) Unmilled Trona with a BGH = if (H<40, 0.0215*H, 0.295e*(0.0287*H)) Milled Trona with a BGH = if (H<40, 0.0180*H, 0.208e*(0.0281*H)) Hydrated Lime with an ESP = 0.604*H*0.3505 Hydrated Lime with a BGH = 0.0087*H*0.8505
Sorbent Feed Rate	M	(ton/hr)	10.85	Trona = (1.2011 x 10 ⁻⁸)*K*A*C*D Hydrated Lime = (8.0055 x 10 ⁻⁷)*K*A*C*D
Estimated HCl Removal	V	(%)	95	Milled or Unmilled Trona with an ESP = 80.66*H*0.1031, or 0.002 lb/MBtu Milled or Unmilled Trona with a BGH = 84.698*H*0.0348, or 0.002 lb/MBtu Hydrated Lime with an ESP = 54.82*H*0.167, or 0.002 lb/MBtu Hydrated Lime with a BGH = 0.0085*H*99.12, or 0.002 lb/MBtu
Sorbent Waste Rate	N	(ton/hr)	12.18	Trona = (0.7387 + 0.00185*H)*M Lime = (1.00 + 0.00777*H)*M Waste product adjusted for a maximum inert content of 6% for Trona and 2% for Hydrated Lime.
Fly Ash Waste Rate Include in VOM? <input checked="" type="checkbox"/>	P	(ton/hr)	20.73	(A*C)*Ash in Coal*(1-Boiler Ash Removal)/(2*H*H) For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2; HHV = 11600 For PRB Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2; HHV = 8400 For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2
Aux Power Include in VOM? <input checked="" type="checkbox"/>	Q	(%)	0.39	= if Milled Trona M*20/A else M*18/A
Sorbent Cost	R	(\$/ton)	150	<— User Input (Trona = \$170, Hydrated Lime = \$150)
Waste Disposal Cost	S	(\$/ton)	80	<— User Input (Disposal cost with fly ash = \$80. Without fly ash, the sorbent waste alone will be more difficult to dispose = \$100)
Aux Power Cost	T	(\$/kWh)	0.08	<— User Input
Operating Labor Rate	U	(\$/hr)	60	<— User Input (Labor cost including all benefits)

Costs are all based on 2016 dollars

Capital Cost Calculation

Includes - Equipment, installation, buildings, foundations, electrical, and retrofit difficulty

BM (\$) = Unmilled Trona or Hydrated Lime if (M>25 then (745,000*B*M) else 7,600,000*B*(M*0.284)
Milled Trona if (M>25 then (820,000*B*M) else 8,300,000*B*(M*0.284)

BM (\$/kW) =

Total Project Cost

A1 = 10% of BM

A2 = 5% of BM

A3 = 5% of BM

CECC (\$) - Excludes Owner's Costs = BM+A1+A2+A3

CECC (\$/kW) - Excludes Owner's Costs =

B1 = 5% of CECC

TPC' (\$) - Includes Owner's Costs = CECC + B1

TPC' (\$/kW) - Includes Owner's Costs =

B2 = 0% of (CECC + B1)

TPC (\$) = CECC + B1 + B2

TPC (\$/kW) =

Fixed O&M Cost

FOMO (\$/kW yr) = (2 additional operator)*2080*U/(A*1000)

FOMM (\$/kW yr) = BM*0.01/(B*A*1000)

FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)

FOM (\$/kW yr) = FOMO + FOMM + FOMA

Variable O&M Cost

VOMR (\$/MWh) = M*P/A

VOMW (\$/MWh) = (N+P)*S/A

VOMP (\$/MWh) = Q*T*10

VOM (\$/MWh) = VOMR + VOMW + VOMP

Example

Comments

\$	14,782,000	Base module for unmilled sorbent includes all equipment from unloading to injection, including dehumidification system
30		Base module cost per kW
\$	1,476,000	Engineering and Construction Management costs
\$	738,000	Labor adjustment for 8 x 10 hour shift premium, per diem, etc...
\$	738,000	Contractor profit and fees
\$	17,714,000	Capital, engineering and construction cost subtotal
35		Capital, engineering and construction cost subtotal per kW
\$	869,000	Owners costs including all "home office" costs (owners engineering, management, and procurement activities)
\$	18,600,000	Total project cost without AFUDC
37		Total project cost per kW without AFUDC
\$		AFUDC (Zero for less than 1 year engineering and construction cycle)
\$	18,600,000	Total project cost
37		Total project cost per kW
\$	0.80	Fixed O&M additional operating labor costs
\$	0.30	Fixed O&M additional maintenance material and labor costs
\$	0.02	Fixed O&M additional administrative labor costs
\$	0.81	Total Fixed O&M costs
\$	3.28	Variable O&M costs for sorbent
\$	3.29	Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection
\$	0.23	Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above)
\$	6.78	

IPM Model – Updates to Cost and Performance for
APC Technologies

Project No. 13527-001
April 2017

DSI Cost Methodology

Table 6. Example of a Complete Cost Estimate for a Hydrated Lime DSI System with a Baghouse

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	800	<-- User Input
Retrofit Factor	B		1	<-- User Input (An "average" retrofit has a factor = 1.0)
Gross Heat Rate	C	(Btu/kWh)	9500	<-- User Input
SO ₂ Rate	D	(lb/MWh)	2	<-- User Input
Type of Coal	E		Bituminous	<-- User Input
Particulate Capture	F		Baghouse	<-- User Input
Sorbent	G		Hydrated Lime	<-- User Input
Removal Target	H	(%)	60	Maximum Removal Targets: Unmilled Trona with an ESP = 65% Milled Trona with an ESP = 80% Unmilled Trona with an BGH = 80% Milled Trona with an BGH = 90% Hydrated Lime with an ESP = 30% Hydrated Lime with a BGH = 50%
Heat Input	J	(Btu/hr)	4.75E+09	A*C*1000
NSR	K		1.00	Unmilled Trona with an ESP = if (H<40,0.0350*H,0.352e*(0.0345*H)) Milled Trona with an ESP = if (H<40,0.0270*H,0.353e*(0.0280*H)) Unmilled Trona with a BGH = if (H<40,0.0210*H,0.295e*(0.0267*H)) Milled Trona with a BGH = if (H<40,0.0160*H,0.208e*(0.0281*H)) Hydrated Lime with an ESP = 0.504*H+0.3105 Hydrated Lime with a BGH = 0.0087*H+0.8535
Sorbent Feed Rate	M	(ton/hr)	0.19	Trona = (J/1.2011 x 10 ⁶ Btu) / (K*A*C*D) Hydrated Lime = (J/0.0056 x 10 ⁶ Btu) / (K*A*C*D)
Estimated HCl Removal	V	(%)	99	Milled or Unmilled Trona with an ESP = 80.88*H*0.1091, or 0.002 lb/MWh Milled or Unmilled Trona with a BGH = 84.598*H*0.0348, or 0.002 lb/MWh Hydrated Lime with an ESP = 54.62*H*0.187, or 0.002 lb/MWh Hydrated Lime with a BGH = 0.0085*H*99.12, or 0.002 lb/MWh
Sorbent Waste Rate	N	(ton/hr)	0.41	Trona = (0.7997 + 0.00185*H*K)*M Lime = (1.00 + 0.00777*H*K)*M Waste product adjusted for a maximum inert content of 5% for Trona and 2% for Hydrated Lime.
Fly Ash Waste Rate Include in VOM? <input checked="" type="checkbox"/>	P	(ton/hr)	20.73	(A*C)*Ash in Coal*(1-Boiler Ash Removal)/(2*HHV) For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2; HHV = 11000 For PRB Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2; HHV = 8400 For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal
Aux Power Include in VOM? <input checked="" type="checkbox"/>	Q	(%)	0.22	=if Milled Trona M*20/A else M*18/A
Sorbent Cost	R	(\$/ton)	150	<-- User Input (Trona = \$170, Hydrated Lime = \$120)
Waste Disposal Cost	S	(\$/ton)	60	<-- User Input (Disposal cost with fly ash = \$50. Without fly ash, the sorbent waste alone will be more difficult to dispose = \$100)
Aux Power Cost	T	(\$/kWh)	0.06	<-- User Input
Operating Labor Rate	U	(\$/hr)	60	<-- User Input (Labor cost including all benefits)

Costs are all based on 2016 dollars

Capital Cost Calculation	Example	Comments
Includes - Equipment, installation, buildings, foundations, electrical, and retrofit difficulty		
BM (\$) = Unmilled Trona or Hydrated Lime if (M>25 then (745,000*B*M) else 7,500,000*B*(M*0.284)	\$ 12,598,000	Base module for unmilled sorbent includes all equipment from unloading to injection, including dehumidification system
BM (\$/kW) = Milled Trona if (M>25 then (820,000*B*M) else 8,300,000*B*(M*0.284)	25	Base module cost per kW
Total Project Cost		
A1 = 10% of BM	\$ 1,259,800	Engineering and Construction Management costs
A2 = 5% of BM	\$ 629,900	Labor adjustment for 6 x 10 hour shift premium, per diem, etc...
A3 = 5% of BM	\$ 629,900	Contractor profit and fees
CECC (\$) - Excludes Owner's Costs = BM+A1+A2+A3	\$ 15,105,000	Capital, engineering and construction cost subtotal
CECC (\$/kW) - Excludes Owner's Costs =	30	Capital, engineering and construction cost subtotal per kW
B1 = 5% of CECC	\$ 755,000	Owners costs including all "home office" costs (owners engineering, management, and procurement activities)
TPC' (\$) - Includes Owner's Costs = CECC + B1	\$ 15,860,000	Total project cost without AFUDC
TPC' (\$/kW) - Includes Owner's Costs =	32	Total project cost per kW without AFUDC
B2 = 0% of (CECC + B1)	\$	AFUDC (Zero for less than 1 year engineering and construction cycle)
TPC (\$) = CECC + B1 + B2	\$ 15,860,000	Total project cost
TPC (\$/kW) =	32	Total project cost per kW
Fixed O&M Cost		
FOMO (\$/kW yr) = (2 additional operator)*2080*U/(A*1000)	\$ 0.60	Fixed O&M additional operating labor costs
FOMM (\$/kW yr) = BM*0.01/(B*A*1000)	\$ 0.26	Fixed O&M additional maintenance material and labor costs
FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	\$ 0.02	Fixed O&M additional administrative labor costs
FOM (\$/kW yr) = FOMO + FOMM + FOMA	\$ 0.77	Total Fixed O&M costs
Variable O&M Cost		
VOMR (\$/MWh) = M*R/A	\$ 1.80	Variable O&M costs for sorbent
VOMW (\$/MWh) = (N*P)*S/A	\$ 2.91	Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection
VOMP (\$/MWh) = Q*T*10	\$ 0.13	Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above)
VOM (\$/MWh) = VOMR + VOMW + VOMP	\$ 4.91	

