



## Cokenergy, LLC

3210 Watling Street  
Mail Code 2-991  
East Chicago, Indiana 46312

October 29, 2019

Chief, Environmental Enforcement Section  
Environment and Natural Resources Division  
U.S. Department of Justice  
Box 7611, Ben Franklin Station  
Washington, DC 20044-7611  
Re: DOJ No. 90-5-2-1-08555/1

Air Enforcement Division Director  
U.S. Environmental Protection Agency  
Office of Civil Enforcement  
Air Enforcement Division  
U.S. Environmental Protection Agency  
1200 Pennsylvania Ave, NW Mail Code: 2242A  
Washington, DC 20460

Compliance Tracker  
Air Enforcement and Compliance Assurance Branch  
U.S. Environmental Protection Agency – Region 5  
77 West Jackson Blvd. AE-18J  
Chicago, IL 60604-3590

Susan Tennenbaum  
U.S. Environmental Protection Agency  
Region 5  
C-14J  
77 West Jackson Blvd  
Chicago, IL 60640

Including an electronic copy to:  
[R5airenforcement@epa.gov](mailto:R5airenforcement@epa.gov)

Including an electronic copy to:  
[tennenbaum.susan@epa.gov](mailto:tennenbaum.susan@epa.gov)

Phil Perry  
Indiana Department of Environmental Management  
Chief, Air Compliance and Enforcement Branch  
100 North Senate Avenue  
MC-61-53, IGCN 1003  
Indianapolis, IN 46204-2251

Elizabeth A. Zlatos  
Indiana Department of Environmental Management  
Office of Legal Counsel  
100 North Senate Avenue  
MC-60-01, IGCN 1307  
Indianapolis, IN 46204-2251

Including an electronic copy to:  
[bzlatos@idem.in.gov](mailto:bzlatos@idem.in.gov)

**Subject:** Consent Decree, United States, et al. v. Indiana Harbor Coke Company, et al.  
Cokenergy, LLC (Part 70 Permit No. T089-38695-00383)  
Semi-Annual Progress Report – April 1, 2019 through September 30, 2019

To Whom It May Concern:

In accordance with Section VIII (Reporting Requirements), Paragraph 51. of the consent decree (18-cv-35), Cokenergy, LLC has prepared a semi-annual progress report detailing activities for the period of April 1, 2019 until September 30, 2019. This report provides an update on Cokenergy's activities during the reporting period. Indiana Harbor Coke Company (IHCC) activities will be provided under a separate cover prepared and submitted by IHCC.

Paragraph 51.a. requires details on work performed and progress made towards implementing the requirements of Section IV (Compliance Requirements), including completion of any milestones. The following paragraphs provide an update on our compliance requirements.

### **Bypass Venting**

**Paragraph 14.a – Annual Bypass Venting Limit** - From January 1, 2017, through December 31, 2019, a maximum of 12% of the Coke Oven waste gases leaving the common tunnel shall be allowed to be vented to the atmosphere through the Bypass Vent Stacks, as determined on an annual basis.

- Bypass venting for the reporting period of April 1, 2019 – September 30, 2019 was 6.49%.
- Year to date bypass venting for the period of January 1, 2019 – September 30, 2019 was 5.13%.

**Paragraph 15. – Daily Bypass Venting Limit** – A Maximum of 19% of the Coke Oven waste gases leaving the common tunnel shall be allowed to be vented to the atmosphere through the Bypass Vent Stacks on a twenty-four (24) hour average.

- During the reporting period of April 1, 2019 through September 30, 2019 there were no incidents of exceedance of the Daily Bypass Venting Limit.

**Paragraph 16. – SO<sub>2</sub> Daily Limit** – Defendants shall limit SO<sub>2</sub> emissions from the Main Stack and Bypass Vent Stacks to 1,656 lbs/hr for a twenty-four (24) hour average.

- During the reporting period of April 1, 2019 through September 30, 2019 there were no incidents of exceedance of the SO<sub>2</sub> Daily Limit.

**Paragraph 17. – Emissions Minimization**

- During the reporting period of April 1, 2019 through September 30, 2019 there were no incidents of exceedance of the Daily Bypass Venting Limit, therefore it was not necessary to implement any Emissions Minimization measures. (Paragraph 51.f.)

**Paragraph 18. – Bypass Venting Incident Root Cause Failure Analysis**

- During the reporting period of April 1, 2019 through September 30, 2019 there were no incidents of exceedance of the Daily Bypass Venting Limit, therefore there were no Bypass Venting Incident RCFA completed. (Paragraph 51.g. and 51.h.)

### **Enhanced Monitoring**

**Paragraph 22. – Bypass Vent Stack and Main Stack Testing**

- Cokenergy is currently planning to complete stack testing for lead and VOC on the Main Stack the week of December 2, 2019.

### **Preventive Maintenance and Operation Plans**

**Paragraph 23.c. – Compliance Assurance**

- The CAP is addressed in Section 9.0 of Cokenergy's PMO Plan. IHCC has not reported production levels in excess of rates included in 23. c. i. during the reporting period of April 1, 2019 through September 30, 2019.

**Paragraph 23.d.** – *Defendants shall comply with the PMO Plans at all times, including periods of startup, shutdown, and malfunction of the HRSB and FGD.*

- Cokenergy has fully implemented our PMO plan and is following the requirements of the PMO plan.

#### Mitigation Measures

**Paragraph 24** – Dual SDA Operation

- Cokenergy has successfully operated the SDAs in dual operation mode prior to the effective date of the CD, except during periods of planned maintenance. The plant wide emissions of SO<sub>2</sub> through September 30, 2019 are approximately 4,033 tons, which projects to be less than 6,165 tons/year.

#### Permits

**Paragraph 26.** – Permits – complete

- IDEM issued the Significant Source Modification (089-40905-00383) and Significant Permit Modification (089-41033-00383) for Public Comment on March 4, 2019. The Public Comment period ended on April 3, 2019. The approved Significant Source Modification was issued by IDEM on April 18, 2019 and the approved Significant Permit Modification was issued by IDEM on May 8, 2019. (Paragraph 51.k.)

**Paragraph 27.b.** – Application to seek a site-specific revision to the Indiana State Implementation Plan (“SIP”) at 326 IAC 7-4.1-7 and 326 IAC 7-4.1-8 - Complete

- Cokenergy formally submitted our request to modify the SIP on December 18, 2018 within the ninety (90) Day requirement specified in the CD. IDEM developed the draft rule LSA Document #19-388 which was posted on August 14, 2019 for public comment. The public comment period ended on September 13, 2019 and a Public Hearing was scheduled by IDEM for the proposed rule on November 13, 2019. (Paragraph 51.k.).

The following paragraphs provide a status update on the requirements of Paragraphs 51.b. through 51.p. that were not addressed above as applicable to Cokenergy operations.

Cokenergy has no modifications to report. Dual SDA operation is our normal operating mode and the Permanent Flow Monitor has been fully integrated into our Continuous Emissions Monitoring System (CEMS) and the Emissions Tracking System (ETS). (Paragraph 51.b.)

Cokenergy did not encounter any problems or anticipate any problems in complying with the Compliance Requirements (Paragraph 51.c.).

Cokenergy has not completed any stack testing required in Paragraph 22. Cokenergy is planning on conducting stack testing for Lead and VOC on the Main Stack the week of December 2, 2019. Details on CEMS performance and QA/QC activities completed on the CEMS is included in the attached quarterly Compliance Monitoring and Deviation Reports. (Paragraph 51.d.)

There were no changes or updates to the PMO plan during the reporting period. (Paragraph 51.i.)

Cokenergy does not have any noncompliance with the Section VII SEP requirements to report per Paragraph 51.l. Cokenergy continues working with Elevate Energy on the lead abatement SEP. To date three (3) lead abatement projects have been completed.

Per Paragraph 51.m. there have been no failures to comply with the reporting requirements in Paragraphs 51, through 55.

Per Paragraph 51.n. Cokenergy has attached copies of the following reports:

- Second Quarter 2019 Deviation and Compliance Monitoring Report; and
- Third Quarter 2019 Deviation and Compliance Monitoring Report;

Pursuant to Paragraph 51.o. the following table is a summary of Lightning Stand-Downs during the April 1, 2019 through September 30, 2019 reporting period.

Start Date/Time	Lightning Warning Detail	End Date/Time	Duration	Compliance response impacted due to lightning stand down
4/11/2019 21:22	Alert: Ltg Waring (south 9)	4/11/2019 22:28	1:06:00	None
4/11/2019 22:52	Alert: Ltg Warning (southwest 10)	4/12/2019 1:27	2:35:00	None
4/18/2019 4:33	Alert: Ltg Warning (West 10)	4/18/2019 5:51	1:18:00	None
4/22/2019 19:00	Alert: Ltg Warning (west 6)	4/22/2019 20:17	1:17:00	None
4/29/2019 7:09	Alert: Ltg Warning (south 5)	4/29/2019 7:50	0:41:00	None
4/29/2019 7:54	Alert: Ltg Warning (northeast 3)	4/29/2019 9:43	1:49:00	None
4/29/2019 9:47	Alert: Ltg Warning (southeast 10)	4/29/2019 10:17	0:30:00	None
4/30/2019 13:54	Alert: Ltg Warning (west 8)	4/30/2019 14:31	0:37:00	None
4/30/2019 14:59	Alert: Ltg Warning (southwest 7)	4/30/2019 16:21	1:22:00	None
5/1/2019 1:14	Alert: Ltg Warning (southeast 9)	5/1/2019 1:45	0:31:00	None
5/1/2019 4:16	Alert: Ltg Warning (southwest 9)	5/1/2019 5:05	0:49:00	None
5/6/2019 23:52	Alert: Ltg Warning (northwest 1)	5/7/2019 0:35	0:43:00	None
5/16/2019 12:06	Alert: Ltg Warning (southwest 5)	5/16/2019 12:36	0:30:00	None
5/16/2019 12:44	Alert: Ltg Warning (northwest 4)	5/16/2019 14:19	1:35:00	None
5/16/2019 22:13	Alert: Ltg Warning (east 8)	5/17/2018 0:55	2:42:00	None
5/17/2019 1:06	Alert: Ltg Warning (northwest 10)	5/17/2019 2:12	1:06:00	None
5/18/2019 14:45	Alert: Ltg Warning (west 9)	5/18/2019 16:45	2:00:00	None
5/22/2019 0:48	Alert: Ltg Warning (southwest 9)	5/22/2019 1:51	1:03:00	None
5/23/2019 3:00	Alert: Ltg Warning (east 1)	5/23/2019 3:31	0:31:00	None
5/24/2019 5:54	Alert: Ltg Warning (southwest 9)	5/24/2019 7:49	1:55:00	None
5/26/2019 1:56	Alert: Ltg Warning (south 9)	5/26/2019 2:27	0:31:00	None
5/27/2019 13:53	Alert: Ltg Warning (southwest 2)	5/27/2019 18:48	4:55:00	None
5/28/2019 15:40	Alert: Ltg Warning (south 9)	5/28/2019 16:10	0:30:00	None

Start Date/Time	Lightning Warning Detail	End Date/Time	Duration	Compliance response impacted due to lightning stand down
5/28/2019 21:34	Alert: Ltg Warning (south 10)	5/29/2019 0:24	2:50:00	None
5/30/2019 1:48	Alert: Ltg Warning (southwest 8)	5/30/2019 3:17	1:29:00	None
6/1/2019 15:14	Alert: Ltg Warning (West 10)	6/1/2019 15:59	0:45:00	None
6/1/2019 16:31	Alert: Ltg Warning (northwest 9)	6/1/2019 17:20	0:49:00	None
6/1/2019 17:26	Alert: Ltg Warning (north 7)	6/1/2019 20:12	2:46:00	None
6/5/2019 1:37	Alert: Ltg Warning (north 9)	6/5/2019 2:50	1:13:00	None
6/5/2019 3:49	Alert: Ltg Warning (West 10)	6/5/2019 5:08	1:19:00	None
6/15/2019 12:05	Alert: Ltg Warning (south 8)	6/15/2019 12:35	0:30:00	None
6/16/2019 1:26	Alert: Ltg Warning (west 6)	6/16/2019 1:56	0:30:00	None
6/23/2019 6:34	Alert: Ltg Warning (southwest 10)	6/23/2019 7:31	0:57:00	None
6/23/2019 13:21	Alert: Ltg Warning (south 4)	6/23/2019 14:38	1:17:00	None
6/25/2019 17:02	Alert: Ltg Warning (north 6)	6/25/2019 17:32	0:30:00	None
6/26/2019 19:55	Alert: Ltg Warning (south 10)	6/26/2019 20:39	0:44:00	None
6/26/2019 20:43	Alert: Ltg Warning (east 10)	6/26/2019 21:13	0:30:00	None
6/26/2019 23:56	Alert: Ltg Warning (southeast 7)	6/27/2019 2:26	2:30:00	None
6/27/2019 19:52	Alert: Ltg Warning (north 8)	6/27/2019 20:28	0:36:00	None
6/28/2019 11:55	Alert: Ltg Warning (west 10)	6/28/2019 12:59	1:04:00	None
6/28/2019 18:18	Alert: Ltg Warning (northwest 4)	6/28/2019 19:14	0:56:00	None
6/30/2019 14:49	Alert: Ltg Warning (west 10)	6/30/2019 16:14	1:25:00	None
7/2/2019 13:46	Alert: Ltg Warning (northwest 10)	7/2/2019 14:32	0:46:00	None
7/2/2019 19:17	Alert: Ltg Warning (north 10)	7/2/2019 22:44	3:27:00	None
7/5/2019 18:05	Alert: Ltg Warning (west 7)	7/5/2019 19:14	1:09:00	None
7/5/2019 20:11	Alert: Ltg Warning (west 4)	7/5/2019 21:41	1:30:00	None
7/6/2019 14:04	Alert: Ltg Warning (south 10)	7/6/2019 14:34	0:30:00	None
7/13/2019 18:59	Alert: Ltg Warning (west 9)	7/13/2019 21:07	2:08:00	None
7/16/2019 13:52	Alert: Ltg Warning (northwest 10)	7/16/2019 14:22	0:30:00	None
7/16/2019 14:46	Alert: Ltg Warning (south 9)	7/16/2019 15:56	1:10:00	None
7/17/2019 17:28	Alert: Ltg Warning (southwest 9)	7/17/2019 18:18	0:50:00	None
7/18/2019 7:28	Alert: Ltg Warning (south 10)	7/18/2019 12:45	5:17:00	None
7/20/2019 17:49	Alert: Ltg Warning (east 9)	7/20/2019 18:31	0:42:00	None
7/21/2019 12:37	Alert: Ltg Warning (southeast 3)	7/21/2019 15:51	3:14:00	None
7/29/2019 9:41	Alert: Ltg Warning (northwest 7)	7/29/2019 10:11	0:30:00	None
7/29/2019 13:41	Alert: Ltg Warning (northwest 10)	7/29/2019 14:36	0:55:00	None
7/29/2019 16:53	Alert: Ltg Warning (north 8)	7/29/2019 19:31	2:38:00	None
8/13/2019 19:23	Alert: Ltg Warning (west 10)	8/13/2019 20:07	0:44:00	None
8/17/2019 2:13	Alert: Ltg Warning (northeast 8)	8/17/2019 2:43	0:30:00	None
8/17/2019 6:49	Alert: Ltg Warning (southwest 7)	8/17/2019 7:45	0:56:00	None
8/18/2019 6:58	Alert: Ltg Warning (northwest 8)	8/18/2019 11:08	4:10:00	None

Start Date/Time	Lightning Warning Detail	End Date/Time	Duration	Compliance response impacted due to lightning stand down
8/20/2019 11:39	Alert: Ltg Warning (west 10)	8/20/2019 12:09	0:30:00	None
8/20/2019 12:13	Alert: Ltg Warning (west 10)	8/20/2019 13:50	1:37:00	None
9/3/2019 7:39	Alert: Ltg Warning (north 9)	9/3/2019 8:20	0:41:00	None
9/3/2019 8:24	Alert: Ltg Warning (northwest 8)	9/3/2019 10:31	2:07:00	None
9/3/2019 20:27	Alert: Ltg Warning (northeast 6)	9/3/2019 20:57	0:30:00	None
9/9/2019 11:27	Alert: Ltg Warning (northwest 10)	9/9/2019 12:27	1:00:00	None
9/10/2019 5:21	Alert: Ltg Warning (northwest 3)	9/10/2019 5:51	0:30:00	None
9/11/2019 20:57	Alert: Ltg Warning (northeast 4)	9/11/2019 21:27	0:30:00	None
9/12/2019 0:14	Alert: Ltg Warning (east 4)	9/12/2019 0:44	0:30:00	None
9/12/2019 3:39	Alert: Ltg Warning (southwest 10)	9/12/2019 5:24	1:45:00	None
9/12/2019 18:56	Alert: Ltg Warning (east 9)	9/12/2019 20:34	1:38:00	None
9/13/2019 5:18	Alert: Ltg Warning (northwest 10)	9/13/2019 6:47	1:29:00	None
9/15/2019 0:54	Alert: Ltg Warning (southwest 10)	9/15/2019 1:50	0:56:00	None
9/15/2019 3:26	Alert: Ltg Warning (north 8)	9/15/2019 4:36	1:10:00	None
9/15/2019 4:44	Alert: Ltg Warning (north 3)	9/15/2019 5:37	0:53:00	None
9/15/2019 5:57	Alert: Ltg Warning (southeast 9)	9/15/2019 6:30	0:33:00	None
9/27/2019 11:12	Alert: Ltg Warning (southwest 10)	9/27/2019 16:52	5:40:00	None
9/27/2019 16:56	Alert: Ltg Warning (south 9)	9/27/2019 23:36	6:40:00	None
9/28/2019 1:19	Alert: Ltg Warning (northwest 7)	9/28/2019 1:55	0:36:00	None
9/29/2019 3:36	Alert: Ltg Warning (southwest 8)	9/29/2019 5:38	2:02:00	None

Per Paragraph 51.p. the following table is a summary of power outages during the April 1, 2019 through September 30, 2019 reporting period reporting period.

Event #	Start Date/Time	Details	End Date/Time	Duration
1	5/27/2019 16:30	Power Loss to IHCC A/C substation	5/27/2019 22:10	5:39:00
2	5/30/2019 2:41	Power Loss to IHCC A/C substation	5/30/2019 8:14	5:33:00

On May 27, 2019 at 16:30 CDT, IHCC experienced a trip on their A/C battery substation. This trip resulted in all 8 of A- and C-battery Heat Recovery Steam Generators (HRSGs) losing power and tripping offline, with all 8 stack lids going open simultaneously. All 8 A/C stack lids opening at the same time, combined with only 5 HRSGs online on B/D batteries (due to IHCC oven work) created a draft pressure excursion resulting in interlock trip of both Cokenergy ID fans at high fenceline draft. Loss of both ID fans resulted in the remaining HRSGs coming offline, and the Cokenergy steam turbine generator (STG) subsequently tripped at low steam. Cokenergy Operations quickly returned #2 ID fan to operation and were able to return 5 HRSGs to service. IHCC also resolved the A/C substation trip during this time. #2 ID fan was maintained online as a single ID fan to allow return-to-service of the remaining HRSGs and restart of the STG. The STG returned to service at 22:10 CDT Monday evening. #1 ID fan was restarted at 06:29 Tuesday morning, with all plant systems returned to normal operation. *There were no environmental exceedances as a result of this event.*


On May 30, 2019 at 02:41 CDT, IHCC experienced a ground fault on their A/C battery substation. This trip resulted in all 8 of A- and C-battery HRSGs losing power and tripping offline, with all 8 stack lids going open simultaneously. All 8 A/C stack lids opening at the same time, combined with only 5 HRSGs online on B/D batteries (due to IHCC oven work) created a draft pressure excursion resulting in interlock trip of both Cokenergy ID fans at high fenceline draft. Loss of both ID fans resulted in the remaining HRSGs coming offline and Cokenergy STG subsequently tripped at low steam. A/C substation power was restored by IHCC at approximately 03:12 CDT. #1 ID fan was returned to operation 04:04 CDT and Cokenergy Operations began the process of warming HRSGs for return to operation. At approximately 05:54 CDT, IHCC experienced a second A/C substation fault, again resulting in lost power for all A/C HRSGs. Cokenergy operated at reduced draft set-point (-14.5 inWC) to prevent a second trip of the on-line ID fan with the A/C trip. IHCC reset the breaker at approximately 05:56 CDT and the process of restoring HRSGs, closing stack lids continued. The STG was restarted at 08:14 CDT. IHCC identified a faulted 480V cable feeding their baghouse MCC Room. Since this breaker doesn't have Ground Fault Protection, the main breaker tripped. The bad section of cable was replaced, and the Fenceline Draft restored in -18 inWC. IHCC completed further investigations of the cable condition to identify if further repairs were needed. *Plant-wide SO2 and venting were within permit limits for the day, however there were three (3), six (6) minute opacity exceedances which occurred when #2 ID fan was restarted after the second A/C substation fault.*

---

If you have any questions regarding this semi-annual progress report, please contact me at (219) 397-4626 or email at [lford@primaryenergy.com](mailto:lford@primaryenergy.com).

I certify under penalty of law that this information was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my directions and my inquiry of the person(s) who manage the system, or the person(s) directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,



Luke E. Ford  
Director EH&S  
Primary Energy

cc: East Chicago Public Library  
2401 E. Columbus Drive  
East Chicago, Indiana 46312

East Chicago Public Library  
1008 W. Chicago Avenue  
East Chicago, Indiana 46312

---

#### Attachments

File: X://675

# ATTACHMENT 1

First Quarter 2019 Deviation and  
Compliance Monitoring Report





# Cokenergy LLC

3210 Watling Street MC 2-991  
East Chicago, IN 46312

July 18, 2019

Via UPS

Indiana Department of Environmental Management  
Compliance and Enforcement Branch  
Office of Air Quality  
100 N. Senate Avenue  
Mail Code 61-50, IGCN 1003  
Indianapolis, IN 46204 - 2251

RE: Cokenergy, LLC Quarterly Report – Second Quarter 2019  
Part 70 Permit No. T089-36965-00383

To Whom It May Concern:

In accordance with sections C.18 and D.1.14 of the subject permit, 326 IAC 3-5-5 and 326 IAC 3-5-7, we have enclosed the second quarter 2019 reports for the Cokenergy, LLC facility. This report includes:

- Part 70 Quarterly Report – Certification
- Part 70 Quarterly Deviation and Compliance Report
- CEMS Excess Emissions Report
- CEMS Downtime Report
- COMS Second Quarter 2019 Opacity Monitor Audit
- CEMS Second Quarter 2019 Cylinder Gas Audit

If you have any questions concerning this data, please call Luke Ford at (219) 397-4626.

Sincerely,

Seth Acheson  
General Manager  
Cokenergy LLC

Enclosure

cc: Luke Ford (scan via email)  
Cliff Yukawa IDEM (scan via email)

File: X:\615.4

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR MANAGEMENT  
COMPLIANCE AND ENFORCEMENT SECTION  
PART 70 OPERATING PERMIT  
CERTIFICATION**

Source Name: Cokenergy LLC

Source Address: 3210 Watling Street, MC 2-991, East Chicago, Indiana 46312-1610

Part 70 Permit No. : T089-36965-00383

**This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.**

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify) 2<sup>nd</sup> Quarter 2019 COMS Performance Audit and Cylinder Gas Audit
- Report (specify) 2<sup>nd</sup> Quarter 2019 Deviation and Compliance Monitoring Report
- Notification (specify) \_\_\_\_\_
- Affidavit (specify) \_\_\_\_\_
- Other (specify) \_\_\_\_\_

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature: 

Printed Name: Seth Acheson

Title/Position: General Manager, Cokenergy, LLC

Phone: (219) 397-4521

Date: July 18, 2019

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH  
PART 70 OPERATING PERMIT  
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: Cokenergy LLC  
 Source Address: 3210 Watling Street, MC 2-991, East Chicago, Indiana 46312-1610  
 Part 70 Permit No. : T089-36965-00383

Months: April to July Year: 2019

This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. Deviations that are required to be reported by an applicable requirement shall be reported according to the schedule stated in the applicable requirement and do not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".

NO DEVIATIONS OCCURRED THIS REPORTING PERIOD

THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD

**Permit Requirement:** (specify permit condition #) C.1 (a)

**Date of Deviation:** 5/30/2019

**Duration of Deviation:** 18 minutes

**Number of Deviations:** 3

**Probable Cause of Deviation:** On May 30, 2019 at approximately 1:42 AM CST the Indiana Harbor Coke Company (IHCC) facility experienced a loss of power to the A/C substation when the 3A1 main breaker tripped. This caused a power interruption to the A/C substation and subsequently all A/C battery HRSGs. This sudden disruption caused both ID fans to trip offline along with the Cokenergy steam turbine and generator. As the fans were being restarted at approximately 2:30 AM a second trip of the 3A1 main breaker occurred and the No. 1 ID fan tripped. The No. 2 ID fan was restarted at approximately 3:03 AM and there were three (3), six (6) minute opacity exceedances due to dust which settled in the duct work after the second ID fan trip. ID fan No.1 was left offline while IHCC identified the cause of the fault to prevent motor damage. ID fan No. 1 was restarted at 11:41 AM.

**Response Steps Taken:** Air flow and draft were stabilized once ID fan No. 2 was online.

**Permit Requirement:** (specify permit condition #)

**Date of Deviation:**

**Duration of Deviation:**

**Number of Deviations:**

**Probable Cause of Deviation:**

**Response Steps Taken:**



---

## **Excess Emissions and Downtime Report**

---

COKENERGY, LLC, East Chicago, IN

Plant ID: 089-00383

Emissions Unit ID: Stack 201

Emissions Unit: Heat Recovery Coke Carbonization Waste Heat Stack

**PLANT OPERATIONS DOWNTIME SUMMARY**

Reporting Period: 2nd Quarter of 2019

Commencement of Emission Unit Downtime	Completion of Emission Unit Downtime	Emission Unit Downtime Duration (hours)	Reasons for Emission Unit Downtime
5/30/2019 1:42	5/30/2019 5:32	4	IHCC A/C Substation Power Loss
Total Emission Unit Downtime for the quarter =		4	hours

COKENERGY, LLC, East Chicago, IN

Plant ID: 089-00383

Emissions Unit ID: Stack 201

Emissions Unit: Heat Recovery Coke Carbonization Waste Heat Stack

**EXCESS EMISSIONS SUMMARY**

Reporting Period: 2nd Quarter of 2019

**SO<sub>2</sub> Exceedances**

Emission Standard: 1,656 lb/hr on a 24-hr average basis

(Note that this limit is for the combined emissions from Cokenergy Stack 201 and 16 IHCC Vent Stacks)

Date/Time of Commencement	Date/Time of Completion	Magnitude of Emissions (lb/hr)			Reasons for Excess Emissions	Corrective Actions Taken
		Main Stack Avg	Vent Stack Avg	Plant Avg		
<b>None</b>						

COKENERGY, LLC, East Chicago, IN  
 Plant ID: 089-00383

Emissions Unit ID: Stack 201

Emissions Unit: Heat Recovery Coke Carbonization Waste Heat Stack

**EXCESS EMISSIONS SUMMARY**

Reporting Period: 2nd Quarter of 2019

**Opacity Exceedances**

Emission Standard: 20% opacity

Date/Time of Commencement	Date/Time of Completion	Magnitude of Emissions	Reasons for Excess Emissions	Corrective Actions Taken
5/30/19 3:11	5/30/19 3:29	38.1	Plant trip due to power loss of IHCC A/C substation, ID fans and FGD tripped offline.	IHCC restored power to substation, allowing Cokenergy to return equipment to normal operation.
Total Duration	18 minutes			



COKENERGY, LLC, East Chicago, IN

Plant ID: 089-00383

Emissions Unit ID: Stack 201

Emissions Unit: Heat Recovery Coke Carbonization Waste Heat Stack

**CONTINUOUS MONITORING SYSTEM DOWNTIME SUMMARY**

Reporting Period: 2nd Quarter of 2019

**Opacity Monitor Downtime**

Date/Time of Commencement	Duration of Downtime (minutes)	Reasons for Instrument Downtime	System Repairs and Adjustments
6/10/19 12:00	60	Quarterly PMs and Opacity Performance Audit	Completed PMs and audit
<b>Total Downtime</b>	<b>60 minutes</b>		

Note: Daily zero and span checks of the instrument have been excluded from the downtime summary per 326 IAC 3-5-7.

COKENERGY, LLC, East Chicago, IN

Plant ID: 089-00383

Emissions Unit ID: Stack 201

Emissions Unit: Heat Recovery Coke Carbonization Waste Heat Stack

### CONTINUOUS MONITORING SYSTEM DOWNTIME SUMMARY

Reporting Period: 2nd Quarter of 2019

#### SO<sub>2</sub> CEMS Downtime

Date/Time of Commencement	Duration of Downtime (hours)	Reasons for Instrument Downtime	System Repairs and Adjustments
4/11/19 18:00	11	Sample pump failure	Placed backup pump in service.
4/12/19 5:00	1	Replaced sample pump	Removed temporary pump from service, performed calibration
5/1/19 6:00	3	CEMS system maintenance on wet O2	Checked linearity on wet O2 ordered a replacement cell.
6/10/19 11:00	3	Complete quarterly PMs and CGA on the CEMS	Routine quarterly preventative maintenance
Total Downtime	18 hours		

**Note:** Daily zero and span checks of the instrument have been excluded from the downtime summary per 326 IAC 3-5-7.

COKENERGY, LLC, East Chicago, IN

Plant ID: 089-00383

Emissions Unit ID: Stack 201

Emissions Unit: Heat Recovery Coke Carbonization Waste Heat Stack

**CONTINUOUS MONITORING SYSTEM DOWNTIME SUMMARY**

Reporting Period: 2nd Quarter of 2019

**Flow Monitor Downtime**

Date/Time of Commencement	Duration of Downtime (hours)	Reasons for Instrument Downtime	System Repairs and Adjustments
6/10/19 12:00	1.00	Quarterly PM & Leak Check	Completed PMS
<b>Total Downtime</b>	<b>1 hours</b>		

Note: Daily zero and span checks of the instrument have been excluded from the downtime summary per 326 IAC 3-5-7.

# CYLINDER GAS AUDIT

*FOR*

## **Primary Energy**

*E. Chicago, IN*

**Unit: Stack 201**

**MONITORING SOLUTIONS, INC.  
FULL EXTRACTIVE**

**Second (2nd) Quarter Results  
2019**

CGA Completed On: 6/10/2019

**PREPARED BY:**



**Monitoring | Solutions**

*Leaders in Environmental Monitoring Systems & Services*

TABLE OF CONTENTS

***I. Introduction .....1***  
***II. Cylinder Gas Audit Procedures ..... 3***  
***III. Cylinder Gas Audit Data Sheets ..... 5***  
***IV. Cylinder Gas Certification Sheets ..... 6***

**LIST OF TABLES**

<b>Table</b>	<b>Page</b>
Table 1-1: Summary of Cylinder Gas Audit Results	2
Table 1-2: Measurement Points for Cylinder Gas Audit	3

**I. Introduction**

Monitoring Solutions, Inc. was contracted to conduct a Cylinder Gas Audit on a Continuous Emission Monitoring System (CEMS). This audit was performed:

**Client:** Primary Energy  
**City, State:** E. Chicago, IN  
**Unit:** Stack 201  
**Auditor:** Dan Bowles  
**Audit Date:** 6/10/2019

The audit of the Continuous Emission Monitoring System was conducted for the following gases:

Gas #1 : SO2  
Gas #2 : O2 Dry & O2 Wet

Our assessment of this quarter's CGA results indicates that all of the analyzers evaluated during this test program meet the accuracy requirements as outlined in 40 CFR 60, Appendix F.

**NOTE:** Table 1-1 summarizes the results for the cylinder gas audit.

Reviewed by: John Pollock

Date: 06/27/2019

## Summary of Cylinder Gas Audit Results

<b>Parameter</b>	<b>Low Gas Error</b>	<b>Mid Gas Error</b>
SO <sub>2</sub>	0.57	0.86
O <sub>2</sub> Dry	0.00	2.31
O <sub>2</sub> Wet	2.00	0.37
	Pass	Pass

Table 1-1

40 CFR 60, Appendix F Performance Test requirements: <15%



**II. CYLINDER GAS AUDIT PROCEDURES**

Each Continuous Emission Monitor (CEM) must be audited three out of four calendar quarters of each year. As part of the Quality Control (QC) and Quality Assurance (QA) procedures, the quality of data produced is evaluated by response accuracy compared to known standards,

The Cylinder Gas Audit (CGA) for this quarter was conducted in accordance with the QA/QC procedure outlined in 40 CFR 60, Appendix F.

All applicable audit gases are connected to the sampling system. Each gas is introduced into the sampling and analysis system. The gases flow through as much of the sampling path as possible.

The gases are actuated on and off by utilizing a computer and/or PLC controlled solenoids at designated time intervals.

- a) Challenge each monitor (both pollutant and diluent, if applicable) with cylinder gases of known concentrations at two measurement points listed in Table 1-2.
- b) Use a separate cylinder gas for measurement points 1 and 2. Challenge the CEMS three times at each measurement point and record the responses.
- c) Use cylinder gases that have been certified by comparison to National Institute of Standards and Technology (NIST) gaseous standard reference material (SRM) or NIST/EPA approved gas manufacturer’s certified reference material (CRM) following “Traceability Protocol for Establishing True Concentrations of Gases Used for Calibration and Audits of Continuous Source Emission Monitors. (Protocol Number 1).”

**NOTE:** In rare cases, some operators may have pollutant cylinder gases that are not "Protocol 1". Pollutant cylinder gases in high concentrations may not be certifiable to the "Protocol 1 Standard" and are only available as a "Certified Standard" (e.g. Sulfur Dioxide [SO<sub>2</sub>] in a concentration of 3.0% - or - 30,000 ppm).

<i>Gas</i>	<i>Measurement point #1</i>	<i>Measurement point #2</i>
Pollutants -	20-30% of span value	50-60% of span value
Diluent - O <sub>2</sub>	4-6% by volume	8-12% by volume
Diluent - CO <sub>2</sub>	5-8% by volume	10-14% by volume

Table 1-2

**NOTE:** Some operators may have cylinder gas values that fall outside of these parameters. This may be a result of previous agreements with their state or local EPA authority.

- d) Determine the Relative Accuracy of each measurement point using the formula below. The RA error must not exceed 15%.

$$RA = \left| \left( \frac{\bar{d}}{AC} \right) 100 \right| \leq 15 \text{ percent}$$

Where:

RA = Relative Accuracy

$\bar{d}$  = Average of the three responses (Arithmetic Mean)

AC = The certified concentration of the cylinder gas.

### **III. Cylinder Gas Audit Data Sheets**

# CYLINDER GAS AUDIT (CGA) ERROR DETERMINATION

<b>CLIENT:</b> <u>Primary Energy</u> <b>PLANT / SITE:</b> <u>E. Chicago, IN</u> <b>UNIT ID:</b> <u>Stack 201</u>	<b>CONDUCTED BY :</b> <u>Dan Bowles</u> <b>ATTENDEE :</b> <u>N/A</u> <b>AUDIT DATE:</b> <u>6/10/2019</u>
<b>MONITOR TESTED:</b> <u>O2 Dry</u> <b>RANGE :</b> <u>0 - 25</u> %	<b>ANALYZER SERIAL NUMBER:</b> <u>11400</u>

	Run	Time	Reference value	Monitor value	Difference	Error %
Low-level	1	13:25	5.00	5.00	0.00	0.00 %
	2	13:43	5.00	5.00	0.00	0.00 %
	3	14:01	5.00	5.00	0.00	0.00 %
Mid-level	1	13:31	9.97	10.20	0.23	2.31 %
	2	13:49	9.97	10.20	0.23	2.31 %
	3	14:07	9.97	10.20	0.23	2.31 %

Low-level	Arithmetic Mean: 5.00  <b>CGA Error:        0.00 %</b>	Tank S/N <u>CC14789</u> Tank Expiration Date <u>7/25/2025</u>
-----------	--	--

Mid-Level	Arithmetic Mean: 10.20  <b>CGA Error:        2.31 %</b>	Tank S/N <u>CC400438</u> Tank Expiration Date <u>8/16/2025</u>
-----------	---	---

Date	Parameter	Run#	Timestamp	Type	Expected	Measured	Low Diff	-----	Mid Diff	-----
------	-----------	------	-----------	------	----------	----------	----------	-------	----------	-------

06/10/2019

	O2 DRY, %	1	13:25:38	QTR_LOW	5.0	5.0	0.0			
	O2 DRY, %	1	13:31:36	QTR_MID	10.0	10.2			0.2	
	O2 DRY, %	2	13:43:37	QTR_LOW	5.0	5.0	0.0			
	O2 DRY, %	2	13:49:37	QTR_MID	10.0	10.2			0.2	
	O2 DRY, %	3	14:01:37	QTR_LOW	5.0	5.0	0.0			
	O2 DRY, %	3	14:07:37	QTR_MID	10.0	10.2			0.2	

Arithmetic Mean of Quarterly Low : 5.0  
 Linearity Error of Quarterly Low : 0.2  
 Calibration Tolerance: 15.0

Arithmetic Mean of Quarterly Mid : 10.2  
 Linearity Error of Quarterly Mid : 2.3  
 Calibration Tolerance: 15.0

Calibration Result : Pass

CEMS Type : Full Extractive  
 Manufacturer: Brand Gaus  
 Model Number : 4705  
 Serial Number: 11400  
 Monitor Certification Date:

Tested By : \_\_\_\_\_

Date: \_\_\_\_\_

# CYLINDER GAS AUDIT (CGA) ERROR DETERMINATION

<b>CLIENT:</b> <u>Primary Energy</u> <b>PLANT / SITE:</b> <u>E. Chicago, IN</u> <b>UNIT ID:</b> <u>Stack 201</u>	<b>CONDUCTED BY :</b> <u>Dan Bowles</u> <b>ATTENDEE :</b> <u>N/A</u> <b>AUDIT DATE:</b> <u>6/10/2019</u>
<b>MONITOR TESTED:</b> <u>O2 Wet</u> <b>RANGE :</b> <u>0 - 25</u> %	<b>ANALYZER SERIAL NUMBER:</b> <u>11401</u>

	Run	Time	Reference value	Monitor value	Difference	Error %
Low-level	1	13:25	5.00	4.90	-0.10	-2.00 %
	2	13:43	5.00	4.90	-0.10	-2.00 %
	3	14:01	5.00	4.90	-0.10	-2.00 %
Mid-level	1	13:31	9.97	9.90	-0.07	-0.70 %
	2	13:49	9.97	9.90	-0.07	-0.70 %
	3	14:07	9.97	10.00	0.03	0.30 %

Low-level	Arithmetic Mean: 4.90  <b>CGA Error: 2.00 %</b>	Tank S/N <u>CC14789</u> Tank Expiration Date <u>7/25/2025</u>
-----------	---	--

Mid-Level	Arithmetic Mean: 9.93  <b>CGA Error: 0.37 %</b>	Tank S/N <u>CC400438</u> Tank Expiration Date <u>8/16/2025</u>
-----------	---	---

Date	Parameter	Run#	Timestamp	Type	Expected	Measured	Low Diff	-----	Mid Diff	-----
------	-----------	------	-----------	------	----------	----------	----------	-------	----------	-------

06/10/2019

	O2 WET, %	1	13:25:38	QTR_LOW	5.0	4.9	0.1			
	O2 WET, %	1	13:31:36	QTR_MID	10.0	9.9			0.1	
	O2 WET, %	2	13:43:37	QTR_LOW	5.0	4.9	0.1			
	O2 WET, %	2	13:49:37	QTR_MID	10.0	9.9			0.1	
	O2 WET, %	3	14:01:37	QTR_LOW	5.0	4.9	0.1			
	O2 WET, %	3	14:07:37	QTR_MID	10.0	10.0			0.0	

Arithmetic Mean of Quarterly Low : 4.9  
 Linearity Error of Quarterly Low : 2.2  
 Calibration Tolerance: 15.0

Arithmetic Mean of Quarterly Mid : 9.9  
 Linearity Error of Quarterly Mid : 0.4  
 Calibration Tolerance: 15.0

Calibration Result : Pass

CEMS Type : Full Extractive  
 Manufacturer: Brand Gaus  
 Model Number : 4705  
 Serial Number: 11401  
 Monitor Certification Date:

Tested By : \_\_\_\_\_

Date: \_\_\_\_\_

# CYLINDER GAS AUDIT (CGA) ERROR DETERMINATION

<b>CLIENT:</b> <u>Primary Energy</u> <b>PLANT / SITE:</b> <u>E. Chicago, IN</u> <b>UNIT ID:</b> <u>Stack 201</u>	<b>CONDUCTED BY :</b> <u>Dan Bowles</u> <b>ATTENDEE :</b> <u>N/A</u> <b>AUDIT DATE:</b> <u>6/10/2019</u>
<b>MONITOR TESTED:</b> <u>SO2</u> <b>RANGE :</b> <u>0 - 700 PPM</u>	<b>ANALYZER SERIAL NUMBER:</b> <u>1152150034</u>

	Run	Time	Reference value	Monitor value	Difference	Error %
Low-level	1	13:25	176.50	175.30	-1.20	-0.68 %
	2	13:43	176.50	176.10	-0.40	-0.23 %
	3	14:01	176.50	175.10	-1.40	-0.79 %
Mid-level	1	13:19	391.60	388.80	-2.80	-0.72 %
	2	13:37	391.60	387.20	-4.40	-1.12 %
	3	13:55	391.60	388.70	-2.90	-0.74 %

Low-level	Arithmetic Mean: 175.50  <b>CGA Error:        0.57 %</b>	Tank S/N <u>CC14789</u> Tank Expiration Date <u>7/25/2025</u>
-----------	--	--

Mid-Level	Arithmetic Mean: 388.23  <b>CGA Error:        0.86 %</b>	Tank S/N <u>SG9150083</u> Tank Expiration Date <u>12/17/2026</u>
-----------	--	---



Date	Parameter	Run#	Timestamp	Type	Expected	Measured	Low Diff	-----	Mid Diff	-----
06/10/2019										
	SO2, PPM	1	13:19:37	QTR_MID	391.6	388.8			2.8	
	SO2, PPM	1	13:25:38	QTR_LOW	176.5	175.3	1.2			
	SO2, PPM	2	13:37:36	QTR_MID	391.6	387.2			4.4	
	SO2, PPM	2	13:43:37	QTR_LOW	176.5	176.1	0.4			
	SO2, PPM	3	13:55:37	QTR_MID	391.6	388.7			2.9	
	SO2, PPM	3	14:01:37	QTR_LOW	176.5	175.1	1.4			

Arithmetic Mean of Quarterly Low : 175.5  
 Linearity Error of Quarterly Low : 0.6  
 Calibration Tolerance: 15.0

Arithmetic Mean of Quarterly Mid : 388.2  
 Linearity Error of Quarterly Mid : 0.9  
 Calibration Tolerance: 15.0

Calibration Result : Pass

CEMS Type : Full Extractive  
 Manufacturer: Thermo  
 Model Number : 43i-HL  
 Serial Number: 1152150034  
 Monitor Certification Date:

Tested By : \_\_\_\_\_

Date: \_\_\_\_\_

## **IV. Cylinder Gas Certification Sheets**

In Service 9/29/17

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number:	E02NI90E15A0228	Reference Number:	54-400967311-1
Cylinder Number:	CC400438	Cylinder Volume:	145.2 CF
Laboratory:	124 - Chicago (SAP) - IL	Cylinder Pressure:	2015 PSIG
PGVP Number:	B12017	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Aug 16, 2017

**Expiration Date: Aug 16, 2025**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	10.00 %	9.970 %	G1	+/- 1% NIST Traceable	08/16/2017
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	06120102	CC195613	9.898 % OXYGEN/NITROGEN	+/- 0.7%	Jul 26, 2018

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
O2-1 HORIBA MPA-510 3VUYL9NR	Paramagnetic	Jul 17, 2017

Triad Data Available Upon Request



*Abbas Hussain*

Approved for Release

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number: E04NI84E15A0007	Reference Number: 54-124629354-1
Cylinder Number: CC14789	Cylinder Volume: 150.4 CF
Laboratory: 124 - Chicago - IL	Cylinder Pressure: 2015 PSIG
PGVP Number: B12017	Valve Outlet: 660
Gas Code: CO2,O2,SO2,BALN	Certification Date: Jul 25, 2017

**Expiration Date: Jul 25, 2025**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

### ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
SULFUR DIOXIDE	175.0 PPM	176.5 PPM	G1	+/- 1.0% NIST Traceable	07/17/2017, 07/25/2017
OXYGEN	5.000 %	5.009 %	G1	+/- 1.0% NIST Traceable	07/18/2017
CARBON DIOXIDE	10.00 %	10.00 %	G1	+/- 0.9% NIST Traceable	07/17/2017
NITROGEN	Balance				

### CALIBRATION STANDARDS


Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060140	CC437515	515.2 PPM SULFUR DIOXIDE/NITROGEN	+/- 0.8%	Nov 16, 2021
NTRM	11060719	CC338460	4.861 % OXYGEN/NITROGEN	+/- 0.4%	Dec 13, 2022
NTRM	13060635	CC413759	13.359 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	May 09, 2019

### ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801332	FTIR	Jun 21, 2017
O2-1 HORIBA MPA-510 3VUYL9NR	Paramagnetic	Jul 17, 2017
Nicolet 6700 AHR0801332	FTIR	Jul 21, 2017

Triad Data Available Upon Request



  
 Approved for Release

*In Service  
5/1/19*

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number:	E03NI89E15A0052	Reference Number:	54-401367855-1
Cylinder Number:	SG9150083	Cylinder Volume:	149.9 CF
Laboratory:	124 - Chicago (SAP) - IL	Cylinder Pressure:	2015 PSIG
PGVP Number:	B12018	Valve Outlet:	660
Gas Code:	CO2,SO2,BALN	Certification Date:	Dec 17, 2018

**Expiration Date: Dec 17, 2026**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

### ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
SULFUR DIOXIDE	385.0 PPM	391.6 PPM	G1	+/- 1.0% NIST Traceable	12/10/2018, 12/17/2018
CARBON DIOXIDE	10.00 %	9.912 %	G1	+/- 0.7% NIST Traceable	12/10/2018
NITROGEN	Balance				

### CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	15060628	CC450467	248.1 PPM SULFUR DIOXIDE/NITROGEN	+/- 0.6%	Dec 17, 2020
NTRM	13060738	CC414595	16.939 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	May 08, 2019

### ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801332	FTIR	Nov 26, 2018
Nicolet 6700 AHR0801332	FTIR	Nov 26, 2018

Triad Data Available Upon Request



*Alban Kucari*

Approved for Release

# OPACITY PERFORMANCE AUDIT

*FOR*

## Primary Energy

*E. Chicago, IN*

**Unit: Stack 201**

**MONITORING SOLUTIONS, INC.  
MODEL: DURAG D-R 290 COMS**

**Second (2nd) Quarter Results  
2019**

Audit Completed On: 6/10/2019

**PREPARED BY:**



TABLE OF CONTENTS

***I. Introduction ..... 1***

***II. Monitoring Solutions, Inc. COMS Model Durag D-R 290***

    A. COMS Description..... 2

    B. Performance Audit Procedures ..... 3

    C. Interpretation of Audit Results ..... 9

*Appendix A - COMS Audit Data Forms for the Durag Model D-R 290*

*Appendix B - Audit Filter Certification Sheet(s)*

I. Introduction

Monitoring Solutions, Inc. was contracted to conduct an opacity performance audit on a Durag Model D-R 290 opacity system.

**Client:** Primary Energy  
**City, State:** E. Chicago, IN  
**Auditor:** Dan Bowles  
**Audit Date:** 6/10/2019

The performance testing consists of:

- 1 Zero and Span Check
- 2 Zero Compensation Check
- 3 Optical Alignment Check
- 4 Calibration Error Check
- 5 Annual Zero Alignment (When required)


All raw data, calculated data and final summary are presented. The results indicate compliance for all specifications. Testing was performed as per 40CFR60 Appendix F and 40CFR60 Appendix B, PS1 (Where Applicable).

Annual "Zero Alignment" check performed this quarter:

YES: \_\_\_\_\_ NO:  X  ERROR:  N/A

**Summary of Calibration Error Check**

Filter :	Low	Mid	High
Percent of Error:	0.60	0.80	0.23
	PASS	PASS	PASS

Reviewed by:  

Date:  7/17/19

Revision: March 2016



**PERFORMANCE AUDIT PROCEDURES FOR THE  
MONITORING SOLUTIONS, INC. OPACITY MONITOR**

**II. Monitoring Solutions, Inc. Durag Model D-R 290**

The instrument is manufactured by the Durag Corporation and distributed and serviced by Monitoring Solutions, Inc.

**A. COMS Description**

The Monitoring Solutions, Inc. D-R 290 opacity monitoring system consists of four major components: the Transmissometer, the terminal control box, the air-purging system and the remote control unit and data acquisition equipment. The Transmissometer component consists of an optical transmitter/receiver (transceiver) unit mounted on one side of a stack or duct and a retro reflector unit mounted on the opposite side. The transceiver unit contains the light source, the photodiode detector, and the associated electronics. The transceiver uses a single-lamp, single detector system to determine effluent opacity. A LED light source is modulated electronically at 2 KHz to eliminate any ambient light interference. The modulated beam is configured to alternately produce reference and measurement signals so that the effects of variations in the optical and electronic components of the COMS are minimized.

In a single display configuration, an AW unit is mounted in a blue housing next to the transceiver location. In a dual display configuration, an AZ unit is mounted in the blue housing next to the transceiver location and an AW is mounted in a remote location, typically, a control room. The AZ and the AW communicate via an RS 422 cable. The AZ unit provides an on stack readout and can be used as a diagnostic tool. In either configuration, only the AW provides the signals to the final recording device.

The air purging system serves a threefold purpose: 1) it provides an air window to keep exposed optical surfaces clean; 2) it protects the optical surfaces from condensation of stack gas moisture; and 3) it minimizes thermal conduction from the stack to the instrument. A standard installation has one air-purging system for each the transceiver and the retro reflector units.

The opacity monitor measures the amount of light transmitted through the effluent from the transceiver to the retro reflector and back again. The control unit uses the effluent transmittance to calculate the optical density of the effluent at the monitor location, or the "path" optical density. In order to provide stack exit opacity data, the path optical density must be corrected. The correction factor is expressed as the ratio of the stack exit inside diameter to the inside diameter of the stack at the Transmissometer location. This ratio is called the "stack correction factor" (SCF) by Monitoring Solutions, Inc. The following equations illustrate the relationship between this ratio, path optical density, and stack exit opacity.

Calculation of "Stack Correction Factor"

$$L_x / L_t = \text{stack correction factor}$$

---

where:  $L_x$  = stack exit inside diameter (in)

$L_t$  = the stack inside diameter (or the duct width) at the monitor location (in).

$$OP_x = 1 - \left(1 - \frac{Opacity}{100}\right)^{correction\ factor}$$

$OP_x$  = stack exit opacity (%)

**B. Performance Audit Procedures****1. Preliminary Data**

- a. Obtain the stack exit inside diameter (in feet) and the stack inside diameter at the monitor location (in feet). Record these values in Blanks 1 and 2 of the Monitoring Solutions, Inc. D-R 290 Performance Audit Data Sheet.

**Note:** Effluent handling system dimensions may be acquired from the following sources listed in descending order of reliability: 1) physical measurements, 2) construction drawings, 3) opacity monitor installation/certification documents, and 4) source personnel recollections.

- b. Calculate the stack correction factor (SCF) by dividing the value in Blank 1 by the value in Blank 2. Record the result in Blank 3.
- c. Record the source-cited Stack Correction Factor (SCF) in Blank 4.

**Note:** The stack correction factor (SCF) is preset by the manufacturer using information supplied by the source. The value recorded in Blank 4 should be the value source personnel agree should be set inside the monitor.

- d. Obtain the reference zero and span calibration values. Record these values in Blank 5 and Blank 6, respectively.

**Note:** The reference zero and span calibration values may not be the same as the values recorded during instrument installation and/or certification. The zero and span values recorded in Blank 5 and Blank 6 should be the reference values recorded during the most recent clear-path calibration of the CEMS.

## 2. Error Checks

The following steps describe the error codes for the Monitoring Solutions, Inc. D-R 290 remote control unit. The audit can continue with the error codes shown below being present, provided the source has been informed of the fault conditions. All other error codes must be corrected prior to audit.

Error code 100 = Transceiver blower fault

Error code 200 = Transceiver filter plugged

Error code 300 = Reflector blower fault

Error code 400 = Reflector filter plugged

**Note:** If a fault is active, an error code will be displayed on the stack mounted display and on the remote display. An explanation of the error codes can be found in the manual.

## 3. Instrument Range Check

- a. Check the COMS measurement range by pressing the MOD button (the LED on the button will light up) and using the PLUS button to cycle through the displays.
- b. Record the instrument range in Blank 11.

## 4. Reference Signal, Zero and Span Checks

- a. Initiate the calibration cycle by pressing the arrow and plus buttons simultaneously and holding for approximately 5 seconds.

**Note:** The opacity monitor will automatically cycle through the internal zero (zero point check), external zero (window check), span and stack taper ratio modes. Approximately 6 minutes for a complete cycle.

- b. Record the milliamp value shown for the internal zero (zero point check) displayed on the control panel display in Blank 12.

**Note:** The internal zero checks the instrument reference signal (Zero Point Check). Since the instrument provides a full scale output of 4 to 20 milliamps, a value of 4 milliamps displayed on the control unit display represents a zero condition. After 1 ½ minutes in the internal zero mode, the monitor will automatically switch to the external zero mode (Window Check).

- c. Record the milliamp value shown for the external zero (window check) displayed on the control panel in Blank 13. Also record the external zero value (in percent opacity) displayed on the opacity data recorder in Blank 14.

(Continued on next page)

**Note:** During the zero calibration check, the zero mirror is moved into the path of the measurement beam by a servomotor. The zero mechanism is designed to present the transceiver with a simulated clear-path condition. The daily zero check does not test the actual clear-path zero, nor does it provide a check of cross-stack parameters such as the optical alignment of the Transmissometer or drift in the reflectance of the retro reflector. The actual clear-path zero can only be checked during clear-stack or off-stack calibration of the CEMS. In addition to simulating the instrument clear-path zero, the zero mechanism allows the amount of dust on the transceiver optics (primary lens and zero mirror) to be quantified. After 1 ½ minutes in the external zero mode, the CEMS will automatically enter the span mode.

- d. Record in Blank 15 the span value (in milliamps) displayed on the control panel display. Also record the span value (in percent opacity) displayed on the data recorder in Blank 16. Go to the Transmissometer location.

**Note:** During the span calibration check, a servomotor moves an internal span filter into the path of the measurement beam while the zero mirror is in place. The span mechanism is designed to provide an indication of the upscale accuracy of the CEMS relative to the simulated clear-path zero. Note: The opacity monitor display will output its stack correction factor (SCF) for 1 ½ minutes when the span portion of the calibration cycle is completed. The CEMS automatically returns to the measurement mode when the SCF portion of the calibration cycle is complete.

#### **5. Reflector Dust Accumulation Check.**

- a. Record the effluent opacity prior to cleaning the retroreflector optics in Blank 17.
- b. Open the reflector housing, inspect and clean the retroreflector optics, and close the housing.
- c. Record the post-cleaning effluent opacity in Blank 18. Go to the transceiver location.

#### **6. Transceiver Dust Accumulation Check.**

- a. Record the pre-cleaning effluent opacity in Blank 19.
- b. Open the transceiver, clean the optics (primary window and zero mirror) and close the transceiver.
- c. Record the post-cleaning effluent opacity in Blank 20.

**7. Alignment Check**

- a. Determine the monitor alignment by looking through the alignment port of the side of the transceiver.
- b. Observe whether the image is centered in the cross hairs and record this information (YES or NO) in Blank 21.

**8. Zero Compensation Check**

The Durag 290 provides internal compensation for window contamination. This compensation value can be determined by performing the Window Check. This compensation cannot be disabled for testing. Remove internal compensation as follows: Clean the transceiver window and the zero mirror lens. Verify the window check value is at zero so no compensation is applied to the quarterly audit. Enter the Filter Audit Mode and verify the starting Durag opacity value is zero percent. **NOTE:** This process must be completed prior to the Calibration Error Check.

**9. Zero Alignment Error Check**

The Zero Alignment Error Check is performed one time each year. This check utilizes Durag's Clear Path Procedure. This procedure verifies the "measuring" zero point of the unit in a known clear path setup. The Transceiver and reflector are removed from their installation and set up on stands in a clean, dust free environment. The stands are set at the same distance as the installation location. Without performing any adjustments, the measuring zero is compared to the simulated zero - or - Window Check. The difference between the measuring zero and the simulated zero, must NOT exceed 2% opacity.

Verify the Zero Compensation Check has been performed. Since the zero compensation function cannot be disabled for the zero alignment check, the optics must be cleaned and a manual calibration performed. This will set the internal compensation value to 0.0%. This MUST be accomplished prior to the Zero Alignment Check.

Perform the following to document the "Zero Alignment Error":

- a) Remove the Transceiver & Reflector from its current installation and setup on stands at the exact distance as their original location.
- b) Perform the Zero Compensation Check and perform a manual calibration.
- c) Record the Durag's response to the clear path zero in % opacity without any adjustment.
- d) Activate the simulated zero (Window Check) and record the reading in % opacity without any adjustment.  
(continued on next page)

- e) The response difference between these two readings are recorded as the “zero alignment error”. The maximum allowable zero alignment error is 2%.
- f) Adjust the simulated zero (window check) to read the same value in % opacity as the clear path zero.

## 10. Calibration Error Check

The calibration error check is performed using three neutral density filters. Performing the calibration error check on-stack using the filters determines the linearity of the instrument response relative to the current clear-path zero setting. This calibration error check does not determine the accuracy of the actual instrument clear-path zero or the status of any cross-stack parameters. A true calibration check is performed by moving the on-stack components to a location with minimal ambient opacity, making sure that the proper path length and alignments are attained, and then placing the calibration filters in the measurement path.

- a. Put the monitor in Filter Audit mode.
- b. Wait approximately three minutes or until a clear “zero” value has been recorded and displayed on the data recorder.
- c. Record the audit filter serial numbers and opacity values in Blanks 22, 23, and 24.
- d. Remove the filters from their protective covers, inspect and if necessary, clean them.
- e. Insert the low range neutral density filter into the filter audit slot located in front of the heated lens.
- f. Wait approximately three minutes or until a clear value has been recorded and displayed on the data recorder.

**Note:** The audit data should be taken from a data recording/reporting device that presents instantaneous opacity (or opacity data with the shortest available integration period).

- g. Record the COMS response to the low range neutral density filter.
- h. Remove the low range filter and insert the mid range neutral density filter.
- i. Wait approximately three minutes and record the COMS response to the mid range neutral density filter.
- j. Remove the mid range filter and insert the high range filter.
- k. Wait approximately three minutes and record the COMS response to the high range neutral density filter.

(continued on next page)

- l. Remove the high range filter.
- m. \* If applicable, wait approximately three minutes, and record the zero value.
- n. Repeat steps (e) through (m) until a minimum of three opacity readings are obtained for each neutral density filter.
- o. If six-minute integrated opacity data is required, repeat steps (e) through (m) once more, changing the waiting periods to 13 minutes.
- p. Record the six-minute integrated data.

**Note:** In order to acquire valid six-minute averaged opacity data, each filter must remain in for at least two consecutive six-minute periods; the first period will be invalid because it was in progress when the filter was inserted. A waiting period of 13 minutes is recommended. You should have a “starting zero” reading and an “ending zero” reading.

- q. When the calibration error check is complete, return the monitor to measuring mode. Close the transceiver head and the weather cover, and return to the COMS control unit.

## 11. Test Conclusion

- a. Obtain a copy of the audit data from the data recorder.
- b. Transcribe the calibration error response from the data recorder to Blanks 25 through 50 of the audit form and complete the audit data calculations.

## C. Interpretation of Audit Results

This section is designed to help the auditor interpret the D-R 290 performance audit results.

### Error codes / fault analysis

Error codes are typically associated with parameters that the monitor manufacturer feels are critical to COMS function, and to the collection of valid opacity data. The parameters associated with each of the error codes are found in the manufacturer’s manual. With the exception of alarms that warn of elevated opacity levels (alarm or warning lamps), the error codes indicate that the COMS is not functioning properly. An error or failure indication will be represented by a “YES” in Blanks 7 - 10.

(continued on next page)

### Stack Exit Correlation Error Check

The path length correction error in Blank 51 should be within +2%. This error exponentially affects the opacity readings, resulting in over - or - underestimation of the stack exit opacity. The most common error in computing the optical path length correction factor is the use of the flange-to-flange distance in place of the stack/duct inside diameter at the monitor location. This error will result in underestimation of the stack exit opacity and can be identified by comparing the monitor optical path length to the flange-to-flange distance; the flange-to-flange distance should be greater by approximately two to four feet

### Control Panel Meter Error (Optional)

The accuracy of the control panel meter (AW) is important at sources using the meter during monitor adjustment and calibration. The accuracy of the control panel meter (Blank 52 and Blank 54) is determined by comparing the zero and span reference values to the panel meter output recorded during the COMS calibration check.

**Note:** Some installations utilize a different “Instrument Range Setting” than the normal 100% range. The panel meter span error must be corrected for the different range in order to provide an accurate error result. Use the following equation to calculate the span error corrected for “Instrument Range” (Blank 11):

$$\text{Panel Meter span error in \% opacity} = \\ (((\text{Blank 15} - 4) \div 16) \times \text{Blank 11}) - \text{Blank 6}$$

### Zero and Span Checks

The D-R 290 internal zero or “zero point check” (Blank 12) should be set to indicate 0% opacity (equivalent to 3.7 - 4.3 mA). An external zero error or “window check” (Blank 53) greater than 4% opacity is usually due to excessive dust accumulation on the optical surfaces, electronic drift or an electronic/mechanical offset of the data recorder. Excessive dust on the optical surfaces sufficient to cause a significant zero error would be indicated by the difference in the internal and external zero values and/or window alarm. Instrument span error (Blank 55) may be caused by the same problem(s) that cause zero errors and may be identified in a similar fashion.

If the zero and span errors are due to a data recorder offset, both errors will be in the same direction and will be of the same magnitude

(continued on next page)



The external zero displayed on the control unit panel meter (AW) also indicates the level of dust accumulation on the zero retroreflector and transceiver measurement window. The difference between the internal and external zero responses should equal the amount of dust found on the transceiver optics (Blank 57). To convert the zero responses to a value that represents lens dusting in percent opacity, use the following equation.

$$\text{Meter response in \% opacity} = 6.25 [(\text{Blank 13}) - (\text{Blank 12})]$$

### **Optical Alignment Check**

When the transceiver and retroreflector are misaligned, a portion of the measurement beam that should be returned to the measurement detector is misdirected, resulting in a positive bias in the data reported by the COMS. One of the most common causes of misalignment is vibration which may cause the on-stack components to shift slightly on the instrument mounting flanges. Another common cause of misalignment is thermal expansion and contraction of the structure on which the transmissometer is mounted. If the COMS is being audited while the unit is off-line (cold stack), the results of the alignment analysis may not be representative of the alignment of the instrument when the stack or duct is at normal operating temperature. When checking the alignment, the reflected light beam should be centered.

### **Zero Compensation Check**

The Zero Compensation Check should be performed and documented as such in (Blank 21a).

### **Annual Zero Alignment Error Check**

The Zero Alignment Error Check is performed once each year. It verifies that the energy output from the simulated zero device (Window Check) is within 2% of the Clear Path reading. The values required for this check are documented in (Blank 21b). If the difference between the Clear Path Value and the Simulated Zero (Window Check) value differ by more than 2%, then the COMS unit is considered Out Of Control. If the difference is 2% or less, then the Window Check Value is adjusted to match the Clear Path value.

### **Optical Surface Dust Accumulation Check**

The results of the dust accumulation check (Blank 58) should not exceed 4%. A dust accumulation value of more than 4% opacity indicates that the air flow of the purge system and/or the cleaning frequency of the optical surfaces are inadequate. When determining the optical surface dust accumulation, the auditor should note whether the effluent opacity is relatively stable (within +2% opacity) before and after cleaning the optical surfaces. If the effluent opacity is fluctuating by more than +2%, the dust accumulation analysis should be omitted.

(continued on next page)

**Calibration Error**

Calibration error results (Blanks 68, 69 and 70) in excess of +3% are indicative of a non-linear or miss calibrated instrument. However, the absolute calibration accuracy of the monitor can be determined only when the instrument clear-path zero value is known. If the zero and span data are out-of-specification, the calibration error data will often be biased in the direction of the zero and span errors. Even if the zero and span data indicate that the COMS is calibrated properly, the monitor may still be inaccurate due to error in the clear-path zero adjustment. The optimum calibration procedure involves using neutral density filters during clear-stack or off-stack COMS calibration. This procedure would establish both the absolute calibration accuracy and linearity of the COMS. If this procedure is impractical, and it is reasonable to assume that the clear-path zero is set correctly, the monitor's calibration can be set using either the neutral density filters or the internal zero and span values.

**Appendix A**  
**COMS Audit Data Forms for the Durag Model D-R 290**

AUDIT DATA SHEET  
MONITORING SOLUTIONS DURAG D-R 290 COMS

6/10/2019                      Primary Energy                      E. Chicago, IN                      Stack 201                      Page 1 of 5

---

Company: <u>Primary Energy</u>	City, ST: <u>E. Chicago, IN</u>
Unit ID: <u>Stack 201</u>	
Auditor: <u>Dan Bowles</u>	Representing: <u>Monitoring Solutions</u>
Attendees: <u>N/A</u>	Representing: _____
Transceiver serial number: <u>1248342</u>	
Reflector serial number: <u>1248145</u>	
Remote serial number: <u>1248283</u>	COMS Flange to Flange distance (Feet / Inches): <u>226.125"</u>
Date: <u>6/10/2019</u>	

---

Preliminary Data

1 Inside diameter at Stack Exit = Lx	<u>216.000</u> inches
2 Inside diameter at the Transmissometer location = Lt	<u>216.000</u> inches
3 Calculated Stack Correction Factor (SCF) = Lx/Lt	<u>1.000</u>
4 Source-cited Stack Correction Factor (SCF)	<u>1.000</u>
5 Source-cited zero automatic calibration value (% opacity)	<u>0.00</u> %
6 Source-cited span automatic calibration value (% opacity)	<u>40.00</u> %

---

[START AT CONTROL UNIT / DATA RECORDER LOCATION]

(If required) [INSPECT DATA RECORDING SYSTEM AND MARK WITH "OPACITY AUDIT,"  
AUDITOR'S NAME, AFFILIATION, DATE, SOURCE, PROCESS UNIT/STACK  
IDENTIFICATION, AND THE TIME OF DAY.]

Error codes / faults

	<b>YES - or - NO</b>
7 Blower [Loss of purge air from blower - Error 100, 300]	NO
8 Filter [Air filter restriction - Error 200, 400]	NO
9 Window [Excessive dirt on transceiver window - Error 001]	NO
10 Fault [Additional CEMS fault has occurred. Note fault code on Opacity display and consult the instrument manual.]	NO

---

Instrument Range Check

11 Instrument range setting	<u>100</u> %
-----------------------------	--------------

---

Zero Check

12 Opacity Display - Internal zero value in "milliamps" (Zero Point Check) [Wait for 1½ minutes for automatic change to external zero mode.]	<u>4.00</u> mA
13 Opacity Display - Zero calibration value in "milliamps" (Window Check)	<u>4.00</u> mA
14 Opacity data recorder zero calibration value in "% Op" (Window Check) [Wait 1½ minutes for automatic change to span mode.]	<u>0.00</u> mA

Span Check

15 Opacity Display - Span calibration value in "milliamps" (Span Check)	<u>10.40</u> mA
16 Opacity data recorder span calibration value in "% Op" (Span Check) [Go to reflector location.]	<u>40.00</u> %

AUDIT DATA SHEET  
MONITORING SOLUTIONS DURAG D-R 290 COMS

6/10/2019      Primary Energy      E. Chicago, IN      Stack 201      Page 2 of 5

---

Reflector Dust Accumulation Check

17 Pre-cleaning effluent opacity (% Op)      0.0 %  
[Inspect and clean optical surface.]

18 Post-cleaning effluent opacity (% Op)      0.0 %  
[Go to transceiver location.]

Transceiver Dust Accumulation Check and Zero Compensation Check

19 Pre-cleaning effluent opacity (% Op)      0.0 %  
[Inspect and clean optical window and zero mirror.]

20 Post-cleaning effluent opacity (% Op)      0.0 %

---

Optical Alignment Check

[LOOK THROUGH ALIGNMENT SIGHT AND DETERMINE IF BEAM IMAGE IS CENTERED.]

21 Is the image centered?

YES - or - NO
YES

---

Zero Compensation Check

21a Did you comply with the Zero Compensation Check?

YES - or - NO
YES

Annual Zero Alignment Error Check

21b Did you comply with the Annual Zero Alignment Error Check?

YES - or - NO
NO

Zero Alignment Error Check results (if applicable):

Clear Path Value % =

N/A
-----

Window Check Value % =

N/A
-----

Zero Alignment

Error % =

N/A
-----

[Record audit filter data.]

Filter	Serial NO.	% Opacity	SCF%
22 LOW	<u>YC61</u>	<u>18.20</u>	<u>18.20 %</u>
23 MID	<u>YC62</u>	<u>27.30</u>	<u>27.30 %</u>
24 HIGH	<u>YC63</u>	<u>46.40</u>	<u>46.40 %</u>

[Remove the audit filters from the protective covers, inspect, and clean each filter]

[Set the unit up to display the initial zero. Wait 3 minutes to allow opacity data recorder to record initial zero]

[Insert a filter, wait approximately 3 minutes, and record the opacity value reported by the opacity data recorder. Repeat the process 5 times for each filter.]

[Read and transcribe final calibration error data from the opacity data recorder on the next page]



AUDIT DATA SHEET  
MONITORING SOLUTIONS DURAG D-R 290 COMS

6/10/2019      Primary Energy      E. Chicago, IN      Stack 201      Page 4 of 5

---

**Span Error (% Op.):**

	10.40	100	40.00		
54 Opacity Display	(((Blank 15 - 4.0) ÷ 16) × Blank 11) - Blank 6			=	<u>0.00 %</u>

	40	40		
55 Opacity Data Recorder	Blank 16	- Blank 6	=	<u>0.00</u>

**Optical Surface Dust Accumulation (% OP):**

	0	0.0		
56 Retroreflector	Blank 17	- Blank 18	=	<u>0.00 %</u>

	0	0		
57 Transceiver	Blank 19	- Blank 20	=	<u>0.00 %</u>

	0	0		
58 Total	Blank 56	+ Blank 57	=	<u>0.00 %</u>

**Optical Path Length Correction (SCF)**

**Audit Filters Corrected for Path Length:**

59 LOW:	18.20	1.000			
	$1 - (1 - (\frac{Blank\ 22}{100})^{Blank\ 4}) \times 100$			=	<u>18.20 %</u>

60 MID:	27.30	1.000			
	$1 - (1 - (\frac{Blank\ 23}{100})^{Blank\ 4}) \times 100$			=	<u>27.30 %</u>

61 HIGH	46.40	1.000			
	$1 - (1 - (\frac{Blank\ 24}{100})^{Blank\ 4}) \times 100$			=	<u>46.40 %</u>

---

AUDIT DATA SHEET  
MONITORING SOLUTIONS DURAG D-R 290 COMS

6/10/2019

Primary Energy

E. Chicago, IN

Stack 201

Page 5 of 5

Auditor: Dan Bowles

Date: 06/10/19

Source: Primary Energy

Unit: Stack 201

PARAMETER		Blank No.	Audit Results	Specifications
<b>Error Codes/Faults</b>				
Blower failure		7	NO	NO
Filter Blockage		8	NO	NO
Window		9	NO	NO
Fault		10	NO	NO
<b>SCF Correlation Error</b>		51	0.00	+/- 2% Op
<b>Internal Zero Error</b>	Display	52	0.00	+/- 4% Op
	Data	53	0.00	+/- 4% Op
<b>Internal Span Error</b>	Display	54	0.00	+/- 4% Op
	Data	55	0.00	+/- 4% Op
<b>Optical Alignment Analysis</b>		21	YES	YES = Centered
<b>Zero Compensation Check</b>		21a	YES	YES = Complied With
<b>Zero Alignment Error</b>		21b	N/A	≤ 2% Op
<b>Optical Surface Dust Accumulation</b>				
Retroreflector		56	0.00	≤ 2% Op
Transceiver		57	0.00	≤ 2% Op
Total		58	0.00	≤ 4% Op
<b>Calibration Error Analysis</b>				
Arithmetic Mean Difference				
LOW		62	0.16	
		71a	-0.10	
MID		63	0.30	
		72a	0.10	
HIGH		64	-0.16	
		73a	-0.10	
Confidence Coefficient				
		65	0.44	
		66	0.50	
		67	0.07	
Calibration Error				
		68	0.60	≤ 3% Op
		69	0.80	≤ 3% Op
		70	0.23	≤ 3% Op

Revision: March, 2016



## OPACITY LOW FILTER AUDIT

### Accuracy Determination

Primary Energy

E. Chicago, IN

Stack 201

6/10/2019

LOW FILTER RUN	Opacity Output from Recording Device	Audit Filter Value Corrected for Path Length (SCF)	(FILTER-MONITOR) Difference	Difference <sup>2</sup>
		<b>RM</b>	<b>(X<sub>i</sub>)</b>	<b>X<sub>i</sub><sup>2</sup></b>
1	18.70	18.20	0.50	0.2500
2	18.80	18.20	0.60	0.3600
3	18.10	18.20	-0.10	0.0100
4	18.10	18.20	-0.10	0.0100
5	18.10	18.20	-0.10	0.0100

n = 5

t(0.975) = 2.776

Mean Ref. Method Value	<b>18.2000</b> <i>RM</i>
Sum of Differences	<b>0.8000</b> <i>Xi</i>
Arithmetic Mean Difference	<b>0.1600</b> <i>Xi ave</i>
Sum of Differences Squared	<b>0.6400</b> <i>Xi<sup>2</sup></i>
Standard Deviation	<b>0.3578</b> <i>sd</i>
2.5% Error Conf. Coef	<b>0.4442</b> <i>CC</i>
Calibration Error	<b>0.6042</b> <i>percent</i>

## OPACITY MID FILTER AUDIT

### Accuracy Determination

Primary Energy

E. Chicago, IN

Stack 201

6/10/2019

MID FILTER RUN	Opacity Output from Recording Device	Audit Filter Value Corrected for Path Length (SCF)	(FILTER-MONITOR) Difference	Difference <sup>2</sup>
		RM	(X <sub>i</sub> )	X <sub>i</sub> <sup>2</sup>
1	28.30	27.30	1.00	1.0000
2	27.60	27.30	0.30	0.0900
3	27.40	27.30	0.10	0.0100
4	27.30	27.30	0.00	0.0000
5	27.40	27.30	0.10	0.0100

n = 5

t(0.975) = 2.776

Mean Ref. Method Value	<b>27.3000</b> <i>RM</i>
Sum of Differences	<b>1.5000</b> <i>Xi</i>
Arithmetic Mean Difference	<b>0.3000</b> <i>Xi ave</i>
Sum of Differences Squared	<b>1.1100</b> <i>Xi<sup>2</sup></i>
Standard Deviation	<b>0.4062</b> <i>sd</i>
2.5% Error Conf. Coef	<b>0.5043</b> <i>CC</i>
Calibration Error	<b>0.8043</b> <i>percent</i>

## OPACITY HIGH FILTER AUDIT

### Accuracy Determination

Primary Energy

E. Chicago, IN

Stack 201

6/10/2019

HIGH FILTER RUN	Opacity Output from Recording Device	Audit Filter Value Corrected for Path Length (SCF)	(FILTER-MONITOR) Difference	Difference <sup>2</sup>
		RM	(X <sub>i</sub> )	X <sub>i</sub> <sup>2</sup>
1	46.30	46.40	-0.10	0.0100
2	46.30	46.40	-0.10	0.0100
3	46.20	46.40	-0.20	0.0400
4	46.20	46.40	-0.20	0.0400
5	46.20	46.40	-0.20	0.0400

n = 5

t(0.975) = 2.776

Mean Ref. Method Value	<b>46.4000</b> <i>RM</i>
Sum of Differences	<b>-0.8000</b> <i>Xi</i>
Arithmetic Mean Difference	<b>-0.1600</b> <i>Xi ave</i>
Sum of Differences Squared	<b>0.1400</b> <i>Xi<sup>2</sup></i>
Standard Deviation	<b>0.0548</b> <i>sd</i>
2.5% Error Conf.Coef	<b>0.0680</b> <i>CC</i>
Calibration Error	<b>0.2280</b> <i>percent</i>

**06/10/2019 OPACITY, %**

11:39

11:39:00	0.0	MOS
11:39:02	0.0	MOS
11:39:04	0.0	MOS
11:39:06	0.0	MOS
11:39:08	0.0	MOS
11:39:10	0.0	MOS
11:39:12	0.0	MOS
11:39:14	2.0	MOS
11:39:16	6.7	MOS
11:39:18	11.4	MOS
11:39:20	16.1	MOS
11:39:22	18.7	MOS
11:39:24	18.7	MOS
11:39:26	18.7	MOS
11:39:28	18.7	MOS
11:39:30	18.7	MOS
11:39:32	18.7	MOS
11:39:34	18.7	MOS
11:39:36	18.7	MOS
11:39:38	18.7	MOS
11:39:40	18.7	MOS
11:39:42	18.7	MOS
11:39:44	18.7	MOS
11:39:46	16.1	MOS
11:39:48	18.4	MOS
11:39:50	20.8	MOS
11:39:52	23.2	MOS
11:39:54	28.3	MOS
11:39:56	28.3	MOS
11:39:59	28.3	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**06/10/2019 OPACITY, %**

11:40

11:40:01	28.3	MOS
11:40:03	28.3	MOS
11:40:05	28.3	MOS
11:40:07	28.3	MOS
11:40:09	28.3	MOS
11:40:11	28.3	MOS
11:40:13	28.3	MOS
11:40:15	28.3	MOS
11:40:17	28.3	MOS
11:40:19	28.3	MOS
11:40:21	28.3	MOS
11:40:23	28.3	MOS
11:40:25	24.8	MOS
11:40:27	28.8	MOS
11:40:29	33.3	MOS
11:40:31	37.7	MOS
11:40:33	45.7	MOS
11:40:35	46.2	MOS
11:40:37	46.2	MOS
11:40:39	46.2	MOS
11:40:41	46.3	MOS
11:40:43	46.3	MOS
11:40:45	46.2	MOS
11:40:47	46.3	MOS
11:40:49	46.3	MOS
11:40:51	46.3	MOS
11:40:53	46.3	MOS
11:40:55	46.3	MOS
11:40:57	46.3	MOS
11:40:59	46.3	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**06/10/2019 OPACITY, %**

11:41

11:41:01	46.3	MOS
11:41:03	46.3	MOS
11:41:05	37.9	MOS
11:41:07	27.5	MOS
11:41:09	17.6	MOS
11:41:11	6.1	MOS
11:41:13	4.7	MOS
11:41:15	9.4	MOS
11:41:17	14.0	MOS
11:41:19	18.7	MOS
11:41:21	18.8	MOS
11:41:23	18.7	MOS
11:41:25	18.7	MOS
11:41:27	18.7	MOS
11:41:29	18.7	MOS
11:41:31	18.7	MOS
11:41:33	18.7	MOS
11:41:35	18.8	MOS
11:41:37	18.8	MOS
11:41:39	18.8	MOS
11:41:41	18.8	MOS
11:41:43	18.1	MOS
11:41:45	17.4	MOS
11:41:47	20.2	MOS
11:41:49	22.3	MOS
11:41:51	25.6	MOS
11:41:53	27.4	MOS
11:41:55	27.4	MOS
11:41:57	27.4	MOS
11:41:59	27.4	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**06/10/2019 OPACITY, %**

11:42

11:42:01	27.4	MOS
11:42:03	27.4	MOS
11:42:05	27.4	MOS
11:42:07	27.4	MOS
11:42:09	27.4	MOS
11:42:11	27.4	MOS
11:42:13	27.4	MOS
11:42:15	27.2	MOS
11:42:17	22.9	MOS
11:42:19	27.6	MOS
11:42:21	32.3	MOS
11:42:23	37.0	MOS
11:42:25	46.2	MOS
11:42:27	46.2	MOS
11:42:29	46.3	MOS
11:42:31	46.3	MOS
11:42:33	46.2	MOS
11:42:35	46.3	MOS
11:42:37	46.3	MOS
11:42:39	46.3	MOS
11:42:42	46.3	MOS
11:42:44	46.3	MOS
11:42:46	46.3	MOS
11:42:48	46.3	MOS
11:42:50	46.3	MOS
11:42:52	45.8	MOS
11:42:54	36.4	MOS
11:42:56	29.4	MOS
11:42:58	20.6	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**06/10/2019 OPACITY, %**

11:43

11:43:00	16.4	MOS
11:43:02	18.1	MOS
11:43:04	18.1	MOS
11:43:06	18.1	MOS
11:43:08	18.1	MOS
11:43:10	18.1	MOS
11:43:12	18.1	MOS
11:43:14	18.1	MOS
11:43:16	18.1	MOS
11:43:18	18.1	MOS
11:43:20	18.1	MOS
11:43:22	18.1	MOS
11:43:24	18.1	MOS
11:43:26	16.4	MOS
11:43:28	15.8	MOS
11:43:30	18.1	MOS
11:43:32	20.4	MOS
11:43:34	24.5	MOS
11:43:36	27.4	MOS
11:43:38	27.4	MOS
11:43:40	27.4	MOS
11:43:42	27.3	MOS
11:43:44	27.4	MOS
11:43:46	27.4	MOS
11:43:48	27.4	MOS
11:43:50	27.4	MOS
11:43:52	27.4	MOS
11:43:54	27.4	MOS
11:43:56	27.4	MOS
11:43:58	27.4	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE



**06/10/2019 OPACITY, %**

11:44

11:44:00	23.4	MOS
11:44:02	25.2	MOS
11:44:04	29.9	MOS
11:44:06	35.8	MOS
11:44:08	46.2	MOS
11:44:10	46.2	MOS
11:44:12	46.2	MOS
11:44:14	46.2	MOS
11:44:16	46.2	MOS
11:44:18	46.2	MOS
11:44:20	46.2	MOS
11:44:22	46.2	MOS
11:44:24	46.2	MOS
11:44:26	46.3	MOS
11:44:28	46.3	MOS
11:44:30	46.3	MOS
11:44:32	46.3	MOS
11:44:34	46.2	MOS
11:44:36	46.2	MOS
11:44:38	40.5	MOS
11:44:40	33.4	MOS
11:44:42	26.4	MOS
11:44:44	19.4	MOS
11:44:46	18.1	MOS
11:44:48	18.1	MOS
11:44:50	18.1	MOS
11:44:52	18.1	MOS
11:44:54	18.1	MOS
11:44:56	18.1	MOS
11:44:58	18.1	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**06/10/2019 OPACITY, %**

11:45

11:45:00	18.1	MOS
11:45:02	18.1	MOS
11:45:04	18.1	MOS
11:45:06	18.1	MOS
11:45:08	18.1	MOS
11:45:10	18.1	MOS
11:45:12	14.7	MOS
11:45:14	17.5	MOS
11:45:16	19.7	MOS
11:45:18	22.1	MOS
11:45:20	27.3	MOS
11:45:23	27.3	MOS
11:45:25	27.3	MOS
11:45:27	27.3	MOS
11:45:29	27.3	MOS
11:45:31	27.3	MOS
11:45:33	27.3	MOS
11:45:35	27.3	MOS
11:45:37	27.3	MOS
11:45:39	27.3	MOS
11:45:41	27.3	MOS
11:45:43	27.3	MOS
11:45:45	25.7	MOS
11:45:47	18.9	MOS
11:45:49	23.4	MOS
11:45:51	28.1	MOS
11:45:53	34.4	MOS
11:45:55	46.0	MOS
11:45:57	46.2	MOS
11:45:59	46.2	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**06/10/2019 OPACITY, %**

11:46		
11:46:01	46.2	MOS
11:46:03	46.2	MOS
11:46:05	46.2	MOS
11:46:07	46.2	MOS
11:46:09	46.2	MOS
11:46:11	46.2	MOS
11:46:13	36.6	MOS
11:46:15	32.8	MOS
11:46:17	28.2	MOS
11:46:19	23.5	MOS
11:46:21	27.3	MOS
11:46:23	27.4	MOS
11:46:25	27.4	MOS
11:46:27	27.4	MOS
11:46:29	27.4	MOS
11:46:31	27.3	MOS
11:46:33	27.3	MOS
11:46:35	27.3	MOS
11:46:37	27.4	MOS
11:46:39	27.4	MOS
11:46:41	27.4	MOS
11:46:43	27.4	MOS
11:46:45	24.0	MOS
11:46:47	28.7	MOS
11:46:49	33.4	MOS
11:46:51	38.1	MOS
11:46:53	46.2	MOS
11:46:55	46.2	MOS
11:46:57	46.2	MOS
11:46:59	46.2	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**06/10/2019 OPACITY, %**

11:47

11:47:01	46.2	MOS
11:47:03	46.2	MOS
11:47:05	46.2	MOS
11:47:07	46.2	MOS
11:47:09	46.2	MOS
11:47:11	46.2	MOS
11:47:13	46.3	MOS
11:47:15	46.3	MOS
11:47:17	46.3	MOS
11:47:19	35.4	MOS
11:47:21	29.3	MOS
11:47:23	23.1	MOS
11:47:25	16.1	MOS
11:47:27	18.1	MOS
11:47:29	18.1	MOS
11:47:31	18.1	MOS
11:47:33	18.1	MOS
11:47:35	18.1	MOS
11:47:37	18.1	MOS
11:47:39	18.1	MOS
11:47:41	18.1	MOS
11:47:43	18.1	MOS
11:47:45	18.1	MOS
11:47:47	18.1	MOS
11:47:49	18.1	MOS
11:47:51	18.1	MOS
11:47:53	17.5	MOS
11:47:55	16.3	MOS
11:47:57	18.4	MOS
11:47:59	21.0	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**06/10/2019 OPACITY, %**

11:48

11:48:01	23.8	MOS
11:48:03	27.4	MOS
11:48:06	27.4	MOS
11:48:08	27.4	MOS
11:48:10	27.4	MOS
11:48:12	27.4	MOS
11:48:14	27.4	MOS
11:48:16	27.4	MOS
11:48:18	27.4	MOS
11:48:20	27.4	MOS
11:48:22	27.4	MOS
11:48:24	27.4	MOS
11:48:26	27.4	MOS
11:48:28	24.1	MOS
11:48:30	27.6	MOS
11:48:32	32.1	MOS
11:48:34	36.8	MOS
11:48:36	43.2	MOS
11:48:38	46.2	MOS
11:48:40	46.2	MOS
11:48:42	46.2	MOS
11:48:44	46.2	MOS
11:48:46	46.2	MOS
11:48:48	46.2	MOS
11:48:50	46.2	MOS
11:48:52	46.2	MOS
11:48:54	37.0	MOS
11:48:56	28.2	MOS
11:48:58	21.2	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**06/10/2019 OPACITY, %**

11:49

11:49:00	16.8	MOS
11:49:02	18.1	MOS
11:49:04	18.1	MOS
11:49:06	18.1	MOS
11:49:08	18.1	MOS
11:49:10	18.1	MOS
11:49:12	19.8	MOS
11:49:14	22.1	MOS
11:49:16	24.5	MOS
11:49:18	26.8	MOS
11:49:20	27.4	MOS
11:49:22	22.3	MOS
11:49:24	15.4	MOS
11:49:26	8.6	MOS
11:49:28	10.3	MOS
11:49:30	20.1	MOS
11:49:32	31.7	MOS
11:49:34	43.3	MOS
11:49:36	46.2	MOS
11:49:38	46.2	MOS
11:49:40	46.3	MOS
11:49:42	40.1	MOS
11:49:44	28.5	MOS
11:49:46	16.9	MOS
11:49:48	5.3	MOS
11:49:50	0.0	MOS
11:49:52	0.0	MOS
11:49:54	0.0	MOS
11:49:56	0.0	MOS
11:49:58	0.0	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**06/10/2019 OPACITY, %**

11:50

11:50:00	0.0	MOS
11:50:02	0.0	MOS
11:50:04	0.0	MOS
11:50:06	0.0	MOS
11:50:08	0.0	MOS
11:50:10	0.0	MOS
11:50:12	0.0	MOS
11:50:14	0.0	MOS
11:50:16	0.0	MOS
11:50:18	0.0	MOS
11:50:20	0.0	MOS
11:50:22	0.0	MOS
11:50:24	0.0	MOS
11:50:26	0.0	MOS
11:50:28	0.0	MOS
11:50:30	0.0	MOS
11:50:32	0.0	MOS
11:50:34	0.0	MOS
11:50:36	0.0	MOS
11:50:38	0.0	MOS
11:50:40	0.0	MOS
11:50:42	0.0	MOS
11:50:44	0.0	MOS
11:50:47	0.0	MOS
11:50:49	0.0	MOS
11:50:51	0.0	MOS
11:50:53	0.0	MOS
11:50:55	0.0	MOS
11:50:57	0.0	MOS
11:50:59	0.0	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**OPACITY FILTER AUDIT**

**\* 6-minute Averages \***

**Accuracy Determination**

Primary Energy

E. Chicago, IN

Stack 201

6/10/2019

<b>6 Minute Averages</b>	<b>Opacity Output from Recording Device</b>	<b>Audit Filter Value Corrected for Path Length (SCF)</b>	<b>(FILTER-MONITOR) Difference</b>	<b>Opacity Error</b>
		RM	(Xi)	
<b>ZERO</b>	0.00	0.00	0.00	<b>0.00</b>
<b>LOW</b>	18.10	18.20	-0.10	<b>0.10</b>
<b>MID</b>	27.40	27.30	0.10	<b>0.10</b>
<b>HIGH</b>	46.30	46.40	-0.10	<b>0.10</b>
<b>ZERO</b>	0.00	0.00	0.00	<b>0.00</b>



# Opacity Report

East Chicago, IN

06/10/2019 - 06/10/2019

06/10/2019

STACK 201

Hour	Opac, % Minutes 0 - 5	Opac, % Minutes 6 - 11	Opac, % Minutes 12 - 17	Opac, % Minutes 18 - 23	Opac, % Minutes 24 - 29	Opac, % Minutes 30 - 35	Opac, % Minutes 36 - 41	Opac, % Minutes 42 - 47	Opac, % Minutes 48 - 53	Opac, % Minutes 54 - 59
0	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.8 SVC	1.8 SVC
1	1.9 SVC	1.9 SVC	1.9 SVC	2.1 SVC	2.0 SVC	2.0 SVC	2.0 SVC	2.0 SVC	1.8 SVC	1.8 SVC
2	1.6 SVC	1.6 SVC	1.7 SVC	1.7 SVC	1.8 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	2.0 SVC
3	2.0 SVC	2.1 SVC	2.0 SVC	1.9 SVC	2.0 SVC	2.0 SVC	2.0 SVC	2.0 SVC	1.9 SVC	1.9 SVC
4	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	2.0 NSA	1.9 SVC
5	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC
6	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	2.0 SVC	2.0 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC
7	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	1.9 SVC	2.0 SVC
8	1.9 SVC	2.0 SVC	1.9 SVC	1.9 SVC	1.9 SVC	2.0 SVC	2.0 SVC	2.0 SVC	2.0 SVC	2.1 SVC
9	2.0 SVC	2.0 SVC	2.0 SVC	2.0 SVC	2.0 SVC	2.0 SVC	2.0 SVC	1.9 SVC	1.9 SVC	1.9 SVC
10	1.9 SVC	1.9 SVC	1.9 SVC	2.0 SVC	1.9 SVC	1.8 SVC	1.9 SVC	1.9 SVC	1.9 SVC	2.0 SVC
11	2.1 SVC	2.1 SVC	2.1 SVC	2.0 SVC	2.0 NSA	1.5 MOS	12.0 MOS	30.2 MOS	9.0 MOS	0.0 MOS
12	5.4 MOS	18.1 MOS	18.1 MOS	26.3 MOS	27.4 MOS	42.5 MOS	46.3 MOS	26.7 MOS	0.0 MOS	0.9 MOS
13	2.1 MOS	2.1 MOS	2.1 SVC	2.1 SVC	2.1 SVC	2.1 SVC	2.1 SVC	2.1 SVC	2.1 SVC	2.1 SVC
14	2.1 SVC									

Status Code Definitions

MOS = MONITOR OUT OF SERVICE      NSA = NO SAMPLE AVAILABLE      SVC = MONITOR IN SERVICE


The average opacity period average for the day was 1.9 % for 122 periods of valid data.

The Fan was in operation for 141 periods

The maximum opacity period average for the day was 2.1 %

There were 19 periods of invalid data

**APPENDIX B**  
**AUDIT FILTER CERTIFICATION SHEETS**



# Monitoring Solutions

Leaders in Environmental Monitoring Systems & Services

4440 S. High School Rd., Suite D, Indianapolis, Indiana 46241 Tel: 317.856.9400

## REPORT OF CERTIFICATION OF NEUTRAL DENSITY AUDIT FILTERS

Date of Filter Certification: **March 02, 2019**

Date of Filter Expiration: **August 31, 2019**

Filter Set - K

Audit Device / Filter Slot Angle of Incidence

10 Degrees

Path-Length Correction

1.000 (Straight Stack)

**Table 1: Individual Filter Certification Data**

Serial Number	Opacity Value (%)	Transmittance (%)	Previous Opacity (%)	Change in Opacity (%)
YC60	8.5	91.5	8.5	0.0
YC61	18.2	81.8	18.3	0.1
YC62	27.3	72.7	27.3	0.0
YC63	46.4	53.6	46.3	0.1
YG00	57.8	42.2	57.8	0.0
YG02	86.4	13.6	86.5	0.1

Laboratory-Based Transmissometer  
Operator

\*See second page for Instrument Information and Details of Certification\*

# ATTACHMENT 2

Second Quarter 2019 Deviation and  
Compliance Monitoring Report



# Cokenergy LLC

3210 Watling Street MC 2-991  
East Chicago, IN 46312

October 16, 2019

Via UPS

Indiana Department of Environmental Management  
Compliance and Enforcement Branch  
Office of Air Quality  
100 N. Senate Avenue  
Mail Code 61-50, IGCN 1003  
Indianapolis, IN 46204 - 2251

RE: Cokenergy, LLC Quarterly Report – Third Quarter 2019  
Part 70 Permit No. T089-36965-00383

To Whom It May Concern:

In accordance with sections C.18 and D.1.14 of the subject permit, 326 IAC 3-5-5 and 326 IAC 3-5-7, we have enclosed the third quarter 2019 reports for the Cokenergy, LLC facility. This report includes:

- Part 70 Quarterly Report – Certification
- Part 70 Quarterly Deviation and Compliance Report
- CEMS Excess Emissions Report
- CEMS Downtime Report
- COMS Third Quarter 2019 Opacity Monitor Audit
- CEMS Third Quarter Cylinder Gas Audit

If you have any questions concerning this data, please call Luke Ford at (219) 397-4626.

Sincerely,

Seth Acheson  
General Manager  
Cokenergy LLC

Enclosure

cc: Luke Ford (scan via email)  
Cliff Yukawa IDEM (scan via email)

File: X:\615.4

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR MANAGEMENT  
COMPLIANCE AND ENFORCEMENT SECTION  
PART 70 OPERATING PERMIT  
CERTIFICATION**

Source Name: Cokenergy LLC

Source Address: 3210 Watling Street, MC 2-991, East Chicago, Indiana 46312-1610

Part 70 Permit No. : T089-36965-00383

**This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.**

Please check what document is being certified:

- Annual Compliance Certification Letter
- Test Result (specify) 3<sup>rd</sup> Quarter 2019 COMS Performance Audit and Cylinder Gas Audit
- Report (specify) 3<sup>rd</sup> Quarter 2019 Deviation and Compliance Monitoring Report
- Notification (specify) \_\_\_\_\_
- Affidavit (specify) \_\_\_\_\_
- Other (specify) \_\_\_\_\_

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature: 

Printed Name: Seth Acheson

Title/Position: General Manager, Cokenergy, LLC

Phone: (219) 397-4521

Date: October 16, 2019

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF AIR QUALITY  
COMPLIANCE AND ENFORCEMENT BRANCH  
PART 70 OPERATING PERMIT  
QUARTERLY DEVIATION AND COMPLIANCE MONITORING REPORT**

Source Name: Cokenergy LLC  
 Source Address: 3210 Watling Street, MC 2-991, East Chicago, Indiana 46312-1610  
 Part 70 Permit No. : T089-36965-00383

Months: July to September Year: 2019

This report shall be submitted quarterly based on a calendar year. Any deviation from the requirements, the date(s) of each deviation, the probable cause of the deviation, and the response steps taken must be reported. Deviations that are required to be reported by an applicable requirement shall be reported according to the schedule stated in the applicable requirement and do not need to be included in this report. Additional pages may be attached if necessary. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".

NO DEVIATIONS OCCURRED THIS REPORTING PERIOD

THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD

<b>Permit Requirement:</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

<b>Permit Requirement:</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

<b>Permit Requirement:</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

<b>Permit Requirement:</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

<b>Permit Requirement:</b> (specify permit condition #)	
<b>Date of Deviation:</b>	<b>Duration of Deviation:</b>
<b>Number of Deviations:</b>	
<b>Probable Cause of Deviation:</b>	
<b>Response Steps Taken:</b>	

Form Completed by:           Seth Acheson          

Title / Position:           General Manager, Cokenergy, LLC          

Date:           October 16, 2019          

Phone:           (219) 397-4521



---

## **Excess Emissions and Downtime Report**

---

COKENERGY, LLC, East Chicago, IN

Plant ID: 089-00383

Emissions Unit ID: Stack 201

Emissions Unit: Heat Recovery Coke Carbonization Waste Heat Stack

**PLANT OPERATIONS DOWNTIME SUMMARY**

Reporting Period: 3rd Quarter of 2019

Commencement of Emission Unit Downtime	Completion of Emission Unit Downtime	Emission Unit Downtime Duration (hours)	Reasons for Emission Unit Downtime
<b>None</b>			
Total Emission Unit Downtime for the quarter =		0	hours

COKENERGY, LLC, East Chicago, IN

Plant ID: 089-00383

Emissions Unit ID: Stack 201

Emissions Unit: Heat Recovery Coke Carbonization Waste Heat Stack

**EXCESS EMISSIONS SUMMARY**

Reporting Period: 3rd Quarter of 2019

**SO<sub>2</sub> Exceedances**

Emission Standard: 1,656 lb/hr on a 24-hr average basis  
(Note that this limit is for the combined emissions from Cokenergy Stack 201 and 16 IHCC Vent Stacks)

Date/Time of Commencement	Date/Time of Completion	Magnitude of Emissions (lb/hr)		Reasons for Excess Emissions	Corrective Actions Taken
		Main Stack Avg	Vent Stack Avg		
<b>None</b>					

COKENERGY, LLC, East Chicago, IN

Plant ID: 089-00383

Emissions Unit ID: Stack 201

Emissions Unit: Heat Recovery Coke Carbonization Waste Heat Stack

**EXCESS EMISSIONS SUMMARY**

Reporting Period: 3rd Quarter of 2019

**Opacity Exceedances**

Emission Standard: 20% opacity

Date/Time of Commencement	Date/Time of Completion	Magnitude of Emissions	Reasons for Excess Emissions	Corrective Actions Taken
<b>None</b>				
Total Duration	0 minutes			



COKENERGY, LLC, East Chicago, IN

Plant ID: 089-00383

Emissions Unit ID: Stack 201

Emissions Unit: Heat Recovery Coke Carbonization Waste Heat Stack

**CONTINUOUS MONITORING SYSTEM DOWNTIME SUMMARY**

Reporting Period: 3rd Quarter of 2019

**SO<sub>2</sub> CEMS Downtime**

Date/Time of Commencement	Duration of Downtime (hours)	Reasons for Instrument Downtime	System Repairs and Adjustments
8/26/19 10:00	2	Complete quarterly PMs and CGA on the CEMS	
9/27/19 19:00	43	Lightning strike	Routine quarterly preventative maintenance Replaced analyzer mother board, completed calibrations
Total Downtime	45 hours		

Note: Daily zero and span checks of the instrument have been excluded from the downtime summary per 326 IAC 3-5-7.



# CYLINDER GAS AUDIT

*FOR*

## Primary Energy

*E. Chicago, IN*

**Unit: Stack 201**

**MONITORING SOLUTIONS, INC.  
FULL EXTRACTIVE**

**Third (3rd) Quarter Results  
2019**

CGA Completed On: 8/26/2019

**PREPARED BY:**





TABLE OF CONTENTS

<i>I. Introduction .....</i>	<i>1</i>
<i>II. Cylinder Gas Audit Procedures .....</i>	<i>3</i>
<i>III. Cylinder Gas Audit Data Sheets .....</i>	<i>5</i>
<i>IV. Cylinder Gas Certification Sheets .....</i>	<i>6</i>

**LIST OF TABLES**

<b>Table</b>	<b>Page</b>
Table 1-1: Summary of Cylinder Gas Audit Results	2
Table 1-2: Measurement Points for Cylinder Gas Audit	3

**I. Introduction**

Monitoring Solutions, Inc. was contracted to conduct a Cylinder Gas Audit on a Continuous Emission Monitoring System (CEMS). This audit was performed:

**Client:** Primary Energy  
**City, State:** E. Chicago, IN  
**Unit:** Stack 201  
**Auditor:** Dan Bowles  
**Audit Date:** 8/26/2019

The audit of the Continuous Emission Monitoring System was conducted for the following gases:

Gas #1 : SO2  
Gas #2 : O2 Dry & O2 Wet

Our assessment of this quarter's CGA results indicates that all of the analyzers evaluated during this test program meet the accuracy requirements as outlined in 40 CFR 60, Appendix F.

**NOTE:** Table 1-1 summarizes the results for the cylinder gas audit.

Reviewed by: \_\_\_\_\_

Date: 09/11/2019

## Summary of Cylinder Gas Audit Results

<b>Parameter</b>	<b>Low Gas Error</b>	<b>Mid Gas Error</b>
SO2	1.17	2.14
O2 Dry	0.00	2.31
O2 Wet	2.00	3.31
	Pass	Pass

Table 1-1

40 CFR 60, Appendix F Performance Test requirements: <15%

**II. CYLINDER GAS AUDIT PROCEDURES**

Each Continuous Emission Monitor (CEM) must be audited three out of four calendar quarters of each year. As part of the Quality Control (QC) and Quality Assurance (QA) procedures, the quality of data produced is evaluated by response accuracy compared to known standards,

The Cylinder Gas Audit (CGA) for this quarter was conducted in accordance with the QA/QC procedure outlined in 40 CFR 60, Appendix F.

All applicable audit gases are connected to the sampling system. Each gas is introduced into the sampling and analysis system. The gases flow through as much of the sampling path as possible.

The gases are actuated on and off by utilizing a computer and/or PLC controlled solenoids at designated time intervals.

- a) Challenge each monitor (both pollutant and diluent, if applicable) with cylinder gases of known concentrations at two measurement points listed in Table 1-2.
- b) Use a separate cylinder gas for measurement points 1 and 2. Challenge the CEMS three times at each measurement point and record the responses.
- c) Use cylinder gases that have been certified by comparison to National Institute of Standards and Technology (NIST) gaseous standard reference material (SRM) or NIST/EPA approved gas manufacturer’s certified reference material (CRM) following “Traceability Protocol for Establishing True Concentrations of Gases Used for Calibration and Audits of Continuous Source Emission Monitors. (Protocol Number 1).”

**NOTE:** In rare cases, some operators may have pollutant cylinder gases that are not "Protocol 1". Pollutant cylinder gases in high concentrations may not be certifiable to the "Protocol 1 Standard" and are only available as a "Certified Standard" (e.g. Sulfur Dioxide [SO<sub>2</sub>] in a concentration of 3.0% - or - 30,000 ppm).

<i>Gas</i>	<i>Measurement point #1</i>	<i>Measurement point #2</i>
Pollutants -	20-30% of span value	50-60% of span value
Diluent - O <sub>2</sub>	4-6% by volume	8-12% by volume
Diluent - CO <sub>2</sub>	5-8% by volume	10-14% by volume

Table 1-2

**NOTE:** Some operators may have cylinder gas values that fall outside of these parameters. This may be a result of previous agreements with their state or local EPA authority.

- d) Determine the Relative Accuracy of each measurement point using the formula below. The RA error must not exceed 15%.

$$RA = \left| \left( \frac{\bar{d}}{AC} \right) 100 \right| \leq 15 \text{ percent}$$

Where:

RA = Relative Accuracy

$\bar{d}$  = Average of the three responses (Arithmetic Mean)

AC = The certified concentration of the cylinder gas.

### **III. Cylinder Gas Audit Data Sheets**

# CYLINDER GAS AUDIT (CGA) ERROR DETERMINATION

<b>CLIENT:</b> <u>Primary Energy</u> <b>PLANT / SITE:</b> <u>E. Chicago, IN</u> <b>UNIT ID:</b> <u>Stack 201</u>	<b>CONDUCTED BY :</b> <u>Dan Bowles</u> <b>ATTENDEE :</b> <u>N/A</u> <b>AUDIT DATE:</b> <u>8/26/2019</u>
<b>MONITOR TESTED:</b> <u>SO2</u> <b>RANGE :</b> <u>0 - 700 PPM</u>	<b>ANALYZER SERIAL NUMBER:</b> <u>1152150034</u>

	Run	Time	Reference value	Monitor value	Difference	Error %
Low-level	1	11:45	176.50	179.00	2.50	1.42 %
	2	12:03	176.50	178.00	1.50	0.85 %
	3	12:21	176.50	178.70	2.20	1.25 %
Mid-level	1	11:39	386.50	394.80	8.30	2.15 %
	2	11:57	386.50	394.50	8.00	2.07 %
	3	12:15	386.50	395.00	8.50	2.20 %

Low-level	Arithmetic Mean: 178.57	Tank S/N <u>CC14789</u>
		Tank Expiration Date <u>7/25/2025</u>
	<b>CGA Error: 1.17 %</b>	

Mid-Level	Arithmetic Mean: 394.77	Tank S/N <u>CC701716</u>
		Tank Expiration Date <u>3/5/2027</u>
	<b>CGA Error: 2.14 %</b>	



Date	Parameter	Run#	Timestamp	Type	Expected	Measured	Low Diff	-----	Mid Diff	-----
08/26/2019										
	SO2, PPM	1	11:39:25	QTR_MID	386.5	394.8			8.3	
	SO2, PPM	1	11:45:23	QTR_LOW	176.5	179.0	2.5			
	SO2, PPM	2	11:57:23	QTR_MID	386.5	394.5			8.0	
	SO2, PPM	2	12:03:24	QTR_LOW	176.5	178.0	1.5			
	SO2, PPM	3	12:15:24	QTR_MID	386.5	395.0			8.5	
	SO2, PPM	3	12:21:24	QTR_LOW	176.5	178.7	2.2			

Arithmetic Mean of Quarterly Low : 178.6  
 Linearity Error of Quarterly Low : 1.2  
 Calibration Tolerance: 15.0

Arithmetic Mean of Quarterly Mid : 394.8  
 Linearity Error of Quarterly Mid : 2.1  
 Calibration Tolerance: 15.0

Calibration Result : Pass

CEMS Type : Full Extractive  
 Manufacturer: Thermo  
 Model Number : 43i-HL  
 Serial Number: 1152150034  
 Monitor Certification Date:

Tested By : \_\_\_\_\_

Date: \_\_\_\_\_

# CYLINDER GAS AUDIT (CGA) ERROR DETERMINATION

<b>CLIENT:</b> <u>Primary Energy</u> <b>PLANT / SITE:</b> <u>E. Chicago, IN</u> <b>UNIT ID:</b> <u>Stack 201</u>	<b>CONDUCTED BY :</b> <u>Dan Bowles</u> <b>ATTENDEE :</b> <u>N/A</u> <b>AUDIT DATE:</b> <u>8/26/2019</u>
<b>MONITOR TESTED:</b> <u>O2 Dry</u> <b>RANGE :</b> <u>0 - 25</u> %	<b>ANALYZER SERIAL NUMBER:</b> <u>11400</u>

	Run	Time	Reference value	Monitor value	Difference	Error %
Low-level	1	11:45	5.00	5.00	0.00	0.00 %
	2	12:03	5.00	5.00	0.00	0.00 %
	3	12:21	5.00	5.00	0.00	0.00 %
Mid-level	1	11:51	9.97	10.20	0.23	2.31 %
	2	12:09	9.97	10.20	0.23	2.31 %
	3	12:27	9.97	10.20	0.23	2.31 %

Low-level	Arithmetic Mean: 5.00	Tank S/N <u>CC14789</u>
		Tank Expiration Date <u>7/25/2025</u>
	<b>CGA Error: 0.00 %</b>	

Mid-Level	Arithmetic Mean: 10.20	Tank S/N <u>CC400438</u>
		Tank Expiration Date <u>8/16/2025</u>
	<b>CGA Error: 2.31 %</b>	

Date	Parameter	Run#	Timestamp	Type	Expected	Measured	Low Diff	-----	Mid Diff	-----
08/26/2019										
	O2 DRY, %	1	11:45:23	QTR_LOW	5.0	5.0	0.0			
	O2 DRY, %	1	11:51:23	QTR_MID	10.0	10.2			0.2	
	O2 DRY, %	2	12:03:24	QTR_LOW	5.0	5.0	0.0			
	O2 DRY, %	2	12:09:24	QTR_MID	10.0	10.2			0.2	
	O2 DRY, %	3	12:21:24	QTR_LOW	5.0	5.0	0.0			
	O2 DRY, %	3	12:27:24	QTR_MID	10.0	10.2			0.2	

Arithmetic Mean of Quarterly Low : 5.0  
 Linearity Error of Quarterly Low : 0.2  
 Calibration Tolerance: 15.0

Arithmetic Mean of Quarterly Mid : 10.2  
 Linearity Error of Quarterly Mid : 2.3  
 Calibration Tolerance: 15.0

Calibration Result : Pass

CEMS Type : Full Extractive  
 Manufacturer: Brand Gaus  
 Model Number : 4705  
 Serial Number: 11400  
 Monitor Certification Date:

Tested By : \_\_\_\_\_

Date: \_\_\_\_\_

# CYLINDER GAS AUDIT (CGA) ERROR DETERMINATION

<b>CLIENT:</b> <u>Primary Energy</u> <b>PLANT / SITE:</b> <u>E. Chicago, IN</u> <b>UNIT ID:</b> <u>Stack 201</u>	<b>CONDUCTED BY :</b> <u>Dan Bowles</u> <b>ATTENDEE :</b> <u>N/A</u> <b>AUDIT DATE:</b> <u>8/26/2019</u>
<b>MONITOR TESTED:</b> <u>O2 Wet</u> <b>RANGE :</b> <u>0 - 25</u> %	<b>ANALYZER SERIAL NUMBER:</b> <u>11401</u>

	Run	Time	Reference value	Monitor value	Difference	Error %
Low-level	1	11:45	5.00	5.10	0.10	2.00 %
	2	12:03	5.00	5.10	0.10	2.00 %
	3	12:21	5.00	5.10	0.10	2.00 %
Mid-level	1	11:51	9.97	10.30	0.33	3.31 %
	2	12:09	9.97	10.30	0.33	3.31 %
	3	12:27	9.97	10.30	0.33	3.31 %

Low-level	Arithmetic Mean: 5.10  <b>CGA Error:        2.00 %</b>	Tank S/N <u>CC14789</u> Tank Expiration Date <u>7/25/2025</u>
-----------	--	--

Mid-Level	Arithmetic Mean: 10.30  <b>CGA Error:        3.31 %</b>	Tank S/N <u>CC400438</u> Tank Expiration Date <u>8/16/2025</u>
-----------	---	---

Date	Parameter	Run#	Timestamp	Type	Expected	Measured	Low Diff	-----	Mid Diff	-----
08/26/2019										
	O2 WET, %	1	11:45:23	QTR_LOW	5.0	5.1	0.1			
	O2 WET, %	1	11:51:23	QTR_MID	10.0	10.3			0.3	
	O2 WET, %	2	12:03:24	QTR_LOW	5.0	5.1	0.1			
	O2 WET, %	2	12:09:24	QTR_MID	10.0	10.3			0.3	
	O2 WET, %	3	12:21:24	QTR_LOW	5.0	5.1	0.1			
	O2 WET, %	3	12:27:24	QTR_MID	10.0	10.3			0.3	

Arithmetic Mean of Quarterly Low : 5.1  
 Linearity Error of Quarterly Low : 1.8  
 Calibration Tolerance: 15.0

Arithmetic Mean of Quarterly Mid : 10.3  
 Linearity Error of Quarterly Mid : 3.3  
 Calibration Tolerance: 15.0

Calibration Result : Pass

CEMS Type : Full Extractive  
 Manufacturer: Brand Gaus  
 Model Number : 4705  
 Serial Number: 11401  
 Monitor Certification Date:

Tested By : \_\_\_\_\_

Date: \_\_\_\_\_

## **IV. Cylinder Gas Certification Sheets**

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number: E04NI84E15A0007      Reference Number: 54-124629354-1  
 Cylinder Number: CC14789      Cylinder Volume: 150.4 CF  
 Laboratory: 124 - Chicago - IL      Cylinder Pressure: 2015 PSIG  
 PGVP Number: B12017      Valve Outlet: 660  
 Gas Code: CO2,O2,SO2,BALN      Certification Date: Jul 25, 2017

**Expiration Date: Jul 25, 2025**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

### ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
[REDACTED]	175.0 PPM	[REDACTED]	G1	+/- 1.0% NIST Traceable	07/17/2017, 07/25/2017
[REDACTED]	5.000 %	[REDACTED]	G1	+/- 1.0% NIST Traceable	07/18/2017
CARBON DIOXIDE	10.00 %	10.00 %	G1	+/- 0.9% NIST Traceable	07/17/2017
NITROGEN	Balance				

### CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060140	CC437515	515.2 PPM SULFUR DIOXIDE/NITROGEN	+/- 0.8%	Nov 16, 2021
NTRM	11060719	CC338460	4.861 % OXYGEN/NITROGEN	+/- 0.4%	Dec 13, 2022
NTRM	13060635	CC413759	13.359 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	May 09, 2019

### ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801332	FTIR	Jun 21, 2017
O2-1 HORIBA MPA-510 3VUJL9NR	Paramagnetic	Jul 17, 2017
Nicolet 6700 AHR0801332	FTIR	Jul 21, 2017

Triad Data Available Upon Request



*[Signature]*  
Approved for Release

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA Protocol

Part Number:	E02NI90E15A0228	Reference Number:	54-400967311-1
Cylinder Number:	CC400438	Cylinder Volume:	145.2 CF
Laboratory:	124 - Chicago (SAP) - IL	Cylinder Pressure:	2015 PSIG
PGVP Number:	B12017	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Aug 16, 2017

**Expiration Date: Aug 16, 2025**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	10.00 %	9.970 %	G1	+/- 1% NIST Traceable	08/16/2017
NITROGEN	Balance			-	

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	06120102	CC195613	9.898 % OXYGEN/NITROGEN	+/- 0.7%	Jul 26, 2018

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
O2-1 HORIBA MPA-510 3VUYL9NR	Paramagnetic	Jul 17, 2017

Triad Data Available Upon Request



\_\_\_\_\_  
Signature on file  
Approved for Release



*In Service 7/26/19*

**CERTIFICATE OF ANALYSIS**  
**Grade of Product: EPA Protocol**

Part Number: E03NI89E15A0052      Reference Number: 54-401436109-1  
Cylinder Number: CC701716      Cylinder Volume: 149.9 CF  
Laboratory: 124 - Chicago (SAP) - IL      Cylinder Pressure: 2015 PSIG  
PGVP Number: B12019      Valve Outlet: 660  
Gas Code: CO2,SO2,BALN      Certification Date: Mar 05, 2019

**Expiration Date: Mar 05, 2027**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
SULFUR DIOXIDE	385.0 PPM	386.5 PPM	G1	+/- 0.8% NIST Traceable	02/26/2019, 03/05/2019
CARBON DIOXIDE	10.00 %	9.892 %	G1	+/- 1.0% NIST Traceable	02/26/2019
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	15060628	CC450467	248.1 PPM SULFUR DIOXIDE/NITROGEN	+/- 0.6%	Dec 17, 2020
NTRM	13060738	CC414595	16.939 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	May 08, 2019

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801332	FTIR	Feb 25, 2019
Nicolet 6700 AHR0801332	FTIR	Feb 25, 2019

Triad Data Available Upon Request



*Alan Curry*  
**Approved for Release**

# OPACITY PERFORMANCE AUDIT

*FOR*

## Primary Energy

*E. Chicago, IN*

Unit: Stack 201

MONITORING SOLUTIONS, INC.  
MODEL: DURAG D-R 290 COMS

Third (3rd) Quarter Results  
2019

Audit Completed On: 8/26/2019

PREPARED BY:



**Monitoring** | **Solutions**

*Leaders in Environmental Monitoring Systems & Services*

TABLE OF CONTENTS

***I. Introduction ..... 1***

***II. Monitoring Solutions, Inc. COMS Model Durag D-R 290***

    A. COMS Description..... 2

    B. Performance Audit Procedures ..... 3

    C. Interpretation of Audit Results ..... 9

*Appendix A - COMS Audit Data Forms for the Durag Model D-R 290*

*Appendix B - Audit Filter Certification Sheet(s)*

I. Introduction

Monitoring Solutions, Inc. was contracted to conduct an opacity performance audit on a Durag Model D-R 290 opacity system.

Client: Primary Energy  
City, State: E. Chicago, IN  
Auditor: Dan Bowles  
Audit Date: 8/26/2019

The performance testing consists of:

- 1 Zero and Span Check
- 2 Zero Compensation Check
- 3 Optical Alignment Check
- 4 Calibration Error Check
- 5 Annual Zero Alignment (When required)

All raw data, calculated data and final summary are presented. The results indicate compliance for all specifications. Testing was performed as per 40CFR60 Appendix F and 40CFR60 Appendix B, PS1 (Where Applicable).

Annual "Zero Alignment" check performed this quarter:

YES: \_\_\_\_\_ NO:  X  ERROR:  N/A

**Summary of Calibration Error Check**

Filter :	Low	Mid	High
Percent of Error:	0.33	1.13	0.10
	PASS	PASS	PASS

Reviewed by: \_\_\_\_\_

Date:  09/12/2019

Revision: March 2016

## PERFORMANCE AUDIT PROCEDURES FOR THE MONITORING SOLUTIONS, INC. OPACITY MONITOR

### II. Monitoring Solutions, Inc. Durag Model D-R 290

The instrument is manufactured by the Durag Corporation and distributed and serviced by Monitoring Solutions, Inc.

#### A. COMS Description

The Monitoring Solutions, Inc. D-R 290 opacity monitoring system consists of four major components: the Transmissometer, the terminal control box, the air-purging system and the remote control unit and data acquisition equipment. The Transmissometer component consists of an optical transmitter/receiver (transceiver) unit mounted on one side of a stack or duct and a retro reflector unit mounted on the opposite side. The transceiver unit contains the light source, the photodiode detector, and the associated electronics. The transceiver uses a single-lamp, single detector system to determine effluent opacity. A LED light source is modulated electronically at 2 KHz to eliminate any ambient light interference. The modulated beam is configured to alternately produce reference and measurement signals so that the effects of variations in the optical and electronic components of the COMS are minimized.

In a single display configuration, an AW unit is mounted in a blue housing next to the transceiver location. In a dual display configuration, an AZ unit is mounted in the blue housing next to the transceiver location and an AW is mounted in a remote location, typically, a control room. The AZ and the AW communicate via an RS 422 cable. The AZ unit provides an on stack readout and can be used as a diagnostic tool. In either configuration, only the AW provides the signals to the final recording device.

The air purging system serves a threefold purpose: 1) it provides an air window to keep exposed optical surfaces clean; 2) it protects the optical surfaces from condensation of stack gas moisture; and 3) it minimizes thermal conduction from the stack to the instrument. A standard installation has one air-purging system for each the transceiver and the retro reflector units.

The opacity monitor measures the amount of light transmitted through the effluent from the transceiver to the retro reflector and back again. The control unit uses the effluent transmittance to calculate the optical density of the effluent at the monitor location, or the "path" optical density. In order to provide stack exit opacity data, the path optical density must be corrected. The correction factor is expressed as the ratio of the stack exit inside diameter to the inside diameter of the stack at the Transmissometer location. This ratio is called the "stack correction factor" (SCF) by Monitoring Solutions, Inc. The following equations illustrate the relationship between this ratio, path optical density, and stack exit opacity.

### Calculation of "Stack Correction Factor"

$$L_x / L_t = \text{stack correction factor}$$

---

where:  $L_x$  = stack exit inside diameter (in)

$L_t$  = the stack inside diameter (or the duct width) at the monitor location (in).

$$OP_x = 1 - \left(1 - \frac{Opacity}{100}\right)^{correction\ factor}$$

$OP_x$  = stack exit opacity (%)

## B. Performance Audit Procedures

### 1. Preliminary Data

- a. Obtain the stack exit inside diameter (in feet) and the stack inside diameter at the monitor location (in feet). Record these values in Blanks 1 and 2 of the Monitoring Solutions, Inc. D-R 290 Performance Audit Data Sheet.

**Note:** Effluent handling system dimensions may be acquired from the following sources listed in descending order of reliability: 1) physical measurements, 2) construction drawings, 3) opacity monitor installation/certification documents, and 4) source personnel recollections.

- b. Calculate the stack correction factor (SCF) by dividing the value in Blank 1 by the value in Blank 2. Record the result in Blank 3.
- c. Record the source-cited Stack Correction Factor (SCF) in Blank 4.

**Note:** The stack correction factor (SCF) is preset by the manufacturer using information supplied by the source. The value recorded in Blank 4 should be the value source personnel agree should be set inside the monitor.

- d. Obtain the reference zero and span calibration values. Record these values in Blank 5 and Blank 6, respectively.

**Note:** The reference zero and span calibration values may not be the same as the values recorded during instrument installation and/or certification. The zero and span values recorded in Blank 5 and Blank 6 should be the reference values recorded during the most recent clear-path calibration of the CEMS.

## 2. Error Checks

The following steps describe the error codes for the Monitoring Solutions, Inc. D-R 290 remote control unit. The audit can continue with the error codes shown below being present, provided the source has been informed of the fault conditions. All other error codes must be corrected prior to audit.

Error code 100 = Transceiver blower fault  
Error code 200 = Transceiver filter plugged  
Error code 300 = Reflector blower fault  
Error code 400 = Reflector filter plugged

**Note:** If a fault is active, an error code will be displayed on the stack mounted display and on the remote display. An explanation of the error codes can be found in the manual.

## 3. Instrument Range Check

- a. Check the COMS measurement range by pressing the MOD button (the LED on the button will light up) and using the PLUS button to cycle through the displays.
- b. Record the instrument range in Blank 11.

## 4. Reference Signal, Zero and Span Checks

- a. Initiate the calibration cycle by pressing the arrow and plus buttons simultaneously and holding for approximately 5 seconds.

**Note:** The opacity monitor will automatically cycle through the internal zero (zero point check), external zero (window check), span and stack taper ratio modes. Approximately 6 minutes for a complete cycle.

- b. Record the milliamp value shown for the internal zero (zero point check) displayed on the control panel display in Blank 12.

**Note:** The internal zero checks the instrument reference signal (Zero Point Check). Since the instrument provides a full scale output of 4 to 20 milliamps, a value of 4 milliamps displayed on the control unit display represents a zero condition. After 1 ½ minutes in the internal zero mode, the monitor will automatically switch to the external zero mode (Window Check).

- c. Record the milliamp value shown for the external zero (window check) displayed on the control panel in Blank 13. Also record the external zero value (in percent opacity) displayed on the opacity data recorder in Blank 14.

(Continued on next page)

**Note:** During the zero calibration check, the zero mirror is moved into the path of the measurement beam by a servomotor. The zero mechanism is designed to present the transceiver with a simulated clear-path condition. The daily zero check does not test the actual clear-path zero, nor does it provide a check of cross-stack parameters such as the optical alignment of the Transmissometer or drift in the reflectance of the retro reflector. The actual clear-path zero can only be checked during clear-stack or off-stack calibration of the CEMS. In addition to simulating the instrument clear-path zero, the zero mechanism allows the amount of dust on the transceiver optics (primary lens and zero mirror) to be quantified. After 1 ½ minutes in the external zero mode, the CEMS will automatically enter the span mode.

- d. Record in Blank 15 the span value (in milliamps) displayed on the control panel display. Also record the span value (in percent opacity) displayed on the data recorder in Blank 16. Go to the Transmissometer location.

**Note:** During the span calibration check, a servomotor moves an internal span filter into the path of the measurement beam while the zero mirror is in place. The span mechanism is designed to provide an indication of the upscale accuracy of the CEMS relative to the simulated clear-path zero. Note: The opacity monitor display will output its stack correction factor (SCF) for 1 ½ minutes when the span portion of the calibration cycle is completed. The CEMS automatically returns to the measurement mode when the SCF portion of the calibration cycle is complete.

#### **5. Reflector Dust Accumulation Check.**

- a. Record the effluent opacity prior to cleaning the retroreflector optics in Blank 17.
- b. Open the reflector housing, inspect and clean the retroreflector optics, and close the housing.
- c. Record the post-cleaning effluent opacity in Blank 18. Go to the transceiver location.

#### **6. Transceiver Dust Accumulation Check.**

- a. Record the pre-cleaning effluent opacity in Blank 19.
- b. Open the transceiver, clean the optics (primary window and zero mirror) and close the transceiver.
- c. Record the post-cleaning effluent opacity in Blank 20.



## 7. Alignment Check

- a. Determine the monitor alignment by looking through the alignment port of the side of the transceiver.
- b. Observe whether the image is centered in the cross hairs and record this information (YES or NO) in Blank 21.

## 8. Zero Compensation Check

The Durag 290 provides internal compensation for window contamination. This compensation value can be determined by performing the Window Check. This compensation cannot be disabled for testing. Remove internal compensation as follows: Clean the transceiver window and the zero mirror lens. Verify the window check value is at zero so no compensation is applied to the quarterly audit. Enter the Filter Audit Mode and verify the starting Durag opacity value is zero percent. **NOTE:** This process must be completed prior to the Calibration Error Check.

## 9. Zero Alignment Error Check

The Zero Alignment Error Check is performed one time each year. This check utilizes Durag's Clear Path Procedure. This procedure verifies the "measuring" zero point of the unit in a known clear path setup. The Transceiver and reflector are removed from their installation and set up on stands in a clean, dust free environment. The stands are set at the same distance as the installation location. Without performing any adjustments, the measuring zero is compared to the simulated zero - or - Window Check. The difference between the measuring zero and the simulated zero, must NOT exceed 2% opacity.

Verify the Zero Compensation Check has been performed. Since the zero compensation function cannot be disabled for the zero alignment check, the optics must be cleaned and a manual calibration performed. This will set the internal compensation value to 0.0%. This MUST be accomplished prior to the Zero Alignment Check.

Perform the following to document the "Zero Alignment Error":

- a) Remove the Transceiver & Reflector from its current installation and setup on stands at the exact distance as their original location.
- b) Perform the Zero Compensation Check and perform a manual calibration.
- c) Record the Durag's response to the clear path zero in % opacity without any adjustment.
- d) Activate the simulated zero (Window Check) and record the reading in % opacity without any adjustment.  
(continued on next page)

- e) The response difference between these two readings are recorded as the “zero alignment error”. The maximum allowable zero alignment error is 2%.
- f) Adjust the simulated zero (window check) to read the same value in % opacity as the clear path zero.

## 10. Calibration Error Check

The calibration error check is performed using three neutral density filters. Performing the calibration error check on-stack using the filters determines the linearity of the instrument response relative to the current clear-path zero setting. This calibration error check does not determine the accuracy of the actual instrument clear-path zero or the status of any cross-stack parameters. A true calibration check is performed by moving the on-stack components to a location with minimal ambient opacity, making sure that the proper path length and alignments are attained, and then placing the calibration filters in the measurement path.

- a. Put the monitor in Filter Audit mode.
- b. Wait approximately three minutes or until a clear “zero” value has been recorded and displayed on the data recorder.
- c. Record the audit filter serial numbers and opacity values in Blanks 22, 23, and 24.
- d. Remove the filters from their protective covers, inspect and if necessary, clean them.
- e. Insert the low range neutral density filter into the filter audit slot located in front of the heated lens.
- f. Wait approximately three minutes or until a clear value has been recorded and displayed on the data recorder.

**Note:** The audit data should be taken from a data recording/reporting device that presents instantaneous opacity (or opacity data with the shortest available integration period).

- g. Record the COMS response to the low range neutral density filter.
- h. Remove the low range filter and insert the mid range neutral density filter.
- i. Wait approximately three minutes and record the COMS response to the mid range neutral density filter.
- j. Remove the mid range filter and insert the high range filter.
- k. Wait approximately three minutes and record the COMS response to the high range neutral density filter.

(continued on next page)

- l. Remove the high range filter.
- m. \* If applicable, wait approximately three minutes, and record the zero value.
- n. Repeat steps (e) through (m) until a minimum of three opacity readings are obtained for each neutral density filter.
- o. If six-minute integrated opacity data is required, repeat steps (e) through (m) once more, changing the waiting periods to 13 minutes.
- p. Record the six-minute integrated data.

**Note:** In order to acquire valid six-minute averaged opacity data, each filter must remain in for at least two consecutive six-minute periods; the first period will be invalid because it was in progress when the filter was inserted. A waiting period of 13 minutes is recommended. You should have a “starting zero” reading and an “ending zero” reading.

- q. When the calibration error check is complete, return the monitor to measuring mode. Close the transceiver head and the weather cover, and return to the COMS control unit.

## 11. Test Conclusion

- a. Obtain a copy of the audit data from the data recorder.
- b. Transcribe the calibration error response from the data recorder to Blanks 25 through 50 of the audit form and complete the audit data calculations.

## C. Interpretation of Audit Results

This section is designed to help the auditor interpret the D-R 290 performance audit results.

### Error codes / fault analysis

Error codes are typically associated with parameters that the monitor manufacturer feels are critical to COMS function, and to the collection of valid opacity data. The parameters associated with each of the error codes are found in the manufacturer’s manual. With the exception of alarms that warn of elevated opacity levels (alarm or warning lamps), the error codes indicate that the COMS is not functioning properly. An error or failure indication will be represented by a “YES” in Blanks 7 - 10.

(continued on next page)

### Stack Exit Correlation Error Check

The path length correction error in Blank 51 should be within +2%. This error exponentially affects the opacity readings, resulting in over - or - underestimation of the stack exit opacity. The most common error in computing the optical path length correction factor is the use of the flange-to-flange distance in place of the stack/duct inside diameter at the monitor location. This error will result in underestimation of the stack exit opacity and can be identified by comparing the monitor optical path length to the flange-to-flange distance; the flange-to-flange distance should be greater by approximately two to four feet

### Control Panel Meter Error (Optional)

The accuracy of the control panel meter (AW) is important at sources using the meter during monitor adjustment and calibration. The accuracy of the control panel meter (Blank 52 and Blank 54) is determined by comparing the zero and span reference values to the panel meter output recorded during the COMS calibration check.

**Note:** Some installations utilize a different “Instrument Range Setting” than the normal 100% range. The panel meter span error must be corrected for the different range in order to provide an accurate error result. Use the following equation to calculate the span error corrected for “Instrument Range” (Blank 11):

$$\text{Panel Meter span error in \% opacity} = \\ \left( \left( (\text{Blank 15} - 4) \div 16 \right) \times \text{Blank 11} \right) - \text{Blank 6}$$

### Zero and Span Checks

The D-R 290 internal zero or “zero point check” (Blank 12) should be set to indicate 0% opacity (equivalent to 3.7 - 4.3 mA). An external zero error or “window check” (Blank 53) greater than 4% opacity is usually due to excessive dust accumulation on the optical surfaces, electronic drift or an electronic/mechanical offset of the data recorder. Excessive dust on the optical surfaces sufficient to cause a significant zero error would be indicated by the difference in the internal and external zero values and/or window alarm. Instrument span error (Blank 55) may be caused by the same problem(s) that cause zero errors and may be identified in a similar fashion.

If the zero and span errors are due to a data recorder offset, both errors will be in the same direction and will be of the same magnitude

(continued on next page)

The external zero displayed on the control unit panel meter (AW) also indicates the level of dust accumulation on the zero retroreflector and transceiver measurement window. The difference between the internal and external zero responses should equal the amount of dust found on the transceiver optics (Blank 57). To convert the zero responses to a value that represents lens dusting in percent opacity, use the following equation.

$$\text{Meter response in \% opacity} = 6.25 [(\text{Blank 13}) - (\text{Blank 12})]$$

### **Optical Alignment Check**

When the transceiver and retroreflector are misaligned, a portion of the measurement beam that should be returned to the measurement detector is misdirected, resulting in a positive bias in the data reported by the COMS. One of the most common causes of misalignment is vibration which may cause the on-stack components to shift slightly on the instrument mounting flanges. Another common cause of misalignment is thermal expansion and contraction of the structure on which the transmissometer is mounted. If the COMS is being audited while the unit is off-line (cold stack), the results of the alignment analysis may not be representative of the alignment of the instrument when the stack or duct is at normal operating temperature. When checking the alignment, the reflected light beam should be centered.

### **Zero Compensation Check**

The Zero Compensation Check should be performed and documented as such in (Blank 21a).

### **Annual Zero Alignment Error Check**

The Zero Alignment Error Check is performed once each year. It verifies that the energy output from the simulated zero device (Window Check) is within 2% of the Clear Path reading. The values required for this check are documented in (Blank 21b). If the difference between the Clear Path Value and the Simulated Zero (Window Check) value differ by more than 2%, then the COMS unit is considered Out Of Control. If the difference is 2% or less, then the Window Check Value is adjusted to match the Clear Path value.

### **Optical Surface Dust Accumulation Check**

The results of the dust accumulation check (Blank 58) should not exceed 4%. A dust accumulation value of more than 4% opacity indicates that the air flow of the purge system and/or the cleaning frequency of the optical surfaces are inadequate. When determining the optical surface dust accumulation, the auditor should note whether the effluent opacity is relatively stable (within +2% opacity) before and after cleaning the optical surfaces. If the effluent opacity is fluctuating by more than +2%, the dust accumulation analysis should be omitted.

(continued on next page)

**Calibration Error**

Calibration error results (Blanks 68, 69 and 70) in excess of +3% are indicative of a non-linear or miss calibrated instrument. However, the absolute calibration accuracy of the monitor can be determined only when the instrument clear-path zero value is known. If the zero and span data are out-of-specification, the calibration error data will often be biased in the direction of the zero and span errors. Even if the zero and span data indicate that the COMS is calibrated properly, the monitor may still be inaccurate due to error in the clear-path zero adjustment. The optimum calibration procedure involves using neutral density filters during clear-stack or off-stack COMS calibration. This procedure would establish both the absolute calibration accuracy and linearity of the COMS. If this procedure is impractical, and it is reasonable to assume that the clear-path zero is set correctly, the monitor's calibration can be set using either the neutral density filters or the internal zero and span values.

**Appendix A**  
**COMS Audit Data Forms for the Durag Model D-R 290**

AUDIT DATA SHEET  
MONITORING SOLUTIONS DURAG D-R 290 COMS

8/26/2019      Primary Energy      E. Chicago, IN      Stack 201      Page 1 of 5

Company:	<u>Primary Energy</u>	City, ST:	<u>E. Chicago, IN</u>
Unit ID:	<u>Stack 201</u>	Representing:	<u>Monitoring Solutions</u>
Auditor:	<u>Dan Bowles</u>	Representing:	<u></u>
Attendees:	<u>N/A</u>		
Transceiver serial number:	<u>1248342</u>		
Reflector serial number:	<u>1248145</u>		
Remote serial number	<u>1248283</u>	COMS Flange to Flange distance (Feet / Inches):	<u>226.125"</u>
Date:	<u>8/26/2019</u>		

Preliminary Data

1 Inside diameter at Stack Exit = Lx	<u>216.000</u> inches
2 Inside diameter at the Transmissometer location = Lt	<u>216.000</u> inches
3 Calculated Stack Correction Factor (SCF) = Lx/Lt	<u>1.000</u>
4 Source-cited Stack Correction Factor (SCF)	<u>1.000</u>
5 Source-cited zero automatic calibration value (% opacity)	<u>0.00</u> %
6 Source-cited span automatic calibration value (% opacity)	<u>40.00</u> %

[START AT CONTROL UNIT / DATA RECORDER LOCATION]

(If required) [INSPECT DATA RECORDING SYSTEM AND MARK WITH "OPACITY AUDIT,"  
AUDITOR'S NAME, AFFILIATION, DATE, SOURCE, PROCESS UNIT/STACK  
IDENTIFICATION, AND THE TIME OF DAY.]

Error codes / faults

7 Blower [Loss of purge air from blower - Error 100, 300]  
8 Filter [Air filter restriction - Error 200, 400]  
9 Window [Excessive dirt on transceiver window - Error 001]  
10 Fault [Additional CEMS fault has occurred. Note fault code  
on Opacity display and consult the instrument manual.]

YES - or - NO
NO
NO
NO
NO

Instrument Range Check

11 Instrument range setting 100 %

Zero Check

12 Opacity Display - Internal zero value in "milliamps" (Zero Point Check) 4.00 mA  
     [Wait for 1½ minutes for automatic change to external zero mode.]  
 13 Opacity Display - Zero calibration value in "milliamps" (Window Check) 4.00 mA  
 14 Opacity data recorder zero calibration value in "% Op" (Window Check) 0.00 mA  
     [Wait 1½ minutes for automatic change to span mode.]

Span Check

15 Opacity Display - Span calibration value in "milliamps" (Span Check) 10.40 mA  
 16 Opacity data recorder span calibration value in "% Op" (Span Check) 40.00 %  
     [Go to reflector location.]



AUDIT DATA SHEET  
MONITORING SOLUTIONS DURAG D-R 290 COMS

8/26/2019      Primary Energy      E. Chicago, IN      Stack 201      Page 2 of 5

Reflector Dust Accumulation Check

17 Pre-cleaning effluent opacity (% Op)      0.0 %  
 [Inspect and clean optical surface.]  
 18 Post-cleaning effluent opacity (% Op)      0.0 %  
 [Go to transceiver location.]

Transceiver Dust Accumulation Check and Zero Compensation Check

19 Pre-cleaning effluent opacity (% Op)      0.0 %  
 [Inspect and clean optical window and zero mirror.]  
 20 Post-cleaning effluent opacity (% Op)      0.0 %

Optical Alignment Check

[LOOK THROUGH ALIGNMENT SIGHT AND DETERMINE IF BEAM IMAGE IS CENTERED.]

21 Is the image centered?      

YES - or - NO
YES

Zero Compensation Check

21a Did you comply with the Zero Compensation Check?      

YES - or - NO
YES

Annual Zero Alignment Error Check

21b Did you comply with the Annual Zero Alignment Error Check?      

YES - or - NO
NO

Zero Alignment Error Check results (if applicable):

Clear Path Value % = 

N/A
-----

      Window Check Value % = 

N/A
-----

      Zero Alignment Error % = 

N/A
-----

[Record audit filter data.]

Filter	Serial NO.	% Opacity	SCF%
22 LOW	<u>YB11</u>	<u>15.70</u>	<u>15.70 %</u>
23 MID	<u>YB12</u>	<u>25.90</u>	<u>25.90 %</u>
24 HIGH	<u>ZA44</u>	<u>49.30</u>	<u>49.30 %</u>

[Remove the audit filters from the protective covers, inspect, and clean each filter]

[Set the unit up to display the initial zero. Wait 3 minutes to allow opacity data recorder to record initial zero]

[Insert a filter, wait approximately 3 minutes, and record the opacity value reported by the opacity data recorder. Repeat the process 5 times for each filter.]

[Read and transcribe final calibration error data from the opacity data recorder on the next page]



AUDIT DATA SHEET  
MONITORING SOLUTIONS DURAG D-R 290 COMS

8/26/2019

Primary Energy

E. Chicago, IN

Stack 201

Page 4 of 5

**Span Error (% Op.):**

	10.40	100	40.00		
54 Opacity Display	(((Blank 15 - 4.0) ÷ 16) × Blank 11) - Blank 6			=	<u>0.00 %</u>

	40	40		
55 Opacity Data Recorder	Blank 16	- Blank 6	=	<u>0.00</u>

**Optical Surface Dust Accumulation (% OP):**

	0	0.0		
56 Retroreflector	Blank 17	- Blank 18	=	<u>0.00 %</u>

	0	0		
57 Transceiver	Blank 19	- Blank 20	=	<u>0.00 %</u>

	0	0		
58 Total	Blank 56	+ Blank 57	=	<u>0.00 %</u>

**Optical Path Length Correction (SCF)**

**Audit Filters Corrected for Path Length:**

59 LOW:	15.70	1.000			
	$1 - (1 - (\frac{Blank\ 22}{100})^{Blank\ 4}) \times 100$			=	<u>15.70 %</u>

60 MID:	25.90	1.000			
	$1 - (1 - (\frac{Blank\ 23}{100})^{Blank\ 4}) \times 100$			=	<u>25.90 %</u>

61 HIGH	49.30	1.000			
	$1 - (1 - (\frac{Blank\ 24}{100})^{Blank\ 4}) \times 100$			=	<u>49.30 %</u>

AUDIT DATA SHEET  
MONITORING SOLUTIONS DURAG D-R 290 COMS

8/26/2019

Primary Energy

E. Chicago, IN

Stack 201

Page 5 of 5

Auditor: Dan Bowles

Date: 08/26/19

Source: Primary Energy

Unit: Stack 201

PARAMETER		Blank No.	Audit Results	Specifications
<b>Error Codes/Faults</b>				
Blower failure		7	NO	NO
Filter Blockage		8	NO	NO
Window		9	NO	NO
Fault		10	NO	NO
<b>SCF Correlation Error</b>		51	0.00	+/- 2% Op
<b>Internal Zero Error</b>	Display	52	0.00	+/- 4% Op
	Data	53	0.00	+/- 4% Op
<b>Internal Span Error</b>	Display	54	0.00	+/- 4% Op
	Data	55	0.00	+/- 4% Op
<b>Optical Alignment Analysis</b>		21	YES	YES = Centered
<b>Zero Compensation Check</b>		21a	YES	YES = Complied With
<b>Zero Alignment Error</b>		21b	N/A	≤ 2% Op
<b>Optical Surface Dust Accumulation</b>				
Retroreflector		56	0.00	≤ 2% Op
Transceiver		57	0.00	≤ 2% Op
Total		58	0.00	≤ 4% Op
<b>Calibration Error Analysis</b>				
Arithmetic Mean Difference				
LOW		62	0.26	
		71a	0.30	
MID		63	0.30	
		72a	0.60	
HIGH		64	-0.10	
		73a	0.00	
Confidence Coefficient				
		65	0.07	
		66	0.83	
		67	0.00	
Calibration Error				
		68	0.33	≤ 3% Op
		69	1.13	≤ 3% Op
		70	0.10	≤ 3% Op

Revision: March, 2016

## OPACITY LOW FILTER AUDIT

### Accuracy Determination

Primary Energy

E. Chicago, IN

Stack 201

8/26/2019

LOW FILTER RUN	Opacity Output from Recording Device	Audit Filter Value Corrected for Path Length (SCF)	(FILTER-MONITOR) Difference	Difference <sup>2</sup>
		<b>RM</b>	<b>(X<sub>i</sub>)</b>	<b>X<sub>i</sub><sup>2</sup></b>
1	16.00	15.70	0.30	0.0900
2	15.90	15.70	0.20	0.0400
3	15.90	15.70	0.20	0.0400
4	16.00	15.70	0.30	0.0900
5	16.00	15.70	0.30	0.0900

n = 5

t(0.975) = 2.776

Mean Ref. Method Value	<b>15.7000</b> <i>RM</i>
Sum of Differences	<b>1.3000</b> <i>Xi</i>
Arithmetic Mean Difference	<b>0.2600</b> <i>Xi ave</i>
Sum of Differences Squared	<b>0.3500</b> <i>Xi<sup>2</sup></i>
Standard Deviation	<b>0.0548</b> <i>sd</i>
2.5% Error Conf. Coef	<b>0.0680</b> <i>CC</i>
Calibration Error	<b>0.3280</b> <i>percent</i>

## OPACITY MID FILTER AUDIT

### Accuracy Determination

Primary Energy

E. Chicago, IN

Stack 201

8/26/2019

MID FILTER RUN	Opacity Output from Recording Device	Audit Filter Value Corrected for Path Length (SCF)	(FILTER-MONITOR) Difference	Difference <sup>2</sup>
		<b>RM</b>	<b>(X<sub>i</sub>)</b>	<b>X<sub>i</sub><sup>2</sup></b>
1	26.50	25.90	0.60	0.3600
2	26.50	25.90	0.60	0.3600
3	26.50	25.90	0.60	0.3600
4	26.50	25.90	0.60	0.3600
5	25.00	25.90	-0.90	0.8100

n = 5

t(0.975) = 2.776

Mean Ref. Method Value	<b>25.9000</b> <i>RM</i>
Sum of Differences	<b>1.5000</b> <i>Xi</i>
Arithmetic Mean Difference	<b>0.3000</b> <i>Xi ave</i>
Sum of Differences Squared	<b>2.2500</b> <i>Xi<sup>2</sup></i>
Standard Deviation	<b>0.6708</b> <i>sd</i>
2.5% Error Conf. Coef	<b>0.8328</b> <i>CC</i>
Calibration Error	<b>1.1328</b> <i>percent</i>

## OPACITY HIGH FILTER AUDIT

### Accuracy Determination

Primary Energy

E. Chicago, IN

Stack 201

8/26/2019

HIGH FILTER RUN	Opacity Output from Recording Device	Audit Filter Value Corrected for Path Length (SCF)	(FILTER-MONITOR) Difference	Difference <sup>2</sup>
		RM	(X <sub>i</sub> )	X <sub>i</sub> <sup>2</sup>
1	49.20	49.30	-0.10	0.0100
2	49.20	49.30	-0.10	0.0100
3	49.20	49.30	-0.10	0.0100
4	49.20	49.30	-0.10	0.0100
5	49.20	49.30	-0.10	0.0100

n = 5

t(0.975) = 2.776

Mean Ref. Method Value	<b>49.3000</b> <i>RM</i>
Sum of Differences	<b>-0.5000</b> <i>Xi</i>
Arithmetic Mean Difference	<b>-0.1000</b> <i>Xi ave</i>
Sum of Differences Squared	<b>0.0500</b> <i>Xi<sup>2</sup></i>
Standard Deviation	<b>0.0000</b> <i>sd</i>
2.5% Error Conf. Coef	<b>0.0000</b> <i>CC</i>
Calibration Error	<b>0.1000</b> <i>percent</i>

**OPACITY FILTER AUDIT**

**\* 6-minute Averages \***

**Accuracy Determination**

Primary Energy

E. Chicago, IN

Stack 201

8/26/2019

<b>6 Minute Averages</b>	<b>Opacity Output from Recording Device</b>	<b>Audit Filter Value Corrected for Path Length (SCF)</b>	<b>(FILTER-MONITOR) Difference</b>	<b>Opacity Error</b>
		RM	(Xi)	
<b>ZERO</b>	0.00	0.00	0.00	<b>0.00</b>
<b>LOW</b>	16.00	15.70	0.30	<b>0.30</b>
<b>MID</b>	26.50	25.90	0.60	<b>0.60</b>
<b>HIGH</b>	49.30	49.30	0.00	<b>0.00</b>
<b>ZERO</b>	0.10	0.00	0.10	<b>0.10</b>



**AUDIT DATA**

# Opacity Report

East Chicago, IN

08/26/2019 - 08/26/2019

08/26/2019

STACK 201

Hour	Opac, % Minutes 0 - 5	Opac, % Minutes 6 - 11	Opac, % Minutes 12 - 17	Opac, % Minutes 18 - 23	Opac, % Minutes 24 - 29	Opac, % Minutes 30 - 35	Opac, % Minutes 36 - 41	Opac, % Minutes 42 - 47	Opac, % Minutes 48 - 53	Opac, % Minutes 54 - 59
0	2.4 SVC	2.4 SVC	2.5 SVC	2.4 SVC	2.4 SVC	2.4 SVC	2.4 SVC	2.3 SVC	2.4 SVC	2.5 SVC
1	2.5 SVC	2.4 SVC	2.5 SVC	2.5 SVC	2.5 SVC	2.4 SVC	2.4 SVC	2.5 SVC	2.5 SVC	2.5 SVC
2	2.5 SVC	2.5 SVC	2.8 SVC	2.6 SVC	2.7 SVC	2.6 SVC	2.5 SVC	2.5 SVC	2.4 SVC	2.5 SVC
3	2.5 SVC	2.4 SVC	2.4 SVC	2.5 SVC	2.5 SVC	2.5 SVC	2.7 SVC	2.9 SVC	2.6 SVC	2.5 SVC
4	2.6 SVC	2.5 SVC	2.5 SVC	2.5 SVC	2.5 SVC	2.5 SVC	2.5 SVC	2.6 SVC	2.5 SVC	2.5 SVC
5	2.8 SVC	2.8 SVC	2.6 SVC	2.5 NSA	2.6 SVC	2.4 SVC	2.4 SVC	2.4 SVC	2.4 SVC	2.4 SVC
6	2.4 SVC	2.2 SVC	2.2 SVC	2.1 SVC	2.3 SVC	2.2 SVC	2.1 SVC	2.2 SVC	2.2 SVC	2.2 SVC
7	2.2 SVC	2.2 SVC	2.2 SVC	2.1 SVC	2.1 SVC	2.2 SVC	2.2 SVC	2.1 SVC	2.1 SVC	2.1 SVC
8	2.1 SVC	2.1 SVC	2.1 SVC	2.1 SVC	2.1 SVC	2.0 SVC	2.0 SVC	2.1 SVC	2.0 SVC	2.0 SVC
9	2.0 SVC	2.1 SVC	2.1 SVC	2.2 NSA	2.0 MOS	28.3 MOS	17.5 MOS	0.0 MOS	0.0 MOS	11.8 MOS
10	16.0 MOS	21.5 MOS	26.5 MOS	29.7 MOS	49.3 MOS	49.3 MOS	2.8 MOS	0.1 MOS	3.6 MOS	

Status Code Definitions

MOS = MONITOR OUT OF SERVICE      NSA = NO SAMPLE AVAILABLE      SVC = MONITOR IN SERVICE

The average opacity period average for the day was 2.4 % for 92 periods of valid data.

The Fan was in operation for 109 periods

The maximum opacity period average for the day was 2.9 %

There were 17 periods of invalid data

**08/26/2019 OPACITY, %**

09:29		
09:29:00	0.0	MOS
09:29:02	0.0	MOS
09:29:04	0.0	MOS
09:29:06	0.0	MOS
09:29:08	0.0	MOS
09:29:11	0.0	MOS
09:29:13	0.0	MOS
09:29:15	0.0	MOS
09:29:17	0.0	MOS
09:29:19	0.0	MOS
09:29:21	0.0	MOS
09:29:23	0.0	MOS
09:29:25	0.0	MOS
09:29:27	0.0	MOS
09:29:29	0.0	MOS
09:29:31	0.0	MOS
09:29:33	0.0	MOS
09:29:35	0.0	MOS
09:29:37	0.0	MOS
09:29:39	1.4	MOS
09:29:41	4.8	MOS
09:29:43	8.3	MOS
09:29:45	12.3	MOS
09:29:47	16.0	MOS
09:29:49	16.0	MOS
09:29:51	16.0	MOS
09:29:53	16.0	MOS
09:29:55	16.0	MOS
09:29:57	16.0	MOS
09:29:59	16.0	MOS

Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**08/26/2019 OPACITY, %**

09:30		
09:30:01	16.0	MOS
09:30:03	16.0	MOS
09:30:05	16.0	MOS
09:30:07	16.0	MOS
09:30:09	16.0	MOS
09:30:11	16.0	MOS
09:30:13	14.8	MOS
09:30:15	17.5	MOS
09:30:17	20.1	MOS
09:30:19	22.7	MOS
09:30:21	26.5	MOS
09:30:23	26.5	MOS
09:30:25	26.5	MOS
09:30:27	26.5	MOS
09:30:29	26.5	MOS
09:30:31	26.5	MOS
09:30:33	26.5	MOS
09:30:35	26.5	MOS
09:30:37	26.5	MOS
09:30:39	26.5	MOS
09:30:41	26.5	MOS
09:30:43	26.5	MOS
09:30:45	26.5	MOS
09:30:47	26.5	MOS
09:30:49	23.1	MOS
09:30:51	25.8	MOS
09:30:53	31.5	MOS
09:30:55	38.6	MOS
09:30:57	49.1	MOS
09:30:59	49.2	MOS

Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**08/26/2019 OPACITY, %**

09:31		
09:31:01	49.2	MOS
09:31:03	49.2	MOS
09:31:05	49.2	MOS
09:31:07	49.2	MOS
09:31:09	49.2	MOS
09:31:11	49.2	MOS
09:31:13	49.2	MOS
09:31:15	49.2	MOS
09:31:17	49.2	MOS
09:31:19	49.2	MOS
09:31:21	49.2	MOS
09:31:23	40.6	MOS
09:31:25	32.3	MOS
09:31:27	24.0	MOS
09:31:29	15.7	MOS
09:31:31	15.9	MOS
09:31:33	15.9	MOS
09:31:35	15.9	MOS
09:31:37	16.0	MOS
09:31:39	16.0	MOS
09:31:41	16.0	MOS
09:31:43	15.9	MOS
09:31:45	15.9	MOS
09:31:47	15.9	MOS
09:31:49	15.9	MOS
09:31:51	16.0	MOS
09:31:54	13.4	MOS
09:31:56	15.8	MOS
09:31:58	18.0	MOS

Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**08/26/2019 OPACITY, %**

Time	Opacity (%)	Status
09:32		
09:32:00	20.6	MOS
09:32:02	26.2	MOS
09:32:04	26.5	MOS
09:32:06	26.5	MOS
09:32:08	26.5	MOS
09:32:10	26.5	MOS
09:32:12	26.5	MOS
09:32:14	26.5	MOS
09:32:16	26.5	MOS
09:32:18	26.5	MOS
09:32:20	26.5	MOS
09:32:22	26.5	MOS
09:32:24	26.5	MOS
09:32:26	26.5	MOS
09:32:28	26.5	MOS
09:32:30	<b>26.5</b>	MOS
09:32:32	23.4	MOS
09:32:34	29.4	MOS
09:32:36	35.0	MOS
09:32:38	40.7	MOS
09:32:40	49.2	MOS
09:32:42	49.2	MOS
09:32:44	49.2	MOS
09:32:46	49.2	MOS
09:32:48	49.2	MOS
09:32:50	49.2	MOS
09:32:52	49.2	MOS
09:32:54	49.2	MOS
09:32:56	49.2	MOS
09:32:58	49.2	MOS

Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**08/26/2019 OPACITY, %**

09:33		
09:33:00	49.2	MOS
09:33:02	49.2	MOS
09:33:04	45.4	MOS
09:33:06	34.9	MOS
09:33:08	26.5	MOS
09:33:10	18.2	MOS
09:33:12	12.9	MOS
09:33:14	15.9	MOS
09:33:16	15.9	MOS
09:33:18	16.0	MOS
09:33:20	16.0	MOS
09:33:22	16.0	MOS
09:33:24	16.0	MOS
09:33:26	16.0	MOS
09:33:28	16.0	MOS
09:33:30	15.9	MOS
09:33:32	16.0	MOS
09:33:34	15.9	MOS
09:33:36	15.9	MOS
09:33:38	15.2	MOS
09:33:40	14.0	MOS
09:33:42	16.4	MOS
09:33:44	19.7	MOS
09:33:46	23.1	MOS
09:33:48	26.5	MOS
09:33:50	26.5	MOS
09:33:52	26.5	MOS
09:33:54	26.5	MOS
09:33:56	26.5	MOS
09:33:58	26.5	MOS

Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**08/26/2019 OPACITY, %**

09:34		
09:34:00	26.5	MOS
09:34:02	26.5	MOS
09:34:04	26.5	MOS
09:34:06	26.4	MOS
09:34:08	26.4	MOS
09:34:10	26.4	MOS
09:34:12	26.5	MOS
09:34:14	26.5	MOS
09:34:16	26.5	MOS
09:34:18	26.5	MOS
09:34:20	26.5	MOS
09:34:22	23.2	MOS
09:34:24	25.8	MOS
09:34:26	32.9	MOS
09:34:28	38.5	MOS
09:34:30	46.2	MOS
09:34:32	49.2	MOS
09:34:35	49.2	MOS
09:34:37	49.2	MOS
09:34:39	49.2	MOS
09:34:41	49.2	MOS
09:34:43	49.2	MOS
09:34:45	49.2	MOS
09:34:47	49.2	MOS
09:34:49	49.2	MOS
09:34:51	49.2	MOS
09:34:53	49.2	MOS
09:34:55	49.2	MOS
09:34:57	43.2	MOS
09:34:59	34.1	MOS

Status Code Definitions

MOS = MONITOR OUT OF SERVICE



**08/26/2019 OPACITY, %**

09:35		
09:35:01	25.8	MOS
09:35:03	17.5	MOS
09:35:05	15.1	MOS
09:35:07	16.0	MOS
09:35:09	16.0	MOS
09:35:11	16.0	MOS
09:35:13	16.0	MOS
09:35:15	16.0	MOS
09:35:17	16.0	MOS
09:35:19	16.0	MOS
09:35:21	16.0	MOS
09:35:23	16.0	MOS
09:35:25	16.0	MOS
09:35:27	16.0	MOS
09:35:29	15.8	MOS
09:35:31	14.6	MOS
09:35:33	17.2	MOS
09:35:35	19.9	MOS
09:35:37	23.3	MOS
09:35:39	26.5	MOS
09:35:41	26.5	MOS
09:35:43	26.5	MOS
09:35:45	26.5	MOS
09:35:47	26.5	MOS
09:35:49	26.5	MOS
09:35:51	26.5	MOS
09:35:53	26.5	MOS
09:35:55	26.5	MOS
09:35:57	26.5	MOS
09:35:59	26.5	MOS

Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**08/26/2019 OPACITY, %**

09:36		
09:36:01	26.5	MOS
09:36:03	23.4	MOS
09:36:05	30.5	MOS
09:36:07	36.2	MOS
09:36:09	41.9	MOS
09:36:11	49.2	MOS
09:36:13	49.2	MOS
09:36:15	49.2	MOS
09:36:17	49.2	MOS
09:36:19	49.2	MOS
09:36:21	49.2	MOS
09:36:23	49.2	MOS
09:36:25	49.2	MOS
09:36:27	49.2	MOS
09:36:29	49.2	MOS
09:36:31	49.2	MOS
09:36:33	49.2	MOS
09:36:35	49.2	MOS
09:36:37	45.2	MOS
09:36:39	34.9	MOS
09:36:41	26.5	MOS
09:36:43	18.0	MOS
09:36:45	13.6	MOS
09:36:47	15.7	MOS
09:36:49	15.8	MOS
09:36:51	15.9	MOS
09:36:53	16.0	MOS
09:36:55	16.0	MOS
09:36:57	16.0	MOS
09:36:59	16.0	MOS

Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**08/26/2019 OPACITY, %**

09:37

09:37:01	16.0	MOS
09:37:03	16.0	MOS
09:37:05	16.0	MOS
09:37:07	16.0	MOS
09:37:09	15.9	MOS
09:37:11	15.9	MOS
09:37:13	16.0	MOS
09:37:15	13.0	MOS
09:37:18	15.5	MOS
09:37:20	18.1	MOS
09:37:22	20.1	MOS
09:37:24	24.6	MOS
09:37:26	26.5	MOS
09:37:28	26.5	MOS
09:37:30	26.5	MOS
09:37:32	26.5	MOS
09:37:34	26.5	MOS
09:37:36	26.5	MOS
09:37:38	26.5	MOS
09:37:40	26.5	MOS
09:37:42	26.5	MOS
09:37:44	26.5	MOS
09:37:46	26.5	MOS
09:37:48	26.5	MOS
09:37:50	25.6	MOS
09:37:52	25.0	MOS
09:37:54	30.7	MOS
09:37:56	36.3	MOS
09:37:58	42.9	MOS

## Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**08/26/2019 OPACITY, %**

Time	Opacity (%)	Status
09:38		
09:38:00	49.2	MOS
09:38:02	49.2	MOS
09:38:04	49.2	MOS
09:38:06	49.2	MOS
09:38:08	49.2	MOS
09:38:10	49.2	MOS
09:38:12	49.2	MOS
09:38:14	49.2	MOS
09:38:16	49.2	MOS
09:38:18	49.2	MOS
09:38:20	49.2	MOS
09:38:22	49.2	MOS
09:38:24	49.2	MOS
09:38:26	49.2	MOS
09:38:28	41.8	MOS
09:38:30	34.6	MOS
09:38:32	26.3	MOS
09:38:34	18.0	MOS
09:38:36	15.7	MOS
09:38:38	16.0	MOS
09:38:40	15.9	MOS
09:38:42	15.9	MOS
09:38:44	15.9	MOS
09:38:46	13.3	MOS
09:38:48	10.0	MOS
09:38:50	12.5	MOS
09:38:52	15.8	MOS
09:38:54	21.5	MOS
09:38:56	26.5	MOS
09:38:58	26.5	MOS

Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**08/26/2019 OPACITY, %**


09:39		
09:39:00	25.1	MOS
09:39:02	21.3	MOS
09:39:04	26.6	MOS
09:39:06	32.6	MOS
09:39:08	39.7	MOS
09:39:10	49.2	MOS
09:39:12	49.2	MOS
09:39:14	43.9	MOS
09:39:16	31.5	MOS
09:39:18	19.2	MOS
09:39:20	6.9	MOS
09:39:22	0.0	MOS
09:39:24	0.0	MOS
09:39:26	0.0	MOS

---

Status Code Definitions

MOS = MONITOR OUT OF SERVICE

**APPENDIX B**  
**AUDIT FILTER CERTIFICATION SHEETS**



# Monitoring | Solutions

*Leaders in Environmental Monitoring Systems & Services*

4404 Guion Rd., Indianapolis, Indiana 46254 Tel: 317.856.9400

## REPORT OF CERTIFICATION OF NEUTRAL DENSITY AUDIT FILTERS

Date of Filter Certification: **June 30, 2019**

Date of Filter Expiration: **December 30, 2019**

**Filter Set - LRG**

Audit Device / Filter Slot Angle of Incidence

**10 Degrees**

Path-Length Correction

**1.000 (Straight Stack)**

**Table 1: Individual Filter Certification Data**

Serial Number	Opacity Value (%)	Transmittance (%)	Previous Opacity (%)	Change in Opacity (%)
JK20	7.6	92.4	7.6	0.0
YB11	15.7	84.3	15.7	0.0
YB12	25.9	74.1	26.0	0.1
ZA44	49.3	50.7	49.3	0.0

Laboratory-Based Transmissometer

Operator

**\*See second page for Instrument Information and Details of Certification\***