
FIRE PREVENTION AND BUILDING SAFETY COMMISSION
Department of Homeland Security

Written Interpretation of the State Building Commissioner

Interpretation #: CEB-2018-06-2005-IRC-P2719.1

Building or Fire Safety Law Interpreted

[675 IAC 14-4.3](#), the 2005 Indiana Residential Code, P2719.1 Minimum size. Floor drains shall have waste outlets not less than 2 inches (51 mm) in diameter and shall be provided with a removable strainer with an open area of at least two-thirds of the cross-sectional area of the drain line to which it connects.

Interpretation of the State Building Commissioner

The IRC section in question does not require the installation of a floor drain. It only provides minimum design requirements for such a fixture.

Posted: 04/17/2019 by Legislative Services Agency

An [html](#) version of this document.