

April 2, 2015

Pamela Walters
Director, Code Services Section
Department of Homeland Security
6500 Westfield 402 W. Washington Street, Room W246
Indianapolis, Indiana 46204

ETA4U, 10202 E Washington Street
Appeal of Local Order - IC 22-12-7-12

RTM
CONSULTANTS, INC.

BUILDING CODES

FIRE PROTECTION

JCAHO/CMS/HFAP


Dear Pamela,

On behalf of the owner, this letter is a petition for review to the Fire Prevention and Building Safety Commission regarding the enclosed Notice of Violation from the Indianapolis Fire Department regarding exit markings in the ETA4U space at Washington Square Mall, 10202 E Washington Street. The owner contends that the proposed exit signs comply with Sec. 1011.1, IFC and the requirements in Sec. 411.7, IFC do not apply to this space as it is not a Special Amusement Building. The IFD Order states that exit markings must comply with Sec. 411.7, IFC and that plans are required to be submitted for Special Amusement Building exiting.

Thank you for your attention to this matter. If you have any questions, please let us know.

Very truly yours,

RTM Consultants, Inc.



Carrie A. Ballinger
Associate

cc: Scott Waterman - ETA4U
Margie Bovard - Indianapolis Fire Department



INDIANAPOLIS FIRE DEPARTMENT
1200 Madison Avenue
Indianapolis, IN 46225
Office (317) 327-5529
IFD PLAN REVIEW



Occupant Name:	EXETA4U	Inspection Date:	3/31/2015
Address:	10202 East Washington Street	InspectionType:	Plan Review - Remodel
City:	Indianapolis	Inspected By:	Margie Bovard (317) 327-5529 margie.bovard@indy.gov
Zip Code:	46229		

Pass Fail N/A

Indiana Fire Code 2014

Floor 1

Section 1011

Exit Signs

1011.1 Where required.

Exits and exit access doors shall be marked by an approved exit sign readily visible from a direction of egress travel. The path of egress travel to exits and within exits shall be marked by readily visible exit signs to clearly indicate the direction of egress travel in cases where exit or the path of egress travel is not immediately visible to the occupants. Intervening means of egress doors within exits shall be marked by exit signs. Exit sign placement shall be such that no point in an exit access corridor or exit passageway is more than 100 feet (30 480 r or the listed viewing distance for the sign, whichever is less, from the nearest visible exit s Please submit exit sign specifications

Inspector Comments:

Exit marking shall be in accordance with IFC 2012, Section 411.7. Please submit plans for Special Amusement Building exiting.

Inspector will return on or after 3/31/2015

The hazards and/or violations listed in this report have been found to exist. Violations are subject to immediate correction.

INSPECTION COMPLIANCE AFFIDAVIT

THIS ENTIRE FORM MUST BE RETURNED NO LATER THAN 30 DAYS AFTER INSPECTION

The undersigned hereby represents that by signing this certificate and returning it to the Indianapolis Fire Department within 30 days from the date of the inspection via E-mail, US mail, or fax, the code violations listed above have been corrected. The undersigned acknowledges that the Indianapolis Fire Department may determine not to conduct a reinspection, and may fully rely upon the representation that the code violations have been corrected.