

INDIANA FIRE PREVENTION AND BUILDING SAFETY COMMISSION

Friday, March 19, 2021
By Electronic Mail

Kevin Yancey
Petitioner
Madison Consolidated Schools
2421 Wilson Ave
Madison IN, 47250
kyancey@madison.k12.in.us


**Re: Petition for Administrative Review – IDHS Sanctions Order No. 589-792 –
Madison Consolidated High School**

Dear Mr. Yancey:

The Indiana Fire Prevention and Building Safety Commission (Commission) is in receipt of your electronically-filed petition for administrative review of Indiana Department of Homeland Security (IDHS) Sanctions Order No. 589-792 – Madison Consolidated High School, submitted on Friday, March 19, 2021. Pursuant to the requirements of Indiana Code § 4-21.5-3-7, your petition for administrative review is hereby granted by the Commission.

Your petition will now be forwarded to the Indiana Office on Administrative Law Proceedings (OALP) to be assigned to the Commission's administrative law judge. OALP or the judge will contact you directly to make arrangements for further proceedings. Should you have any questions, you may contact the Indiana Department of Homeland Security's deputy general counsel assigned to this matter, Justin Guedel, at jguedel@dhs.in.gov or (317) 234-9515.

Sincerely,



Douglas J. Boyle, Director
Indiana Fire Prevention and Building Safety Commission
Indiana Department of Homeland Security
Indiana Government Center South, Room E-208
302 W. Washington Street
Indianapolis, IN 46204
dboyle@dhs.in.gov

Enclosure

cc: Justin K. Guedel, IDHS Deputy General Counsel – representing the Respondent
(by electronic mail)

Bryston Sprecher, Administrative Assistant of the Indiana Fire Prevention and Building Safety Commission (by electronic mail)

From: [DHS Legal Mailbox](#)
To: [Guedel, Justin K](#); [Boyle, Douglas J \(DHS\)](#); [Sprecher, Bryston](#)
Subject: FW: Petition for Review
Date: Friday, March 19, 2021 3:30:10 PM
Attachments: [68379161_Fire inspection.pdf](#)

From: noreply@formstack.com
Sent: Friday, March 19, 2021 7:29:44 PM (UTC+00:00) Monrovia, Reykjavik
To: DHS Legal Mailbox
Subject: Petition for Review

**** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ****



Formstack Submission For: [petition for review](#)

Submitted at 03/19/21 3:29 PM

Individual Name:	Kevin Yancey
Business Name: :	Madison Consolidated Schools
Phone Number:	(812) 274-8001
Email Address:	kyancey@madison.k12.in.us
Mailing Address:	2421 Wilson Ave Madison IN, 47250 Madison, IN 47250
Are you represented by an attorney?:	No

Attorney Name:	
Firm:	
Phone Number:	
Email Address:	
Mailing Address:	
Order Number:	3
Facility Device Boiler ID:	Madison Consolidated High School
Date Order Received:	Mar 11, 2021
How did you receive the Order? :	Email
Entity Issuing Order:	Fire Prevention and Building Safety Commission
Entity Name:	
Upload Order:	View File
Was this order specifically directed to you?:	Yes
Explain:	The report came to my office email.
Explain:	

Have you been aggrieved or adversely affected by the order?:

Yes

Explain:

The covid virus has made fixing issues in the district slow in receiving parts and labor.

Explain:

If the order was not specifically directed to you and you have not been aggrieved or adversely affected by the order, are you entitled to review under some other law? :

What law?:

I request review of the entire order described above:

Yes

If you are not requesting review of the entire order, what is the scope of your request?:

I request a stay of effectiveness:

Yes

What is the basis of your challenge? :

I would encourage the Indiana Department of Homeland Security Drop the fees at Madison Consolidated High School. Madison Consolidated Schools has worked diligently to fix the items list by the fire inspector. We need more time to fix the issues related to the locker room and the doors in A wing hallway; the covid virus has created issues with receiving materials and man power time. MCHS has fixed these items and has been in contact with Mr. Cole. We thank you for looking into this issue.

What is your desired outcome? :

MCS would like the fees removed.

Additional information in support of my request:

Additional Attachments:

Additional Attachments:

Additional Attachments:


**Report of inspection**

Indiana Department of Homeland Security
 302 W. Washington Street, Room E208
 Indianapolis, IN 46204
 Phone: 317-232-2222

Permit Number	Sanction Number
SC3309C	589-792

Visit us at: <http://www.in.gov/dhs>

Date	03/11/2021	Type	Sanctions
Results	Sanctions		
Location	Owner		
Name	MADISON CONSOLIDATED HIGH SCH	Name	CANAAN SCHOOL SYSTEM
Street	743 CLIFTY DRIVE	Street	8775 NORTH CANAAN MAIN STREET
City	MADISON	City	CANAAN
Zip	47250	Zip	47224
Inspector	Permit		
Name	Kenneth Cole	State Number	SC3309C
Email	KeCole@dhs.IN.gov	Type	School
Phone	317-417-3720		

**Notice of Violations**

#	Code	Description	Order	Correct By	Fee
	Sec. 703.2.3 2014 Edition IFC 675 IAC 22-2.5	Swinging fire doors shall close from the full-open position and latch automatically. The door closer shall exert enough force to close and latch the door from any partially open position.	Fire doors in main entry A wing shall close and latch properly.	03/09/2021 <i>Mark done</i>	\$250.00
	Sec. 1030.4 2014 Edition IFC 675 IAC 22-2.5	Exit signs shall be installed and maintained in accordance with Section 1011. Decorations, furnishings, equipment or adjacent signage that impairs the visibility of exit signs, creates confusion or prevents identification of the exit shall not be allowed.	*Exit signs shall be visible and not be hidden by signs in main gym. ** Boys locker room shall have exit sign.	03/09/2021 <i>George</i>	\$250.00
	Sec. 1008.1.9.1 2014 Edition IFC 675 IAC 22-2.5	Door handles, pulls, latches, locks and other operating devices on doors required to be accessible by Chapter 11 of the International Building Code shall not require tight grasping, tight pinching or twisting of the wrist to operate.	The exit door on the boys locker room shall not require twisting of the wrist to open. Twist lock is on exit door.	03/09/2021 <i>dowe</i>	\$250.00