



Requirements for Seasonal Systems

WHO DOES THIS REFERENCE GUIDE APPLY TO?

SEASONAL SYSTEMS – A SEASONAL SYSTEM IS DEFINED AS A NONCOMMUNITY WATER SYSTEM THAT IS NOT OPERATED AS A PUBLIC WATER SYSTEM (PWS) ON A YEAR-ROUND BASIS AND STARTS-UP AND SHUTS-DOWN AT THE BEGINNING AND END OF EACH OPERATING SEASON. EXAMPLES INCLUDE CAMPGROUNDS, FAIRGROUNDS, SEASONAL FOOD SERVICE FACILITIES, GOLF COURSES, AND SKI AREAS.

RTCR

What to Do?

Step 1

Conduct start-up procedures

Step 2

Complete certification forms

Step 3

Maintain good water quality

Step 4

Complete shutdown procedures



Additional RTCR Reference Guides:

- Requirements for Small Systems on Monthly Monitoring
- Requirements for Small Systems on Quarterly Monitoring
- Repeat Monitoring Requirements for Small Systems
- Level 1 & Level 2 Assessments and Corrective Actions

ATTENTION!

STARTING APRIL 1, 2016, all seasonal systems must complete the state required start-up procedures before serving water to the public. Your water system must complete and submit the state certification form confirming completion of these start-up procedures.

STEP 1: CONDUCT START-UP PROCEDURES



You must conduct IDEM start-up procedures before delivering drinking water to your customers. Start-up procedures help reduce the presence of harmful bacteria in water. The checklist is available at <http://www.in.gov/idem/cleanwater/2494.htm>

Flush all pipes until the water is clear

Flushing the pipe lines in all areas of your water system helps remove buildup and dirty water that has gathered during the off season. Flushing the pipes helps disinfectant (where applicable) work more effectively to kill bacteria and inactivate viruses.

Inspect and Repair

Consider having a qualified water system professional inspect and repair your water system before you deliver water to your customers. Some parts of your water system may have broken down or become worn out during the off season. This can create a situation where bacteria can enter the drinking water. You can find a list of state certified water system professionals, to help with finding any defects at your water system, on this website: <http://www.in.gov/idem/cleanwater/2494.htm>

Clean all water storage tanks

Drain and clean the tanks before delivering water to your customers. Harmful sediments may build up over time inside and along the walls of the water tanks. It is recommended that the tank be inspected and cleaned regularly. Contact IDEM for information about proper procedures for inspecting a tank.

Disinfect

Kill harmful bacteria and inactivate viruses by adding a disinfectant or by making sure the adequate disinfectant residual is present in all areas of your water pipes. Your system should be flushed thoroughly. Be sure to keep the highly chlorinated water away from surface water bodies such as lakes, streams, and ponds, as well as septic systems. Remember, you may not deliver water to your customers until proper disinfecting and flushing of your system is completed. Check our website <http://www.in.gov/idem/cleanwater/2494.htm> or call IDEM 1-317-234-7430 to get more information about how to disinfect your water system.

Collect Samples

Collect water samples and have them tested for the presence of bacteria and chlorine residuals at a state certified lab, after flushing, cleaning, disinfecting, and repairing your water system. Also, sample and test to determine if the adequate amount of disinfectant residual is present to help provide safer drinking water. You should find out your sample results before delivering water to your customers. Check our website <http://www.in.gov/idem/cleanwater/2494.htm> or call IDEM 1-317-234-7430 to get more information about disinfectant residual levels.

STEP 2: COMPLETE SEASONAL SYSTEM START-UP PROCEDURES CHECKLIST EACH YEAR BEFORE DELIVERING WATER TO YOUR CUSTOMERS

CONTACT IDEM if you need help understanding or following the Start-Up Procedures.

- **PERFORM AND COMPLETE** the items in the start-up procedures checklist. The checklist is available at <http://www.in.gov/idem/cleanwater/2494.htm>
- **SUBMIT** Seasonal System Start-Up Procedures Checklist to IDEM.

WHEN YOU SIGN AND SUBMIT this form, you are certifying that you have completed all of the start-up procedures, including:

- Flushed all pipes.
- Cleaned all water storage tanks (if applicable).
- Inspected water system.
- Repaired water system (if applicable).
- Collected samples to test for bacteria.



SEASONAL SYSTEMS ARE REQUIRED TO COLLECT **MONTHLY** TOTAL COLIFORM SAMPLES DURING ALL MONTHS OF OPERATION.

FOR ASSISTANCE CONTACT :

IDEM - Drinking Water Branch
100 N Senate Ave. Rm 1201
Indianapolis, IN 46204

FAX: 1-317-234-7462
PHONE: 1-317-234-7430

EMAIL: DWBMGR@IDEM.IN.GOV

STEP 3: MAINTAIN GOOD WATER QUALITY AND A GOOD REPUTATION WITH YOUR CUSTOMERS

If your water system does not complete all of the start-up procedures, you must notify your customers that your water system had a drinking water violation for failure to complete start-up procedures and tell them of any possible health risks.

CONTACT IDEM for information on the proper public notification procedures (including language you must use), and timing.

STEP 4: COMPLETE SHUTDOWN PROCEDURES

Similar to start-up procedures, completing shutdown procedures at the end of your business season will help you minimize repairs to the water system when your water system opens up again next season. In general, your shutdown procedures should include, but are not limited to:

- Inspect your entire system and look for problems and damage that needs attention or repairs.
- Turn off the power to your water supply pump and all treatment systems.
- If there is potential for your pressure tank or storage tank to freeze, drain it. If there is no potential for your tanks to freeze, you may choose to leave them full.
- Drain all of the water from your internal plumbing.
- Protect your distribution system by not leaving taps open in the off season.