

Area Source Existing, Emergency Use, CI Stationary Engines

Requirements	40 CFR 63 Subpart ZZZZ
Must have a non-resettable hour meter and record hours of operation.	§ 63.6625(f)
Change oil and filter every 500 hours of operation or annually. An oil analysis program may be used instead of the prescribed oil change frequency.	Table 2d to Subpart ZZZZ of Part 63
Inspect air cleaner every 1000 hours of operation or annually.	Table 2d to Subpart ZZZZ of Part 63
Inspect all hoses and belts every 500 hours of operation or annually and replace as necessary.	Table 2d to Subpart ZZZZ of Part 63
Operate and maintain the engine per the manufacturer's instructions or owner developed maintenance plan.	§ 63.6625
Keep records of maintenance for five (5) years.	§ 63.6660
Purchase and use ultra low sulfur diesel fuel by January 1, 2015. Existing inventories of fuel may be depleted.	§ 63.6604
Compliance date of May 3, 2013.	§ 63.6595