

Indiana Department of Labor

Indiana Occupational Safety and Health Administration
402 West Washington St - Room W195
Indianapolis, IN 46204
Phone: 317-232-1979 FAX: (317)233-3790



Certified Mail # 7016 3010 0001 0290 4600 10-11-17 JFD

Safety Order and Notification of Penalty

To:

James Anderson DBA James Anderson Painting
9401 Tower Bridge Road, Suite B
Indianapolis, IN 46240

Inspection Number: 318088614**CSHO ID:** X4033**Optional Report No.:** 00117**Inspection Date(s):** 6/27/2017 - 9/12/2017**Issuance Date:** 10/11/2017**Inspection Site:**

930 Alabama Street
Indianapolis, IN 46202

The violation(s) described in this Safety Order and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.

An inspection of your place of employment has revealed conditions which we believe do not comply with the provisions of the Indiana Occupational Safety and Health Act (Indiana Code Chapter 22-8-1.1) or the standards or rules adopted thereunder. Accordingly, enclosed please find safety order(s) and notification(s) of penalty describing such violation(s) with references to applicable standards, rules, or provisions of the statute and stating the amount of any penalty(ies).

Informal Conference - Please be advised that it may be possible to informally settle any potential dispute without initiating the more elaborate proceedings brought on by a petition for review. Prior to filing a petition for review, you may request an informal conference concerning any of the results of the inspection (safety orders, penalties, abatement dates, etc.) by contacting the Indiana Department of Labor/IOSHA, preferably by telephone, in a prompt manner. Please be advised that a request for an informal conference cannot extend the fifteen working day period for filing a petition for review. Informal conferences frequently resolve any possible disputes, and therefore you are urged to take advantage of this opportunity. Because of the limited time period and in order to facilitate scheduling, any requests for an informal conference should be made promptly upon your receipt of the safety order(s) and notification(s) of penalty.

Right to Contest - You are hereby also notified that you are entitled to seek administrative review of the safety order(s), penalty(ies), or both by filing a written petition for review at the above address postmarked within fifteen working days of your receipt of the safety order(s) and notification(s) of penalty. ("Working days" means Mondays through Fridays, but does not include Saturdays, Sundays, legal holidays under a state statute or days on which the Indiana Department of Labor's offices are closed during regular business hours). If you do not file such a petition for review (contest), the safety order(s)

and penalty(ies) shall be deemed final orders of the Board of Safety Review and not subject to review by any court or agency. The issuance of a safety order does not constitute a finding that a violation has occurred unless no petition for review is filed, or if a petition for review (contest) is filed, it must contain a statement of its basis and should reference the above inspection number. Upon receipt of your petition for review, we will affirm, amend or dismiss the safety order(s) and notification(s) of penalty. If we affirm, your petition for review will be granted (unless it was not timely) and the dispute will be certified by the Board of Safety Review for further proceedings. The Board of Safety Review is an independent agency appointed by the governor with authority to conduct hearings and to issue decisions concerning disputed safety order(s) and notification(s) of penalty. If we amend the safety order(s) or notification(s) of penalty, your petition for review shall be deemed moot. However, you will then be given an opportunity to file a petition for review concerning the amended safety order(s) and notification(s) of penalty.

Please be advised that an employee or representative of employees may file a petition for review to contest the reasonableness of the time stated in the safety order(s) for the abatement of any violation.

Posting - Upon receipt of any safety order(s) you are required to post such safety order(s), or a copy thereof, unedited, at or near each place an alleged violation referred to in the safety order(s) occurred. However, if your operations are such that it is not practicable to post the safety order(s) at or near each place of alleged violation, such safety order(s) shall be posted, unedited, in a prominent place where it will be readily observable by all affected employees. For example, if you are engaged in activities which are physically dispersed, the safety order(s) may be posted at the location from which the employees operate to carry out their activities. You must take steps to ensure that the safety order is not altered, defaced, or covered by other material. Posting shall be until the violation is abated, or for three working days, whichever is longer.

Penalties - Penalties are due within fifteen (15) working days of receipt of this notification unless contested. Abatement does not constitute payment of penalties.

Abatement - The conditions cited in the safety order(s) must be corrected (abated) on or before the date shown for each item on the safety order(s) and notification(s) of penalty unless:

- (1) You file a petition for review concerning the violation, in which case the full abatement period shall commence from the issuance of a final decision by the Board of Safety Review or the courts which requires compliance with the safety order; or
- (2) The abatement period is extended by the granting of a petition for modification of abatement date.

PMAs - The petition for modification of abatement date is a manner in which you may seek additional time to correct (abate) a violation without having to file a petition for review concerning the safety order, or after the expiration of the time period to file such a petition for review when it becomes apparent that you need extra time to abate the violation. A petition for modification of abatement date shall be in writing and shall include the following information:

- (1) All steps you have taken, and the dates of such actions, in an effort to achieve compliance

during the prescribed abatement period.

(2) The specific additional abatement time necessary in order to achieve compliance.

(3) The reasons such additional time is necessary, including the unavailability of professional or technical personnel or of materials and equipment, or because necessary construction or alteration of facilities cannot be completed by the original abatement date.

(4) All available interim steps being taken to safeguard employees against the cited hazard during the abatement period.

~~(5) A certification that a copy of the petition has been posted, and if appropriate, served on the authorized representative of affected employees, and a certification of the date upon which such posting and service was made.~~

A petition for modification of abatement date shall be filed with the Indiana Department of Labor/IOSHA no later than the close of the next working day following the date on which abatement was originally required. A later-filed petition shall be accompanied by the employer's statement of exceptional circumstances explaining the delay. A copy of such petition shall be posted in a conspicuous place where all affected employees will have notice thereof or near such location where the violation occurred. The petition shall remain posted until the time period for the filing of a petition for review of the Commissioner's granting or denying the petition expires. Where affected employees are represented by an authorized representative, said representative shall be served a copy of such petition.

Notification of Corrective Action - Correction of the alleged violations which have an abatement period of thirty (30) days or less should be reported in writing to us promptly upon correction. A "Letter of Abatement" form and an "Abatement Photographs" worksheet are enclosed for your assistance in providing adequate documentation of abatement. Reports of corrections should show specific corrective action on each alleged violation and the date of such action. On alleged violations with abatement periods of more than thirty (30) days, a written progress report should be submitted, detailing what has been done, what remains to be done, and the time needed to fully abate each such violation. When the alleged violation is fully abated, we should be so advised. Timely correction of an alleged violation does not affect the initial proposed penalty..

Followup Inspections - Please be advised that a followup inspection may be made for the purpose of ascertaining that you have posted the safety order(s) and corrected the alleged violations. Failure to correct an alleged violation may result in additional penalties for each day that the violation has not been corrected.

Employer Discrimination Unlawful - The law prohibits discrimination by an employer against an employee for filing a complaint or for exercising any rights under this Act. An employee who believes that he/she has been discriminated against may file a complaint no later than 30 days after the discrimination occurred with the Indiana Department of Labor/IOSHA at the address shown above.

Notice to Employees - The law gives an employee or his/her representative the opportunity to object to any abatement date set for a violation if he/she believes the date to be unreasonable. The contest must

be mailed to the Indiana Department of Labor/IOSHA at the address shown above within fifteen (15) working days (excluding weekends and State holidays) or receipt by the employer of this safety order and penalty.

If you wish additional information, you may direct such requests to us at the address or telephone number stated above.

Indiana Department of Labor

NOTICE TO EMPLOYEES OF INFORMAL CONFERENCE

An informal conference has been scheduled with IOSHA to discuss the safety order(s) issued on 10/11/2017. The conference will be held at the IOSHA office located at 402 West Washington Street, Room W195, Indianapolis, IN 46204 on _____ at _____. Employees and/or representatives of employees have a right to attend an informal conference.

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

Safety Order 01 Item 001 Type of Violation: **Serious**

29 CFR 1926.20(b)(1): The employer did not initiate and maintain such programs as may be necessary to comply with this part.

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017, the employer had not developed, implemented, or enforced an accident prevention safety and health program which included but is not limited to the following items:

- (1) A statement of management commitment toward the identification and evaluation of occupational hazards.
- (2) Establishment of employee participation in safety meetings and inspections.
- (3) Development of documentation of the instructions of each employee in the recognition and avoidance of unsafe work.

Abate - 15 workdays

Date By Which Violation Must Be Abated: **11/6/2017**
Proposed Penalty: **\$450.00**

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

Safety Order 01 Item 002 Type of Violation: **Serious**

29 CFR 1926.20(b)(2): Inspections of the jobsite, materials, and equipment were not made by a competent person designated by the employer.

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017, CSHO observed, the employer's competent persons on site failed to identify existing and predictable hazards and/or take the necessary measures to correct hazards where employees were exposed to Falls, Electrical, Ladder, and Personal Protective Equipment (PPE).

Abate - 15 workdays

Date By Which Violation Must Be Abated: **11/6/2017**
Proposed Penalty: **\$1,500.00**

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

Safety Order 01 Item 003Type of Violation: **Serious**

29 CFR 1926.20(b)(3): Machinery, tool(s), material(s), or equipment which was not in compliance with the applicable requirement(s) of 29 CFR 1926 was not prohibited, and/or was not either identified as unsafe by tagging, or locking the controls to render them inoperable, or physically removed from its place of operation.

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017, CSHO's observed the Werner 32 foot Type 1 Aluminum D-Rung Extension Ladder, model #: D1332-2, was not set up in accordance with the manufactures recommendations in that the extension ladder is missing and/or has illegible labels.

Abate - 15 workdays

Date By Which Violation Must Be Abated: 11/6/2017
Proposed Penalty: \$450.00

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

The alleged violations below have been grouped because they involve similar or related hazards that may increase the potential for injury or illness.

Safety Order 01 Item 004a Type of Violation: **Serious**

29 CFR 1926.21(b)(2): The employer did not instruct each employee in the recognition and avoidance of unsafe conditions and the regulations applicable to his/her environment to control or eliminate any hazards or other exposure to illness or injury:

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017, CSHO observed, employees were not instructed in the recognition and avoidance of unsafe conditions applicable to their work environment such as but not limited to those connected with electrical and Personal Protective Equipment (PPE).

Abate - 15 workdays

Date By Which Violation Must Be Abated:	11/6/2017
Proposed Penalty:	\$450.00

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

Safety Order 01 Item 004b

Type of Violation: **Serious**

29 CFR 1926.503(a)(1): The employer did not provide a training program for each employee exposed to fall hazards.

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017, CSHO observed employees exposed to fall hazards were not provided with a fall training program.

Abate - 15 workdays

Date By Which Violation Must Be Abated: 11/6/2017
Proposed Penalty: \$0.00

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

Safety Order 01 Item 004c Type of Violation: **Serious**

29 CFR 1926.1060(a): The employer did not provide a training program for each employee using ladders and stairways, as necessary, which would enable each employee to recognize hazards related to ladders and stairways and train each employee in the procedures to be followed to minimize these hazards.

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017. CSHO observed the employer did not provide such a program and train each employee in the use of and hazards related to ladders.

Abate - 15 workdays

Date By Which Violation Must Be Abated: 11/6/2017
Proposed Penalty: \$0.00

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

Safety Order 01 Item 005 Type of Violation: **Serious**

29 CFR 1926.100(a): Employees working in areas where there was a possible danger of head injury from impact, or falling or flying objects, or from electrical shock and burns, were not protected by protective helmets:

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017, CSHO observed 2 employees working directly below other employees, were not wearing protective helmets.

On June 27, 2017, CSHO observed hard hats being worn. Disk #2, image# IMG1822.

Date By Which Violation Must Be Abated:
Proposed Penalty:

Corrected During Inspection
\$1,500.00

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

Safety Order 01 Item 006 Type of Violation: **Serious**

29 CFR 1926.405(a)(2)(ii)(J): Extension cord sets used with portable electric tools and appliances were not designed for hard or extra-hard usage:

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017, CSHO observed, the 3 wire, round, orange 16 gauge extension cord that was approximately 50 feet long, with an illegible identification on cord, powering a circular saw, and available to power a Rigid air compressor, s/n 8M16246D0251305, model #OF60150HA and was not designed for hard or extra hard usage.

Abated on June 27, 2017, the employer removed the cord from the jobsite and replaced with an appropriate cord designed for hard or extra hard usage. Abatement - Disk #2, image #IMGP1823.

Date By Which Violation Must Be Abated:
Proposed Penalty:

Corrected During Inspection
\$750.00

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

Safety Order 01 Item 007 Type of Violation: **Serious**

29 CFR 1926.501(b)(1): Each employee on a walking/working surface with an unprotected side or edge which was 6 feet or more above a lower level was not protected from falling by the use of guardrail systems, safety net systems, or personal fall arrest systems.

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017. CSHO observed employees engaged in roof gutter system repair, at a height of 23 feet 4 inches above the lower level, was not protected from falling.

Abate - 15 Workdays

Date By Which Violation Must Be Abated: 11/6/2017
Proposed Penalty: \$1,500.00

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

Safety Order 01 Item 008 Type of Violation: **Serious**

29 CFR 1926.502(e)(2): Positioning devices were not secured to an anchorage capable of supporting impact load of employees fall or 3000 pounds.

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017, CSHO observed 2 employees, working on a 12:12 pitch roof 23 feet 4 inches above the lower level, using a rooftop chimney as an anchorage point; this anchorage is not capable of supporting the employees, resulting in failure of the anchorage and allowing the employee to fall 23 feet 4 inches to the lower level.

Abate - 15 Workdays

Date By Which Violation Must Be Abated: 11/6/2017
Proposed Penalty: \$1,500.00

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

Safety Order 01 Item 009 Type of Violation: **Serious**

29 CFR 1926.1053(b)(1): Where portable ladders were used for access to an upper landing surface and the ladder-s length allows, the ladder side rails did not extend at least 3 feet (.9 m) above the upper landing surface being accessed:

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017. CSHO observed the 32 foot aluminum extension ladder extended only 1.5 feet above, and not at least 3 feet above the 23 foot 4 inch high landing surface being accessed and no other grasping device was provided.

On June 27, 2017, CSHO observed ladder properly set to the required height, 3 feet above the landing surface. Disk #2, Image# IMG1819

Date By Which Violation Must Be Abated:	Corrected During Inspection
Proposed Penalty:	\$1,500.00

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

Safety Order 01 Item 010 Type of Violation: **Serious**

29 CFR 1926.1053(b)(5)(i): Non-self-supporting ladders were not used at an angle such that the horizontal distance from the top support to the foot of the ladder was approximately one-quarter of the working length of the ladder (the distance along the ladder between the foot and the top support).

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017, CSHO observed 3 employees using an extension ladder where, the top support point of the 32 feet long ladder was 23 feet 4 inches above the base or foot of the ladder and the horizontal distance from the top support to the foot of the ladder was approximately 4 feet from the top support, due to the ladder being 6 feet away from the face of the structure, with a 2 foot eave overhang supporting the top of the ladder.

Abated on June 27, 2017, the employer set the portable extension ladder up in accordance with the standard, Disk #2, Image #IMGP1825.

Date By Which Violation Must Be Abated:	Corrected During Inspection
Proposed Penalty:	\$1,500.00

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202

Safety Order 01 Item 011 Type of Violation: **Serious**

29 CFR 1926.1053(b)(7): Ladder(s) that were unsecured or not provided with slip-resistant feet were used on slippery surfaces:

Jobsite - 930 N. Alabama Street, Indianapolis, Indiana 46202 - On June 27, 2017 CSHO observed the 32 foot extension ladder was not secured and slip-resistant feet were not used while placed on a slippery surface consisting of concrete sidewalk.

Date By Which Violation Must Be Abated:
Proposed Penalty:

Corrected During Inspection
\$1,500.00

Indiana Department of Labor
Occupational Safety and Health Administration

Inspection Number: 318088614
Inspection Date(s): 6/27/2017 - 9/12/2017
Issuance Date: 10/11/2017
CSHO ID: X4033
Optional Report No.: 00117

Safety Order and Notification of Penalty

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202


Safety Order 01 Item 012 Type of Violation: **Serious**

29 CFR 1926.1053(b)(22): Employees using ladders were carrying objects or loads that could cause the employee to lose balance and fall:

One employee, using the Werner 32 foot extension ladder for egress, at a height of 23 feet 4 inches above the lower level, was carrying multiple long handle tools and was unable to maintain good contact with the ladder, creating an unsafe descent.

Date By Which Violation Must Be Abated:
Proposed Penalty:

Corrected During Inspection
\$1,500.00



Jerry W. Lander
Director of Construction Safety

Indiana Department of Labor

Indiana Occupational Safety and Health Administration
402 West Washington St - Room W195
Indianapolis, IN 46204
Phone: (317)232-1979 FAX: (317)233-3790



INVOICE/DEBT COLLECTION NOTICE

Company Name: James Anderson DBA James Anderson Painting
Inspection Site: 930 Alabama Street, Indianapolis, IN 46202
Issuance Date: 10/11/2017

Summary of Penalties for Inspection Number: 318088614

Safety Order 1, Serious = **\$14,100.00**
TOTAL PENALTIES = **\$14,100.00**

Penalties are due within fifteen (15) working days of receipt of this notification unless contested. Make your check or money order payable to: "Indiana DOL/IOSHA". Please indicate IOSHA's Inspection Number (indicated above) on the remittance.

IOSHA does not agree to any restrictions or conditions or endorsements put on any check or money order for less than full amount due, and will cash the check or money order as if these restrictions, conditions, or endorsements do not exist.

Corrective action, taken by you for each alleged violation should be submitted to this office on or about the abatement dates indicated on the Safety Order and Notification of Penalty.

A work sheet has been provided to assist in providing the required abatement information. A completed copy of this work sheet should be posted at the worksite with the safety order(s).



Jerry W. Lander
Director of Construction Safety



Date