

# Indiana Department of Labor

Indiana Occupational Safety and Health Administration  
402 West Washington St - Room W195  
Indianapolis, IN 46204  
Phone: (317)232-1979 FAX: (317)233-3790



*Certified Mail # 7016 301000010290 4730 10-16-17 JJA*

## Notification of Failure to Abate Alleged Violations

**To:**

Metro PCS DBA Metro PCS  
7255 N Keystone Ave.  
Indianapolis, IN 46240

**Original Inspection Number:** 318084159

**Original Inspection Date(s):** 2/2/2017

**Inspection Number:** 318091212

**Inspection Date(s):** 09/26/2017

**Issuance Date:** 10/16/2017

**Inspection Site:**

3637 E 38th Street  
Indianapolis, IN 46218

*The violation(s) described in this Notification of Failure to Abate Alleged Violations is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.*

After the original inspection, a Safety Order(s) was issued to you in accordance with the provisions of the Occupational Safety and Health Act of 1970 (the Act), notifying you of certain violations of the Act and the dates by which they were to be abated. Based upon reinspection, it is alleged that you have failed to abate the violation(s) listed below within the time prescribed, and the following additional penalties are proposed. The additional penalty is computed by multiplying a daily penalty times the number of days the violation(s) remained unabated. You are to notify the Area Director in writing of the date and nature of the corrective action taken. If you do not abate the violation(s), further penalties may be proposed and other enforcement action to compel abatement may be taken under section 11(b) of the Act.

You are further notified that you must pay the ADDITIONAL PENALTY unless you inform the Area Director in writing that you intend to contest the Notification or the Additional Penalty within 15 working days (excluding weekends and State holidays) from your receipt of this notification. If you do not contest within 15 working days after receipt, the Notification and the additional penalties will become the final order of the Occupational Safety and Health Review Commission and may not be reviewed by any court or agency. Issuance of this Notification does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless the Notification is affirmed by the Review Commission.

**Notification of Corrective Action** - For **each** violation which you do not contest, you are required by 29 CFR 1903.19 to submit an Abatement Certification to the Area Director of the IOSHA office issuing the

safety order and identification above. The certification **must** be sent by you within **10 calendar days** of the abatement date of the abatement date identification on the safety order. For **Knowing** and **Repeat** violations, documents (examples: photos, copies of recipes, training records, etc.) demonstrating that abatement is complete must accompany the certification. Where the safety order is classified as Serious and the safety orders states that abatement documentation is required, documents such as those described above are required to be submitted along with the abatement certificate. If the safety order indicates that the violation was corrected during the inspection, no abatement certification is required for that item.

For each safety order where you do contest the violation or the abatement date, your obligation to submit abatement certification and any documents is delayed until the contest and the 10-day period after the abatement date have expired. See 29CFR 1903.19 and the OSHA 3000 booklet for more information.

**All abatement verification documents must contain the following information:** 1) Your name and address; 2) the inspection number (found on the front page); 3) the safety order and safety order item number(s) to which the submission relates; 4) a statement that the information is accurate; 5) the signature of the employer or employer's authorized representative; 6) the date the hazard was corrected; 7) a brief statement of how the hazard was corrected; and 8) a statement that affected employees and their representatives have been informed of the abatement.

The law also requires a copy of all abatement verification documents, required by 29 CFR 1903.19 to be sent to IOSHA, also be posted at the location where the violation appeared and the corrective action took place.

**Inspection Activity Data** - you should be aware that IOSHA publishes information on its inspection and safety order activity on the Internet under the provisions of the Electronic Freedom of Information Act. The information related to your inspection will be available 7 calendar days after the Safety Order Issuance Date. You are encouraged to review the information concerning your establishment at [WWW.OSHA.GOV](http://WWW.OSHA.GOV). If you have any dispute with the accuracy of the information displayed, please contact this office.

Make your check or money order payable to "Indiana DOL/IOSHA". Please indicate the Inspection Number on the remittance.

**NOTICE TO EMPLOYEES OF INFORMAL CONFERENCE**

An informal conference has been scheduled with IOSHA to discuss the Notification of Failure to Abate Alleged Violations issued on 7/13/2017. The conference will be held at the OSHA office located at 402 West Washington Street, Room W195, Indianapolis, IN, 46204 on \_\_\_\_\_ at \_\_\_\_\_.

Employees and/or representatives of employees have a right to attend an informal conference.

## Indiana Department of Labor

Indiana Occupational Safety and Health Administration

### Notification of Failure to Abate Alleged Violation

<b>Original Inspection:</b>	318084159	<b>Inspection Number:</b>	318091212
<b>Original Inspection Date(s):</b>	2/2/2017	<b>Inspection Date(s):</b>	09/26/2017
		<b>Issuance Date:</b>	10/16/2017
		<b>CSHO ID:</b>	L0138
		<b>Optional Report No.:</b>	0100-18

**Company Name:** Metro PCS DBA Metro PCS

**Inspection Site:** 3637 E 38th Street, Indianapolis, IN 46218

---

#### Safety Order 01 Item 001

29 CFR 1910.303(b)(1)(i): Electrical equipment was not free from recognized hazards likely to cause death or serious physical harm, in that the employer did not ensure that the electrical equipment had listing or labeling identifying the purpose for whi

120 Electrical panel, Southwest corner of facility, electrical panel does not have the proper labeling for the circuit breakers.

#### FAILURE TO ABATE

On October 6, 2017, a follow-up inspection determined that the electrical panel was not labelled properly. For a period of thirty (30) or more days, including (30) days from July 13, 2017, the employer failed to provide proper labelling as required by the terms of the Safety Order and Notification of Penalty issued In Re Inspection of Wireless PCS dba Metro PCS and its Successors, Inspection No. 318084159, part of the citations issued to the employer on July 13, 2017, and the Final Order resulting therefrom.

**FAILURE TO ABATE Safety Order 01 Item 001, INSPECTION NO. 318084159, ISSUED ON July 13, 2017.**

**Additional Penalty:**

**\$42,000.00**

## Indiana Department of Labor

Indiana Occupational Safety and Health Administration

### Notification of Failure to Abate Alleged Violation

<b>Original Inspection:</b>	318084159	<b>Inspection Number:</b>	318091212
<b>Original Inspection Date(s):</b>	2/2/2017	<b>Inspection Date(s):</b>	09/26/2017
		<b>Issuance Date:</b>	10/16/2017
		<b>CSHO ID:</b>	L0138
		<b>Optional Report No.:</b>	0100-18

**Company Name:** Metro PCS DBA Metro PCS

**Inspection Site:** 3637 E 38th Street, Indianapolis, IN 46218

---

#### Safety Order 01 Item 002

29 CFR 1910.303(b)(7)(i): Unused openings in boxes, raceways, auxiliary gutters, cabinets, equipment cases, or housings were not effectively closed to afford protection substantially equivalent to the wall of the equipment:

120 Volt electrical panel, Southeast corner of facility, employees exposed to electrical hazards due to open circuits inside the electrical panel box.

#### FAILURE TO ABATE

On October 6, 2017, a follow-up inspection determined that the electrical panel had open circuits. For a period of thirty (30) or more days, including (30) days from July 13, 2017, the employer failed to provide blanks for open circuits as required by the terms of the Safety Order and Notification of Penalty issued In Re Inspection of Wireless PCS dba Metro PCS and its Successors, Inspection No. 318084159, part of the citations issued to the employer on July 13, 2017, and the Final Order resulting therefrom.

**FAILURE TO ABATE Safety Order 01 Item 002, INSPECTION NO. 318084159, ISSUED ON July 13, 2017.**

**Additional Penalty:**

**\$42,000.00**

**Indiana Department of Labor**  
Indiana Occupational Safety and Health Administration

**Notification of Failure to Abate Alleged Violation**

<b>Original Inspection:</b>	318084159	<b>Inspection Number:</b>	318091212
<b>Original Inspection Date(s):</b>	2/2/2017	<b>Inspection Date(s):</b>	09/26/2017
		<b>Issuance Date:</b>	10/16/2017
		<b>CSHO ID:</b>	L0138
		<b>Optional Report No.:</b>	0100-18

**Company Name:** Metro PCS DBA Metro PCS  
**Inspection Site:** 3637 E 38th Street, Indianapolis, IN 46218

---

**Safety Order 01 Item 003**

29 CFR 1910.303(g)(1)(ii): The required working space about electric equipment rated 600 volts, nominal, or less to ground, was used for storage:


120 Volt electrical panel, Southwest corner of facility, employees exposed to fire hazards due to storage shelves and boxes being stored within 3 feet of the electrical panel.

**FAILURE TO ABATE**

On October 6, 2017, a follow-up inspection determined that items were stored directly in front of an electrical panel. For a period of thirty (30) or more days, including (30) days from July 13, 2017, the employer failed to provide a 3 foot clearance around the electric panel as required by the terms of the Safety Order and Notification of Penalty issued In Re Inspection of Wireless PCS dba Metro PCS and its Successors, Inspection No. 318084159, part of the citations issued to the employer on July 13, 2017, and the Final Order resulting therefrom.

**FAILURE TO ABATE Safety Order 01 Item 003, INSPECTION NO. 318084159, ISSUED ON July 13, 2017.**

**Additional Penalty: \$42,000.00**



---

Julie C. Alexander, J.D.  
Director General Industry

# Indiana Department of Labor

Indiana Occupational Safety and Health Administration

402 West Washington St - Room W195

Indianapolis, IN 46204

Phone: (317)232-2691 FAX: (317)233-3790



## INVOICE/ DEBT COLLECTION NOTICE

---

**Company Name:** Metro PCS DBA Metro PCS  
**Inspection Site:** 3637 E 38th Street, Indianapolis, IN 46218  
**Issuance Date:** 10/16/2017  
**Opt. Insp. Nr:** 0100-18

**Summary of Penalties for Inspection Number:** 318084159  
**Followup Inspection Number:** 318091212

**Safety Order 1, Serious** = \$126,000.00  
**TOTAL ADDITIONAL PROPOSED PENALTIES**  
= \$126,000.00

---

To avoid additional charges, please remit payment promptly to this Office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: "Indiana DOL/IOSHA". Please indicate IOSHA's Inspection Number (indicated above) on the remittance.

OSHA does not agree to any restrictions or conditions or endorsements put on any check or money order for less than full amount due, and will cash the check or money order as if these restrictions, conditions, or endorsements do not exist.


Pursuant to the Debt Collection Act of 1982 (Public Law 97-365) and regulations of the U.S. Department of Labor (29 CFR Part 20), the Occupational Safety and Health Administration is required to assess interest, delinquent charges, and administrative costs for the collection of delinquent penalty debts for violations of the Occupational Safety and Health Act.

**Interest.** Interest charges will be assessed at an annual rate determined by the Secretary of the Treasury on all penalty debt amounts not paid within one month (30 calendar days) of the date on which the debt amount becomes due and payable (penalty due date). The current interest rate is 5%. Interest will accrue from the date on which the penalty amounts (as proposed or adjusted) become a final order of the Occupational Safety and Health Review Commission (that is, 15 working days from your receipt of the

Safety Order and Notification of Penalty), unless you file a notice of contest. Interest charges will be waived if the full amount owed is paid within 30 calendar days of the final order.

**Delinquent Charges.** A debt is considered delinquent if it has not been paid within one month (30 calendar days) of the penalty due date or if a satisfactory payment arrangement has not been made. If the debt remains delinquent for more than 90 calendar days, a delinquent charge of six percent (6%) per annum will be assessed accruing from the date that the debt became delinquent.

**Administrative Costs.** Agencies of the Department of Labor are required to assess additional charges for the recovery of delinquent debts. These additional charges are administrative costs incurred by the Agency in its attempt to collect an unpaid debt. Administrative costs will be assessed for demand letters sent in an attempt to collect the unpaid debt.



Julie C. Alexander, J.D.  
Director General Industry

10-16-2017

Date