



PROPOSAL FOR CODE CHANGE

State Form 41186 (R2 / 1-92)

RETURN TO: INDIANA DEPARTMENT OF
FIRE AND BUILDING SERVICES
402 W. Washington St., Rm 246
Indianapolis, IN 46204

FOR OFFICE USE ONLY	
Item number:	
Change number:	

INSTRUCTIONS: Only TYPED copy accepted.
KEY: ~~Dashed line through material to be deleted~~; underline or bold face material to be added.
Use second sheet for any material requiring more space.

Code title: Indiana Residential Code		Edition: 2009
Section number and title: R303.1, habitable rooms		Sheet: 1 of 1
Proponent: Craig Wagner/IABO	Title: Code Committee Member	

Address: 220 W Van Buren St, Ste 204, Columbia City, IN 46725	Telephone number: (260) 248-3111
---	--

PROPOSED CODE CHANGE (check one)

Change to read as follows. Add to read as follows. Delete and substitute as follows. Delete without substitution.

Bring forward from the 2005InRC the amendment for the third sentence of R303.1 as follows: ~~Such openings shall be provided with ready access or shall otherwise be readily controllable by the building occupants.~~ Ventilation openings shall be readily accessible and operable.

REASON

This amendment provides clearer, enforceable, language as to the intent of the section.

Fiscal impact: This proposal does not increase construction costs.

REVIEW RECOMMENDATION

Approve
Disapprove
Approve as amended
Further study