



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY
Received 5/12/09
Code 23-09

INSTRUCTIONS: Only *TYPED* copy accepted.
(KEY – *Dashed line through material to be deleted, underline material to be added*)
Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title R306.2 Kitchen		Page 55
Proponent Carolyn Schleif	Title President, Nightingale Designs, Inc.	
Address 10517 Hyde Park, Carmel, IN 46032		Phone (317) 580-0540
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
ADD” “Walls behind sinks and water faucets shall be of non-cellulose material.”		
REASON AND FISCAL IMPACT		
Reason: water will splash onto walls and the wall will dissolve or become moldy. Fiscal impact: Minimal cost. If tile or a grouted finish is used, this is the standard of practice already.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		