



# PROPOSAL FOR CODE CHANGE

State Form 41186 (R2 / 1-92)

RETURN TO: INDIANA DEPARTMENT OF  
FIRE AND BUILDING SERVICES  
402 W. Washington St., Rm 246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY	
Item number:	
Change number:	

INSTRUCTIONS: Only TYPED copy accepted.  
KEY: ~~Dashed line through material to be deleted~~; underline or bold face material to be added.  
Use second sheet for any material requiring more space.

Code title: <b>Indiana Residential Code</b>		Edition: 2009
Section number and title: R308.4, hazardous locations		Sheet: 1 of 1
Proponent: Craig Wagner/IABO	Title: Code Committee Member	

Address: 220 W Van Buren St, Ste 204, Columbia City, IN 46725	Telephone number: (260) 248-3111
--	-------------------------------------

**PROPOSED CODE CHANGE (check one)**

Change to read as follows.    Add to read as follows.    Delete and substitute as follows.    Delete without substitution.

Change in the second sentence of R308.4 Item 3.4, Exception 2., and Item 7. Exception 1. to read as follows:  
The rail shall be capable of withstanding a horizontal load of ~~50~~ 200 pounds per lineal ...

**REASON**

This proposal will require the guards placed in front of non-safety glazed windows (in order to not have to safety glaze the window) to meet the same horizontal load requirement that other guards in the code are required to meet.

**Fiscal impact:** This proposal will increase the cost of construction.

**REVIEW RECOMMENDATION**

Approve

Disapprove

Approve as amended

Further study