



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY
Received 5/4/09
Code 28-09

INSTRUCTIONS: Only TYPED copy accepted.
(KEY – Dashed line through material to be deleted, underline material to be added)
Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title R310.4 Bars, grilles, covers, and screens.		Page 82
Proponent Calvin Bolt Inspections and Testing	Title Owner	
Address 1310 Oriole Dr. Warsaw, IN 46580		Phone 574-269-3507
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
Exception: Bars and grilles over window wells are not required to comply with Sections R310.1.1 to R310.1.3. Bars and grilles shall not have any cross sectional dimensions greater than 4".		
REASON AND FISCAL IMPACT		
As currently written, it would appear that even installing 1 single bar (i.e. re-bar) across the middle (on top) of the 9 square foot opening of the window well (thus making each "half" now 4.5 square feet) would violate compliance with Sections R310.1.1 to R310.1.3. I added the 4 square inch stipulation for child safety to prevent falling through the bars/grilles.		
Fiscal impact---probably no more than the existing.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		