



**Proposed Code Change**  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

<b>FOR OFFICE USE ONLY</b>
Received 5/12/09
Code 31-09

**INSTRUCTIONS:** Only TYPED copy accepted.  
(KEY – Dashed line through material to be deleted, underline material to be added)  
Use second sheet for any material requiring more space.

Code Title <b>International Residential Code</b>		Edition 2009
Section number and title <b>R311.2 Egress Door</b>		Page 62
Proponent Carolyn Schleif	Title President, Nightingale Designs, Inc.	
Address 10517 Hyde Park, Carmel, IN 46032		Phone (317) 580-0540
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <b>X</b> <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
CHANGE "32 inches" to "36 inches."		
REASON AND FISCAL IMPACT		
Reason: Having even one 36" door would be invaluable. Many furnishings will not go through a 32" wide door. Fiscal impact: Minimal.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		