



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY
Received 5/12/09
Code 33-09

INSTRUCTIONS: Only *TYPED* copy accepted.
(*KEY – Dashed line through material to be deleted, underline material to be added*)
Use second sheet for any material requiring more space.

Code Title IRC		Edition
Section number and title R311.7.4.2 Tread Depth		Page 51
Proponent Jeff Washler	Title	
Address 3435 CR 52, Auburn IN 46706		Phone 260.925.8427
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> X Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows Delete without substitution Remove the sentence: “ Winder treads shall have a minimum tread depth of 6 inches (152mm) at any point with in the clear width of the stair.		
REASON AND FISCAL IMPACT		
Stairs turning a right angle take less space if the turn can be used as a step. Should be very little impact \$50 credit or less per stairs		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		