



PROPOSAL FOR CODE CHANGE

State Form 41186 (R2 / 1-92)

RETURN TO: INDIANA DEPARTMENT OF
FIRE AND BUILDING SERVICES
402 W. Washington St., Rm 246
Indianapolis, IN 46204

FOR OFFICE USE ONLY	
Item number:	
Change number:	

INSTRUCTIONS: Only TYPED copy accepted.
KEY: ~~Dashed line through material to be deleted~~; underline or **bold face** material to be added.
Use second sheet for any material requiring more space.

Code title: Indiana Residential Code		Edition: 2009
Section number and title: R311.7.7.2, continuity		Sheet: 1 of 1
Proponent: Craig Wagner/IABO	Title: Code Committee Member	

Address: 220 W Van Buren St, Ste 204, Columbia City, IN 46725	Telephone number: (260) 248-3111
---	--

PROPOSED CODE CHANGE (check one)			
<input checked="" type="checkbox"/> Change to read as follows.	<input type="checkbox"/> Add to read as follows.	<input checked="" type="checkbox"/> Delete and substitute as follows.	<input type="checkbox"/> Delete without substitution.
<p>Delete the first sentence of R311.7.7.2 and substitute as follows: <u>Handrails for stairways shall serve each tread for the full length of the flight, from a point directly above the top riser to a point directly above the lowest riser of the flight.</u></p> <p>Add the words "<u>or by a landing</u>" to the end of Exception 1.</p>			

REASON
<p>This proposal replaces and adds text from the 2005 InRC that has been used and works well, in Indiana.</p> <p>Fiscal impact: There is no increase to the cost of construction.</p>

REVIEW RECOMMENDATION
Approve
Disapprove
Approve as amended
Further study