



PROPOSAL FOR CODE CHANGE

State Form 41186 (R2 / 1-92)

RETURN TO: INDIANA DEPARTMENT OF
FIRE AND BUILDING SERVICES
402 W. Washington St., Rm 246
Indianapolis, IN 46204

FOR OFFICE USE ONLY	
Item number:	
Change number:	

INSTRUCTIONS: Only TYPED copy accepted.
KEY: ~~Dashed line through material to be deleted~~; underline or bold face material to be added.
Use second sheet for any material requiring more space.

Code title: Indiana Residential Code		Edition: 2009
Section number and title: R311.7.7.3, grip size		Sheet: 1 of 1
Proponent: Craig Wagner/IABO	Title: Code Committee Member	

Address: 220 W Van Buren St, Ste 204, Columbia City, IN 46725	Telephone number: (260) 248-3111
---	--

PROPOSED CODE CHANGE (check one)

Change to read as follows. Add to read as follows. Delete and substitute as follows. Delete without substitution.

Change R311.7.7.3, Item 2., fourth sentence as follows: ...to a maximum ~~2 inches (70 mm)~~ 2⁷/₈ inches (72mm).

REASON

This proposal allows the use of several handrails that have been used successfully in Indiana.

Fiscal impact: there is no increase in the cost of construction.

REVIEW RECOMMENDATION

Approve
Disapprove
Approve as amended
Further study