Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY
Received 9-17-09
Code 48.1-09 R

INSTRUCTIONS: *Only TYPED copy accepted.*
(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)
Use second sheet for any material requiring more space.

Code Title	Edition
International Residential Code	2009
Section number and title	Page
401.3 Drainage	71

Proponent	Title
Steve Dean	VP Homebuilding, Ryland Homes
Address	Phone
9025 N River Rd. Indianapolis In 46240	317 846-3234

PROPOSED CODE CHANGE (Check One)

☐ Change to read as follows ☐ Add to read as follows X Delete and substitute as follows ☐ Delete without substitution

Change the last sentence to read as follows: Patios and stoops with Impervious Surfaces within 10 feet of the building foundation shall be sloped a minimum of 2% away from the building.

REASON AND FISCAL IMPACT

Reason: 2009 Code states Impervious Surfaces within 10 feet of the building foundation shall be sloped a minimum of 2% away from the building. This statement would make it difficult to transition house walk and stoop to the porch area.

Fiscal Impact: There is no fiscal impact.

REVIEW RECOMMENDATION

Approve

Disapprove

Approve as amended

Further Study