



**Proposed Code Change**  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

<b>FOR OFFICE USE ONLY</b>
Received 7/1/09
Code 48.2.1-09



**INSTRUCTIONS:** Only TYPED copy accepted.  
(KEY – Dashed line through material to be deleted, underline material to be added)  
Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title Figure R-403.1 (1)		Page 74
Proponent Steve Dean	Title VP Homebuilding, Ryland Homes	
Address 9025 N River Rd. Indianapolis In 46240		Phone 317 710-2134

PROPOSED CODE CHANGE (Check One)

X Change to read as follows     Add to read as follows     Delete and substitute as follows     Delete without substitution

Change the below illustration to read as follows:



Add: Interior braced wall panel  
anchorage at interior of slab

REASON AND FISCAL IMPACT

**Reason:** This foundation detail has not been clear. The diagram on the left shows a monolithic slab with integral footing. The diagram on the right is intended to show interior braced wall panel anchorage at a slab interior.

**Fiscal Impact:** There is no fiscal impact.

REVIEW RECOMMENDATION

Approve

Disapprove

Approve as amended

Further Study