



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY
Received 3/15/10
Code 50.12.6-09

INSTRUCTIONS: Only TYPED copy accepted.
(KEY – *Dashed line through material to be deleted, underline material to be added*)
Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title R806.2 Minimum area		Page 1 of 1
Proponent William Fox / IBA	Title Code Committee Member	
Address 6125 W 29 th Place, Speedway, IN. 46224		Phone 317-291-7575
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Add a second paragraph to Section R 806.2 to read as follows:</p> <p>Mechanical ventilation is permitted provided the following conditions are met.</p> <ol style="list-style-type: none"> 1. The installation complies with the manufacturer's instructions. 2. A humidistat is included with the installation. 3. An ammeter or equivalent device is installed in a readily visible location. 		
REASON AND FISCAL IMPACT		
<p>The above is included in the current code and was overlooked. There will be no added cost.</p>		
REVIEW RECOMMENDATION		
Approve 18-0-0 3/16/10		
Disapprove		
Approve as amended		
Further Study		

