



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY
Received
Code 50.5-09

INSTRUCTIONS: Only TYPED copy accepted.
(KEY – Dashed line through material to be deleted, underline material to be added)
Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title R502.1		Page 111
Proponent Charlie Eldridge	Title Consultant	
Address 551 Grassy Ln., Indianapolis, IN 46217		Phone (317) 370-3444
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>R502.1 Identification. Load-bearing dimension lumber for joists, beams and girders shall be identified by a grade mark of a lumber grading or inspection agency that has been approved by an accreditation body that complies with DOCPS 20. In lieu of a grade mark, a certificate of inspection issued by a lumber grading or inspection agency meeting the requirements of this section shall be accepted.</p> <p><u>Where prefabricated wood I-joists or structural glued laminated timbers are used, a permanent warning plaque shall be mounted on the meter fitting to warn first responders of the presence of this material.</u></p>		
REASON AND FISCAL IMPACT		
<p>Fire fighters should not be faced with falling through an involved floor when working a fire. This would give some warning that engineered floors have been used in the construction of the home.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		