



**Proposed Code Change**  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

<b>FOR OFFICE USE ONLY</b>
Received
Code

**INSTRUCTIONS:**

*Only TYPED copy accepted.*

*(KEY - Dashed line through material to be deleted, underline material to be added)*

*Use second sheet for any material requiring more space.*

Code Title IMC		Edition 2006
Section number and title 506.3.10 Grease duct enclosure		Page 43
Proponent Michael J. Koppes	Title Fire Protection Engineer	
Address 401 South Grant Street, West Lafayette, IN 47907-2024		Phone 765-494-1427
<b>PROPOSED CODE CHANGE (Check One)</b>		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
Change the first sentence of section 506.3.10 to read as follows:  A grease duct serving a Type I hood that penetrates a <u>fire-resistance rated</u> ceiling, wall or floor <u>assembly</u> shall be enclosed from the <u>lowest</u> point of <u>duct</u> penetration to the outlet terminal.		
<b>REASON</b>		
Our current rules and NFPA 96-2004 (Ventilation Control and Fire Protection of Commercial Cooking Operations) would not require fire-rated enclosure of ducts penetrating non-rated assemblies.		
<b>REVIEW RECOMMENDATION</b>		
Approve		
Disapprove		
Approve as amended		
Further Study		