



**Proposed Code Change**  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY	
Received	12/28/09
Code	52.1.1.5-09

**INSTRUCTIONS:**

Only TYPED copy accepted.  
(KEY- ~~Dashed line through material to be deleted~~, underline material to be added)  
Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section R 905.2.8.1 Base and cap flashing		Page
Proponent William Fox / IBA	Title Code Committee Member	
Address 6125 W 29th Place, Speedway, IN. 46224		Phone 317-291-7575
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input checked="" type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p><b>R905.2.8.1 Base and cap flashing. Base and cap flashing shall be installed in accordance with manufacturer's installation instructions. Base flashing at roof penetrations shall be of either corrosion resistant metal of minimum nominal 0.019 inch (0.5 mm) thickness or any mineral surface roll roofing or self adhering polymer modified bitumen underlayment approved for base flashing. Valley linings must comply with R905.2.8.2. Cap flashings (step flashing, dormer flashing and counter flashing) must be of a corrosion resistant metal of minimum nominal 0.019 inch (0.5 mm) thickness.</b></p>		
Reason		
<p>This change helps clarify differences of flashing required for base and cap flashing and allows for new material commonly in use today. No added cost.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		