



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY	
Received	12/28/09
Code	52.15-09

INSTRUCTIONS:

Only TYPED copy accepted.
(KEY – Dashed line through material to be deleted, underline material to be added)
Use second sheet for any material requiring more space.

Code Title		Edition	
2009 Indiana Residential Code		First	
Section number and title		Page	
G2408.3 Private Garages		524	
Proponent		Title	
Phil Gettum		Indiana Builder's Association	
Address		Phone	
PROPOSED CODE CHANGE (Check One)			
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution			
<p>Add an exception to G2408.3 to read as follows:</p> <p><u>Exception #2</u> : The requirements of this section shall not apply where appliances are not installed in a location that is subject to vehicle damage. The area of possible vehicle damage shall be limited to the assumed parking area of the vehicle and defined as the width of the vehicle entrance opening by a distance of 18'-0 deep inside such doorway.</p>			
REASON AND FISCAL IMPACT			
<p>This addition sets measurable boundaries defining locations which would not normally be subject to damage by vehicle traffic.</p> <p>This change could be a savings if it reduced the need for barriers in certain locations or provides greater design flexibility.</p>			
REVIEW RECOMMENDATION			
Approve			
Disapprove			
Approve as amended			
Further Study			