



Proposed Code Change  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY	
Received	12/28/09
Code	52.4.3.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title		Edition
2009 Indiana Residential Code		First
Section number and title		Page
M1307.3.1		481
Proponent	Title	
Phil Gettum	Indiana Builder's Association	
Address		Phone
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p><b>M1307.3.1 Protection from impact:</b> Appliances shall not be installed in a location <u>within a garage that is subject to vehicle damage except where protected by approved barriers. The area of possible vehicle damage shall be limited to the assumed parking area of the vehicle and defined as the width of the vehicle entrance opening by a distance of 18'-0 deep inside such doorway.</u></p>		
REASON AND FISCAL IMPACT		
<p>This addition sets measurable boundaries defining locations which would not normally be subject to damage by vehicle traffic.</p> <p>This change could be a savings if it reduced the need for barriers in certain locations or provided greater design flexibility.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		