



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY
Received 9/22/09
Code 53.22-09

INSTRUCTIONS: *Only TYPED copy accepted.*
(KEY – Dashed line through material to be deleted, underline material to be added)
Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition	
Section number and title P2605.1, Item # 5 Support		Page 1 of 2	
Proponent Craig Wagner		Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111	
PROPOSED CODE CHANGE (Check One)			
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution			
<p>P2605.1 General. Piping shall be supported in accordance with the following:</p> <ol style="list-style-type: none"> 1. Piping shall be supported to ensure alignment and prevent sagging, and allow movement associated with the expansion and contraction of the piping system. 2. Piping in the ground shall be laid on a firm bed for its entire length, except where support is otherwise provided. 3. Hangers and anchors shall be of sufficient strength to maintain their proportional share of the weight of pipe and contents and of sufficient width to prevent distortion to the pipe. Hangers and strapping shall be of <i>approved</i> material that will not promote galvanic action. Rigid support sway bracing shall be provided at changes in direction greater than 45 degrees (0.79 rad) for pipe sizes 4 inches (102 mm) and larger. 4. Piping shall be supported at distances not to exceed those indicated in Table P2605.1. 5. <u>Metal piping shall be isolated from corrugated stainless steel tubing by a space separation of at least 2 inches (51 mm). See also Section G2411.1.1.</u> 			
REASON			

This proposal brings the 2" CSST separation to the plumbing chapters.

Fiscal impact: no increase to the cost of construction, current amendment language.

REVIEW RECOMMENDATION

Approve

Disapprove

Approve as amended

Further Study