



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY	
Received	12/29/09
Code	53.5.8-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title G2417.6.3 Leak check		Page 555
Proponent Calvin Bolt	Title	
Address 1310 Oriole Dr., Warsaw, IN 46580		Phone 574-269-3507
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Change G2417.6.3 Leak check to read as follows: Immediately after the gas is turned on into a new system or into a system that has been initially restored after an interruption of service, the piping system shall be checked for leakage. Where <u>If</u> leakage is indicated, the gas supply shall be shut off until the necessary repairs have been made <u>leakage is corrected</u>.</p>		
REASON AND FISCAL IMPACT		
<p>This proposal brings forward an amendment from the 2005 Indiana Residential Code.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		