

Petition for Review

Date Filed: December 20, 2023
{ . . } = No Information provided

NAME

Petitioner's First Name: John
Petitioner's Last Name: Niegos
Business Name if Applicable: LaPorte County
Name of Counsel if Represented: Douglas Biege

CONTACT INFORMATION

Street Address for Service: 205 W Beech Street
City: Westville
State: IN
Zip Code: 46391
Phone Number: 2196089769
Email Address for Service: jniegos@laporteco.in.gov

ORDER INFORMATION

Facility | Device | Boiler ID: Residential Single Family Home
Order Number: ALB-2023-37
Entity Issuing Order: Local Building Department
Scope of Review Requested? No, Article 210.8(A)(1) of the 2009 IEC does not prohibit the installation of light fixtures on circuits with ground-fault-circuit-interrupter protection.
Date Ordered Received: December 19, 2023
How was Order received: Email
Was this Order specifically directed to you? No
Have you been aggrieved or adversely affected by the Order? Yes
If you answered no to the previous two questions, under what law are you entitled to review? { . . }

INFORMATION CONCERNING REVIEW

Scope of Review Requested: No, Article 210.8(A)(1) of the 2009 IEC does not prohibit the installation of light fixtures on circuits with ground-fault-circuit-interrupter protection.
I request a Stay of Effectiveness: No
What is the basis of your challenge? The safety issue of the lights going off and having to reset the receptacle in the dark not having known what caused it to go off.
What is your desired outcome? To separate the lights from the GFCI.
Additional Information: Please refer to Exhibit 210.9 of the 2008 NEC. The intent of the Exhibit and code shows the luminaries and GFCI outlets are controlled separately. The GFCI's do not control the luminaries; they are both fed off the primary circuit.