

NFPA 1403

Standard on Live Fire Training Evolutions

2002 Edition



NFPA, 1 Batterymarch Park, PO Box 9101, Quincy, MA 02269-9101
An International Codes and Standards Organization

NFPA License Agreement

This document is copyrighted by the National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02269-9101 USA.
All rights reserved.

NFPA grants you a license as follows: The right to download an electronic file of this NFPA document for temporary storage on one computer for purposes of viewing and/or printing one copy of the NFPA document for individual use. Neither the electronic file nor the hard copy print may be reproduced in any way. In addition, the electronic file may not be distributed elsewhere over computer networks or otherwise. The hard copy print may only be used personally or distributed to other employees for their internal use within your organization.

Copyright ©
National Fire Protection Association, Inc.
One Batterymarch Park
Quincy, Massachusetts 02269

IMPORTANT NOTICE ABOUT THIS DOCUMENT

NFPA codes, standards, recommended practices, and guides, of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in its codes and standards.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making this document available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the NFPA list, certify, test or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

NOTICES

All questions or other communications relating to this document and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA documents during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

Users of this document should be aware that this document may be amended from time to time through the issuance of Tentative Interim Amendments, and that an official NFPA document at any point in time consists of the current edition of the document together with any Tentative Interim Amendments then in effect. In order to determine whether this document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments, consult appropriate NFPA publications such as the *National Fire Codes*[®] Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed above.

A statement, written or oral, that is not processed in accordance with Section 5 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

The NFPA does not take any position with respect to the validity of any patent rights asserted in connection with any items which are mentioned in or are the subject of this document, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on this document. Users of this document are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Users of this document should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of this document, intend to urge action that is not in compliance with applicable laws, and this document may not be construed as doing so.

Licensing Policy

This document is copyrighted by the National Fire Protection Association (NFPA). By making this document available for use and adoption by public authorities and others, the NFPA does not waive any rights in copyright to this document.

1. Adoption by Reference—Public authorities and others are urged to reference this document in laws, ordinances, regulations, administrative orders, or similar instruments. Any deletions, additions, and changes desired by the adopting authority must be noted separately. Those using this method are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. The term "adoption by reference" means the citing of title and publishing information only.

2. Adoption by Transcription—**A.** Public authorities with lawmaking or rule-making powers only, upon written notice to the NFPA (Attention: Secretary, Standards Council), will be granted a royalty-free license to print and republish this document in whole or in part, with changes and additions, if any, noted separately, in laws, ordinances, regulations, administrative orders, or similar instruments having the force of law, provided that: (1) due notice of NFPA's copyright is contained in each law and in each copy thereof; and (2) that such printing and republication is limited to numbers sufficient to satisfy the jurisdiction's lawmaking or rule-making process. **B.** Once this NFPA Code or Standard has been adopted into law, all printings of this document by public authorities with lawmaking or rule-making powers or any other persons desiring to reproduce this document or its contents as adopted by the jurisdiction in whole or in part, in any form, upon written request to NFPA (Attention: Secretary, Standards Council), will be granted a nonexclusive license to print, republish, and vend this document in whole or in part, with changes and additions, if any, noted separately, provided that due notice of NFPA's copyright is contained in each copy. Such license shall be granted only upon agreement to pay NFPA a royalty. This royalty is required to provide funds for the research and development necessary to continue the work of NFPA and its volunteers in continually updating and revising NFPA standards. Under certain circumstances, public authorities with lawmaking or rule-making powers may apply for and may receive a special royalty where the public interest will be served thereby.

3. Scope of License Grant—The terms and conditions set forth above do not extend to the index of this document.

(For further explanation, see the Policy Concerning the Adoption, Printing, and Publication of NFPA Documents, which is available upon request from the NFPA.)

Copyright © 2002, National Fire Protection Association, All Rights Reserved

NFPA 1403
Standard on
Live Fire Training Evolutions
2002 Edition

This edition of NFPA 1403, *Standard on Live Fire Training Evolutions*, was prepared by the Technical Committee on Fire Service Training and acted on by NFPA at its November Association Technical Meeting held November 10–14, 2001, in Dallas, TX. It was issued by the Standards Council on January 11, 2002, with an effective date of January 31, 2002, and supersedes all previous editions.

This edition of NFPA 1403 was approved as an American National Standard on January 31, 2002.

IMPORTANT NOTE: *This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notices and Disclaimers Concerning NFPA Documents.” They can also be obtained on request from NFPA or viewed at www.nfpa.org/disclaimers.*

Origin and Development of NFPA 1403

The ongoing training of fire fighters is the cornerstone of good fire protection in today’s world. However, the benefits derived from live fire training can be negated by the injuries and deaths suffered by fire fighters under unsafe and poorly supervised training conditions.

Following a tragic training accident in 1982, which resulted in the deaths of two fire fighters, the Committee on Fire Service Training was urged to address the issue of live fire training evolutions in structures. The committee proceeded to develop NFPA 1403 in order to provide recognized safe practices for conducting such training evolutions.

The first edition, titled *Live Fire Training Evolutions in Structures*, was issued in 1986. It was well received and served as the basis for live fire training evolutions throughout the United States. The document was updated in a 1992 edition. In the 1997 revision, the committee combined NFPA 1403 with NFPA 1406, *Outside Live Fire Training Evolutions*, into a single document.

The committee appointed a task group to review the functionality of the 1997 edition in preparation for the current revision. The task group recommended a general updating of the standard. Edits were made to reflect increased experience with live fire training evolutions. The previous numbering of chapters and paragraphs has changed to reflect requirements in the 2000 edition of the *NFPA Manual of Style*.

In Memoriam, September 11, 2001

We pay tribute to the 343 members of FDNY who gave their lives to save civilian victims on September 11, 2001, at the World Trade Center. They are true American heroes in death, but they were also American heroes in life. We will keep them in our memory and in our hearts. They are the embodiment of courage, bravery, and dedication. May they rest in peace.

Technical Committee on Fire Service Training

William E. Peterson, *Chair*

Plano Fire Department, TX [E]

Rep. International Fire Marshals Association

Roger W. Bassett, R. W. Bassett & Associates, IL [SE]

John Martin Best, Reedy Creek Improvement District, FL [E]

Donald T. Brady, Symtron Systems Inc., NJ [M]

Gene P. Carlson, VFIS-Glatfelter Insurance Group, PA [I]
Rep. VFIS

Jack L. Cottet, Utica National Insurance Company, NY [I]

Nicholas J. Cricenti, Jr., SFC Engineering Partnership, Inc., NH [SE]

William E. Glover, High Temperature Linings (HTL), VA [U]

David C. Grupp, Kemper Insurance Companies, IL [I]

George Hall, US Air Force-HQ AFCEA, FL [U]

John W. Hoglund, University of Maryland, MD [E]

Larry D. Hughes, North Carolina Department of Insurance, NC [E]

James G. Kellam, Jr., Virginia Beach Fire Department, VA [U]

Rep. International Society of Fire Service Instructors

Kent W. Koelz, Palm Beach Fire/Rescue Department, FL [E]

Cortez Lawrence, Auburn Public Safety Department, AL [E]

Roger M. LeBoeuf, Elliott, LeBoeuf & Associates, VA [SE]

Robert A. Lincoln, Jr., Nassau County Fire Service Academy, NY [U]

John B. Lockwood, Bowie, MD [SE]

Francis T. May, Fire Facilities Inc., IL [M]

John Mike Myers, City of Las Vegas Fire Department, NV [E]

Thomas C. Quillin, Tallahassee Fire Department, FL [U]

Rodney D. Reid, Severns, Reid & Associates, Inc., IL [SE]

Michael T. Richardson, Bullard, KY [M]

Daniel N. Rossos, City of Portland Fire Bureau, OR [E]

James B. Straseske, Illinois Fire Service Institute, IL [U]

Phil Welch, Gaston College, NC [U]

Samuel L. Wilkin, Broward County Fire Rescue, FL [SE]

Alternates

Carl Goodson, Fire Protection Publications, OK [M]

(Vot. Alt. to IFSTA Rep.)

Steven J. Williamson, Symtron Systems Inc., NJ [M]

(Alt. to D. T. Brady)

Nonvoting

Edward W. Bent, Sacramento, CA

Jerry W. Laughlin, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on all fire service training techniques, operations, and procedures to develop maximum efficiency and proper utilization of available personnel. Such activities can include training guides for fire prevention, fire suppression, and other missions for which the fire service has responsibility.

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Contents

<p>Chapter 1 Administration 1403- 4</p> <p> 1.1 Scope 1403- 4</p> <p> 1.2 Purpose 1403- 4</p> <p> 1.3 Application 1403- 4</p> <p>Chapter 2 Referenced Publications 1403- 4</p> <p> 2.1 General 1403- 4</p> <p> 2.2 NFPA Publications 1403- 4</p> <p> 2.3 Other Publications. (Reserved) 1403- 4</p> <p>Chapter 3 Definitions 1403- 4</p> <p> 3.1 General 1403- 4</p> <p> 3.2 NFPA Official Definitions 1403- 4</p> <p> 3.3 General Definitions 1403- 4</p> <p>Chapter 4 Acquired Structures 1403- 4</p> <p> 4.1 Student Prerequisites 1403- 4</p> <p> 4.2 Structures and Facilities 1403- 5</p> <p> 4.3 Fuel Materials 1403- 6</p> <p> 4.4 Safety 1403- 6</p> <p> 4.5 Instructors 1403- 7</p> <p>Chapter 5 Gas-Fired Training Center Buildings ... 1403- 8</p> <p> 5.1 Student Prerequisites 1403- 8</p> <p> 5.2 Structures and Facilities 1403- 8</p> <p> 5.3 Fuel Materials 1403- 9</p> <p> 5.4 Safety 1403- 9</p> <p> 5.5 Instructors 1403-10</p> <p>Chapter 6 Non-Gas-Fired Training Center Buildings 1403-10</p> <p> 6.1 Student Prerequisites 1403-10</p>	<p> 6.2 Structures and Facilities 1403-11</p> <p> 6.3 Fuel Materials 1403-12</p> <p> 6.4 Safety 1403-12</p> <p> 6.5 Instructors 1403-13</p> <p>Chapter 7 Exterior Props 1403-14</p> <p> 7.1 Student Prerequisites 1403-14</p> <p> 7.2 Structures and Facilities 1403-14</p> <p> 7.3 Fuel Materials 1403-15</p> <p> 7.4 Safety 1403-15</p> <p> 7.5 Instructors 1403-16</p> <p>Chapter 8 Exterior Class B Fires 1403-17</p> <p> 8.1 Student Prerequisites 1403-17</p> <p> 8.2 Facilities 1403-17</p> <p> 8.3 Fuel Materials 1403-18</p> <p> 8.4 Safety 1403-18</p> <p> 8.5 Instructors 1403-19</p> <p>Chapter 9 Reports and Records 1403-20</p> <p> 9.1 General 1403-20</p> <p>Annex A Explanatory Material 1403-20</p> <p>Annex B Live Fire Evolution Sample Checklist 1403-26</p> <p>Annex C Responsibilities of Personnel 1403-27</p> <p>Annex D Heat Exhaustion and Heat Stroke in Training 1403-28</p> <p>Annex E Informational References 1403-28</p> <p>Index 1403-29</p>
---	---

NFPA 1403

Standard on

Live Fire Training Evolutions

2002 Edition

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

Information on referenced publications can be found in Chapter 2 and Annex E.

Chapter 1 Administration

1.1 Scope. This standard shall contain the minimum requirements for training fire suppression personnel engaged in fire-fighting operations under live fire conditions.

1.1.1 The minimum requirements for training shall comprise a basic system that can be adapted to local conditions to serve as a standard mechanism for live fire training.

1.2* Purpose. The purpose of this standard shall be to provide a process for conducting live fire training evolutions to ensure that they are conducted in safe facilities and that the exposure to health and safety hazards for the fire fighters receiving the training is minimized.

1.3 Application. Procedures for live fire training evolutions that involve marine structures or vessels and ground cover or wildland fires shall not be covered in this standard.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 30, *Flammable and Combustible Liquids Code*, 2000 edition.

NFPA 58, *Liquefied Petroleum Gas Code*, 2001 edition.

NFPA 59, *Utility LP-Gas Plant Code*, 2001 edition.

NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, 1997 edition.

NFPA 1142, *Standard on Water Supplies for Suburban and Rural Fire Fighting*, 2001 edition.

NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*, 2000 edition.

NFPA 1975, *Standard on Station/Work Uniforms for Fire and Emergency Services*, 1999 edition.

NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus for the Fire Service*, 1997 edition.

NFPA 1982, *Standard on Personal Alert Safety Systems (PASS)*, 1998 edition.

2.3 Other Publications. (Reserved)

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not included, common usage of the terms shall apply.

3.2 NFPA Official Definitions.

3.2.1* Authority Having Jurisdiction (AHJ). The organization, office, or individual responsible for approving equipment, materials, an installation, or a procedure.

3.2.2 Shall. Indicates a mandatory requirement.

3.2.3 Should. Indicates a recommendation or that which is advised but not required.

3.3 General Definitions.

3.3.1 Acquired Prop. A piece of equipment such as an automobile that was not designed for burning but is used for live fire training evolutions.

3.3.2 Building.

3.3.2.1 Acquired Building. A structure acquired by the authority having jurisdiction from a property owner for the purpose of conducting live fire training evolutions.

3.3.2.2* Training Center Burn Building. A structure specifically designed for conducting live fire training evolutions on a repetitive basis.

3.3.3 Demonstration. The act of showing a skill.

3.3.4 Evolution. A set of prescribed actions that result in an effective fireground activity.

3.3.5 Instructor. An individual qualified by the authority having jurisdiction to deliver fire fighter training, who has the training and experience to supervise students during live fire training evolutions.

3.3.6 Instructor-in-Charge. An individual qualified as an instructor and designated by the authority having jurisdiction to be in charge of the live fire training evolution.

3.3.7 Live Fire. Any unconfined open flame or device that can propagate fire to the building or other combustible materials.

3.3.8 Participant. Any student, instructor, safety officer, visitor, or other person who is involved in the live fire training evolution within the operations area.

3.3.9 Safety Officer. An individual appointed by the authority having jurisdiction as qualified to maintain a safe working environment at all live fire training evolutions.

3.3.10 Student. Any person who is present at the live fire training evolution for the purpose of receiving training.

Chapter 4 Acquired Structures

4.1 Student Prerequisites.

4.1.1* Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the job performance requirements for Fire Fighter I in NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, related to the following subjects:

- (1) Safety
- (2) Fire behavior
- (3) Portable extinguishers
- (4) Personal protective equipment
- (5) Ladders
- (6) Fire hose, appliances, and streams

- (7) Overhaul
- (8) Water supply
- (9) Ventilation
- (10) Forcible entry

4.1.2* Students participating in a live fire training evolution who received the required minimum training specified in 4.1.1 from other than the authority having jurisdiction shall present written evidence of having successfully completed the prescribed training prior to being permitted to participate in any live fire training evolution.

4.2 Structures and Facilities.

4.2.1* Any building that is considered for a structural fire training exercise shall be prepared for the live fire training evolution.

4.2.2* Preparation shall include application for and receipt of required permits and permissions.

4.2.3* Ownership of the acquired building shall be determined prior to its acceptance by the authority having jurisdiction.

4.2.4 Evidence of clear title shall be required for all structures acquired for live fire training evolutions.

4.2.5* Written permission shall be secured from the owner of the structure in order for the fire department to conduct live fire training evolutions within the acquired building.

4.2.6 A clear description of the anticipated condition of the acquired building at the completion of the evolution(s) and the method of returning the property to the owner shall be put in writing and shall be acknowledged by the owner of the structure.

4.2.7* Proof of insurance cancellation or a signed statement of nonexistence of insurance shall be provided by the owner of the structure prior to acceptance for use of the acquired building by the authority having jurisdiction.

4.2.8 The permits specified in this chapter shall be provided to outside, contract, or other separate training agencies by the authority having jurisdiction upon the request of those agencies.

4.2.9* All hazardous storage conditions shall be removed from the structure or neutralized in such a manner as to not present a safety problem during use of the structure for live fire training evolutions.

4.2.9.1 Closed containers and highly combustible materials shall be removed from the structure.

4.2.9.2 Oil tanks and similar closed vessels that cannot be removed shall be vented sufficiently to prevent an explosion or overpressure rupture.

4.2.9.3 Any hazardous or combustible atmosphere within the tank or vessel shall be rendered inert.

4.2.10 All hazardous structural conditions shall be removed or repaired so as to not present a safety problem during use of the structure for live fire training evolutions.

4.2.10.1 Floor openings shall be covered.

4.2.10.2 Missing stair treads and rails shall be repaired or replaced.

4.2.10.3 Dangerous portions of any chimney shall be removed.

4.2.10.4 Holes in walls and ceilings shall be patched.

4.2.10.5* Low-density combustible fiberboard and other unconventional combustible interior finishes shall be removed.

4.2.10.6* Extraordinary weight above the training area shall be removed.

4.2.11 All hazardous environmental conditions shall be removed prior to conducting live fire training evolutions in the structure.

4.2.11.1 Debris creating or contributing to unsafe conditions shall be removed.

4.2.11.2* Roof ventilation openings that are normally closed but can be opened in the event of an emergency shall be permitted to be utilized.

4.2.11.3 Utilities shall be disconnected.

4.2.11.4 Any toxic weeds, insect hives, or vermin that could present a potential hazard shall be removed.

4.2.11.5 All forms of asbestos deemed hazardous to personnel shall be removed by an approved asbestos removal contractor.

4.2.12 Exits from the building shall be identified and evaluated prior to each training burn.

4.2.12.1 Participants of the live fire training shall be made aware of exits from the building prior to each training burn.

4.2.13 Buildings that cannot be made safe as required by this chapter shall not be utilized for interior live fire training evolutions.

4.2.14 Adjacent buildings or property that might become involved shall be protected or removed.

4.2.15 Utility services adjacent to the live burn site shall be removed or protected.

4.2.16 Trees, brush, and surrounding vegetation that create a hazard to participants shall be removed.

4.2.17 Combustible materials, other than those intended for the live fire training evolution, shall be removed or stored in a protected area to preclude accidental ignition.

4.2.18 Property adjacent to the training site that could be affected by the smoke from the live fire training evolution, such as railroads, airports or heliports, and nursing homes, hospitals, or other similar facilities, shall be identified.

4.2.19 The persons in charge of the adjacent properties identified in 4.2.18 shall be informed of the date and time of the evolution.

4.2.20* Streets or highways in the vicinity of the training site shall be surveyed for potential effects from live fire training evolutions and safeguards shall be taken to eliminate possible hazards to motorists.

4.2.21 Fire lines shall be established to keep pedestrian traffic in the vicinity of the training site clear of the operations area of the live burn.

4.2.22* Awareness of weather conditions, wind velocity, and wind direction shall be maintained, including a final check for possible changes in weather conditions immediately before actual ignition.

4.2.23 The lead instructor shall determine the rate and duration of water flow necessary for each individual live fire training evolution, including the water necessary for control and extinguishment of the training fire, the supply necessary for

backup lines to protect personnel, and any water needed to protect exposed property.

4.2.23.1 The minimum water supply and delivery for live fire training evolutions shall meet the criteria identified in NFPA 1142, *Standard on Water Supplies for Suburban and Rural Fire Fighting*.

4.2.23.2 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand determined in 4.2.23.1 shall be available to handle exposure protection or unforeseen situations.

4.2.23.3* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

4.2.24 Areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.

4.2.24.1 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations.

4.2.24.2 If any of the apparatus described in 4.2.24.1 is in service to respond to an emergency, it shall be located in an area to facilitate a prompt response.

4.2.24.3 Where required or necessary, parking areas for police vehicles or for the press shall be designated.

4.2.24.4 A parking area for an ambulance or an emergency medical services vehicle shall be designated and located where it will facilitate a prompt response in the event of personal injury to participants in the evolution.

4.2.24.5 Ingress/egress routes shall be designated, identified, and monitored during the training evolutions to ensure their availability in the event of an emergency.

4.2.25 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants, in which all facets of each evolution to be conducted are discussed and assignments made for all crews participating in the training session are given.

4.2.25.1 The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed during the briefing.

4.2.25.2 A preburn plan shall be prepared and shall be utilized during the preburn briefing sessions.

4.2.25.3 All features of the training areas and structure shall be indicated on the preburn plan.

4.2.25.4 Prior to conducting any live fire training, all participants shall be required to conduct a walk-through of the structure in order to have a knowledge of and familiarity with the layout of the building and to facilitate any necessary evacuation of the building.

4.2.26 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.

4.2.26.1 Control measures such as ropes, signs, and fire line markings shall be posted to indicate the perimeter of the operations area.

4.2.26.2 Visitors who are allowed within the operations area perimeter to observe operations shall be escorted at all times.

4.2.26.3 Visitors allowed within the operations area perimeter shall be equipped with and shall wear complete protective clothing in accordance with 4.4.17.1 through 4.4.17.7.

4.2.27 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.

4.3 Fuel Materials.

4.3.1 The fuels that are utilized in live fire training evolutions shall have known burning characteristics that are as controllable as possible.

4.3.2 Unidentified materials, such as debris found in or around the structure that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be used.

4.3.3* Pressure-treated wood, rubber, and plastic, and straw or hay treated with pesticides or harmful chemicals shall not be used.

4.3.4* Fuel materials shall be used only in the amounts necessary to create the desired fire size.

4.3.5 The fuel load shall be limited to avoid conditions that could cause an uncontrolled flashover or backdraft.

4.3.6 Flammable or combustible liquids, as defined in NFPA 30, *Flammable and Combustible Liquids Code*, shall not be used in live fire training evolutions in acquired structures.

4.3.7* The instructor-in-charge shall assess the selected fire room environment for factors that can affect the growth, development, and spread of fire.

4.3.8* The instructor-in-charge shall document fuel loading including all of the following:

- (1) Furnishings
- (2) Wall and floor coverings and ceiling materials
- (3) Type of construction of the structure including type of roof and combustible void spaces
- (4) Dimensions of the room

4.3.9* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard.

4.3.10 An exercise stopped as a result of an assessed hazard according to 4.3.9 shall continue only when actions have been taken to reduce the hazard.

4.4 Safety.

4.4.1 A safety officer shall be appointed for all live fire training evolutions.

4.4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.

4.4.3 The responsibilities of the safety officer shall include, but shall not be limited to, the following:

- (1) Prevention of unsafe acts
- (2) Elimination of unsafe conditions

4.4.4 The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.

4.4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

4.4.6* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary.

4.4.6.1 Each hoseline shall be capable of delivering a minimum of 360 L/min (95 gpm).

4.4.6.2 Backup lines shall be provided to ensure protection for personnel on training attack lines.

4.4.7 The instructor-in-charge then shall assign the following personnel:

- (1) One instructor to each functional crew, which shall not exceed five students
- (2) One instructor to each backup line
- (3) Additional personnel to backup lines to provide mobility
- (4) One additional instructor for each additional functional assignment

4.4.8* Additional safety personnel, as deemed necessary by the safety officer, shall be located strategically within the structure to react to any unplanned or threatening situation or condition.

4.4.9 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.

4.4.10* A building evacuation plan shall be established, including an evacuation signal to be demonstrated to all participants in an interior live fire training evolution.

4.4.11 Emergency medical services shall be available on site to handle injuries.

4.4.12 Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.

4.4.13 A search of the structure shall be conducted to ensure that no unauthorized persons, animals, or objects are in the building immediately prior to ignition.

4.4.14 No person(s) shall play the role of a victim inside the building.

4.4.15 Only one fire at a time shall be permitted within an acquired structure.

4.4.16 The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.

4.4.17 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA).

4.4.17.1 All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn properly and are in serviceable condition.

4.4.17.2 Protective coats, trousers, hoods, footwear, helmets, and gloves shall have been manufactured to meet the requirements of NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*.

4.4.17.3 Self-contained breathing apparatus (SCBA) shall have been manufactured to meet the requirements of NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus for the Fire Service*.

4.4.17.4* Where station or work uniforms are worn by any participant, the station or work uniform shall have been manufactured to meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Fire and Emergency Services*.

4.4.17.5 Personal alarm devices shall have been manufactured to meet the requirements of NFPA 1982, *Standard on Personal Alert Safety Systems (PASS)*.

4.4.17.6 All students, instructors, safety personnel, and other personnel shall wear according to manufacturer's instructions all protective clothing and equipment specified in this chapter whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.

4.4.17.7* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from an SCBA air supply whenever operating under one or more of the following conditions:

- (1) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (2) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both
- (3) In any atmosphere that can become oxygen deficient or contaminated, or both
- (4) Below ground level

4.4.18 One person who is not a student shall be designated as the "ignition officer" to control the materials being burned.

4.4.18.1 The ignition officer shall wear full protective clothing, including self-contained breathing apparatus (SCBA), as required in 4.4.17.1 through 4.4.17.7, when performing this control function.

4.4.18.2 A charged hoseline shall accompany the ignition officer when he or she is igniting any fire.

4.4.18.3* The decision to ignite the training fire shall be made by the instructor-in-charge in coordination with the safety officer.

4.4.18.4 The fire shall be ignited by the ignition officer in the presence of and under the direct supervision of the safety officer.

4.5 Instructors.

4.5.1 All instructors shall be qualified to deliver fire fighter training according to the authority having jurisdiction.

4.5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.

4.5.3 Additional instructors shall be designated when factors such as extreme temperatures or large groups are present, and classes of long duration are planned.

4.5.4 The instructor-in-charge shall be responsible for full compliance with this standard.

4.5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn according to manufacturer's instructions.

4.5.6 Instructors shall take a head count when entering and exiting the building during an actual attack evolution conducted in accordance with this standard.

4.5.7 Instructors shall monitor and supervise all assigned students during the live fire training evolution.

4.5.8 The instructor-in-charge shall provide for rest and rehabilitation of members operating at the scene, including any necessary medical evaluation and treatment, food and fluid replenishment, and relief from climatic conditions. (*See Annex D.*)

Chapter 5 Gas-Fired Training Center Buildings

5.1 Student Prerequisites.

5.1.1* Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the job performance requirements for Fire Fighter I in NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, related to the following subjects:

- (1) Safety
- (2) Fire behavior
- (3) Portable extinguishers
- (4) Personal protective equipment
- (5) Ladders
- (6) Fire hose, appliances, and streams
- (7) Overhaul
- (8) Water supply
- (9) Ventilation
- (10) Forcible entry

5.1.2* Students participating in a live fire training evolution who have received the required minimum basic training from other than the authority having jurisdiction shall not be permitted to participate in any live fire training evolution without presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 5.1.1.

5.2 Structures and Facilities.

5.2.1* Strict safety practices shall be applied to all structures selected for live fire training evolutions.

5.2.2* Training center burn buildings shall be inspected visually for damage prior to live fire training evolutions.

5.2.2.1 Damage shall be documented.

5.2.2.2* The structural integrity of the building shall be evaluated and documented annually by a licensed professional engineer with burn building experience and expertise.

5.2.2.3* Part of the burn building evaluation shall include, once every five years, the removal and reinstallation of a representative area of thermal linings (if any) to inspect the hidden conditions behind the linings.

5.2.2.4 The engineer shall core solid structural concrete slabs and walls that have been exposed to temperatures in excess of 149°C (300°F) to check for hidden delamination and to test comprehensive strength once every 10 years for conventional (Portland) concrete and every three years for refractory (calcium aluminate) concrete.

5.2.2.5 Where the burn building damage is severe enough to affect the safety of the students, training shall not be permitted.

5.2.3 All doors, windows and window shutters, roof scuttles and automatic ventilators, mechanical equipment, lighting, manual or automatic sprinklers, and standpipes necessary for the live fire training evolution shall be checked and operated prior to any live fire training evolution to ensure they operate correctly.

5.2.4* All safety devices, such as thermometers, oxygen and toxic and combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.

5.2.5* For burn buildings that contain gas-fueled training systems, the instructors shall run the system prior to exposing students to live flames in order to ensure the correct operation of devices such as the gas valves, flame safeguard units, agent sensors, combustion fans, and ventilation fans.

5.2.6 Training center burn buildings shall be left in a safe condition upon completion of live fire training evolutions.

5.2.7 Debris hindering the access or egress of fire fighters shall be removed prior to the beginning of the next training exercises.

5.2.8 Pedestrian traffic in the vicinity of the training site shall be kept clear of the operations area of the live burn and fire lines shall be established for this purpose.

5.2.9 Awareness of weather conditions, wind velocity, and wind direction shall be maintained, including a final check for possible changes in weather conditions immediately before actual ignition.

5.2.10 The water supply for any individual live fire training evolution shall be assessed based on the extent of the evolutions to be performed.

5.2.10.1 Consideration shall be given to the control and extinguishment of the fire and the provision of backup lines to protect personnel.

5.2.10.2 The minimum water supply and delivery for the live fire training evolutions shall meet the criteria identified in NFPA 1142, *Standard on Water Supplies for Suburban and Rural Fire Fighting*.

5.2.10.3 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand determined in accordance with 5.2.10.2 shall be available to handle exposure protection or unforeseen situations.

5.2.10.4* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

Exception: A single source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

5.2.11 Adequate areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.

5.2.11.1 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations.

5.2.11.2 Consideration shall be given to locating this parking area to facilitate prompt response of apparatus in the event of an emergency.

5.2.11.3 Where required or necessary, parking areas for police or press vehicles shall be designated.

5.2.11.4 A parking area for an ambulance or an emergency medical services vehicle shall be designated.

5.2.11.5 Consideration shall be given to locating the “parking area” to facilitate prompt response in the event of personal injury to participants in the evolution.

5.2.11.6 Consideration shall be given to the designation and layout of ingress/egress routes in order to ensure their availability in the event of an emergency.

5.2.12 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants.

5.2.12.1 All facets of each evolution to be conducted shall be discussed in the preburn briefing, and assignments shall be made for all crews participating in the training session.

5.2.12.2 The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed during the preburn briefing.

5.2.12.3 A preburn plan shall be prepared and utilized during the preburn briefing sessions.

5.2.12.4 All features of the training areas and structure shall be indicated on the preburn plan.

5.2.13 Prior to conducting any live fire training, all participants shall be required to conduct a walk-through of the structure in order to have a knowledge of and familiarity with the layout of the building and to be able to facilitate any necessary evacuation of the building.

5.2.14 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.

5.2.14.1 Control measures such as ropes, signs, and fire line markings shall be used to indicate the perimeter of the operations area.

5.2.14.2 Visitors who are allowed within the operations area perimeter to observe operations shall be escorted at all times.

5.2.14.3 Visitors who are allowed within the operations area perimeter shall be equipped with and shall properly wear complete protective clothing in accordance with 5.4.17.1 through 5.4.17.7.

5.2.15 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.

5.2.16 There shall be ample room provided around all props such that there is space for all attack lines as well as backup lines to operate freely.

5.3 Fuel Materials.

5.3.1 The fuels that are utilized in live fire training evolutions shall have known burning characteristics that are as controllable as possible.

5.3.2 Unidentified materials, such as debris found in or around the structure that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be permitted to be used.

5.3.3* The use of flammable gas, such as propane and natural gas, shall be permitted only in burn buildings specifically designed for their use.

5.3.4 Liquefied versions of the gases specified in 5.3.3 shall not be permitted inside the burn building.

5.3.5* The instructor-in-charge shall assess the selected fire room environment for factors that can affect the growth, development, and spread of fire.

5.3.6* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard.

5.3.7 The exercise shall continue only when the appropriate actions have been taken to reduce the hazard.

5.4 Safety.

5.4.1 A safety officer shall be appointed for all live fire training evolutions.

5.4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.

5.4.3 The responsibilities of the safety officer shall include, but shall not be limited to, the following:

- (1) Prevention of unsafe acts
- (2) Elimination of unsafe conditions

5.4.4 The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.

5.4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

5.4.6 The safety officer shall be knowledgeable in the operation and location of safety features available within the burn building, such as emergency shutoff switches, gas shutoff valves, and evacuation alarms.

5.4.7* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary.

5.4.7.1 Each hoseline shall be capable of delivering a minimum of 360 L/min (95 gpm).

5.4.7.2 Backup lines shall be provided to ensure protection for personnel on training attack lines.

5.4.7.3 The instructor-in-charge shall assign the following personnel:

- (1) One instructor to each functional crew, which shall not exceed five students
- (2) One instructor to each backup line
- (3) Additional personnel to backup lines to provide mobility
- (4) One additional instructor for each additional functional assignment

5.4.8* Additional safety personnel, as deemed necessary by the safety officer, shall be located strategically within the structure to react to any unplanned or threatening situation or condition.

5.4.9 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.

5.4.10* A building evacuation plan shall be established, including an evacuation signal to be demonstrated to all participants in an interior live fire training evolution.

5.4.11 Emergency medical services shall be available on site to handle injuries.

5.4.12 Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.

5.4.13 A thorough search of the structure shall be conducted to ensure that no unauthorized persons, animals, or objects are in the building immediately prior to ignition.

5.4.14 No person(s) shall play the role of a victim inside the building.

5.4.15 Fires shall not be located in any designated exit paths.

5.4.16 The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.

5.4.17 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA).

5.4.17.1 All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn according to manufacturer's instructions and are in serviceable condition.

5.4.17.2 Protective coats, trousers, hoods, footwear, helmets, and gloves shall have been manufactured to meet the requirements of NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*.

5.4.17.3 Self-contained breathing apparatus (SCBA) shall have been manufactured to meet the requirements of NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus for the Fire Service*.

5.4.17.4* Where station or work uniforms are worn by any participant, the station or work uniform shall have been manufactured to meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Fire and Emergency Services*.

5.4.17.5 Personal alarm devices shall have been manufactured to meet the requirements of NFPA 1982, *Standard on Personal Alert Safety Systems (PASS)*.

5.4.17.6 All students, instructors, safety personnel, and other personnel shall wear all protective clothing and equipment specified in this chapter according to manufacturer's instructions whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.

5.4.17.7* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from an SCBA air supply whenever operating under one or more of the following conditions:

- (1) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (2) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both

(3) In any atmosphere that can become oxygen deficient or contaminated, or both

(4) Below ground level

5.4.18* The decision to ignite a training fire shall be made by the instructor-in-charge in coordination with the safety officer.

5.4.19 Fires shall not be ignited without an instructor visually confirming that the flame area is clear of personnel.

5.4.20 Flammable gas fires shall not be ignited manually.

5.5 Instructors.

5.5.1 All instructors shall be qualified to deliver fire fighter training according to the authority having jurisdiction.

5.5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.

5.5.3 Additional instructors shall be designated when factors such as extreme temperatures or large groups are present, and classes of long duration are planned.

5.5.4 The instructor-in-charge shall be responsible for full compliance with this standard.

5.5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn according to manufacturer's instructions.

5.5.6 Instructors shall take a head count when entering and exiting the building during an actual attack evolution conducted in accordance with this standard.

5.5.7 Instructors shall monitor and supervise all assigned students closely during the live fire training evolution.

5.5.8 The instructor-in-charge shall provide for rest and rehabilitation of members operating at the scene, including any necessary medical evaluation and treatment, food and fluid replenishment, and relief from climatic conditions. (*See Annex D.*)

5.5.9 Instructors responsible for conducting live fire training evolutions with a gas-fueled training system shall be trained in the complete operation of the system.

5.5.10 The training of instructors shall be performed by an individual authorized by the gas-fueled training system manufacturer or others qualified to perform this type of training.

5.5.11 Where concurrent, multiple, live fire training evolutions are being conducted in a specifically designed burn building, the identity of the instructor-in-charge of the evolutions shall be clear to all participants.

5.5.12 It shall be this instructor's responsibility to coordinate overall burn building fireground activities to ensure proper levels of safety.

Chapter 6 Non-Gas-Fired Training Center Buildings

6.1 Student Prerequisites.

6.1.1* Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the job performance requirements for Fire Fighter I in NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, related to the following subjects:

- (1) Safety

- (2) Fire behavior
- (3) Portable extinguishers
- (4) Personal protective equipment
- (5) Ladders
- (6) Fire hose, appliances, and streams
- (7) Overhaul
- (8) Water supply
- (9) Ventilation
- (10) Forcible entry

6.1.2* Students participating in a live fire training evolution who have received the required minimum basic training from other than the authority having jurisdiction shall not be permitted to participate in any live fire training evolution without presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 6.1.1.

6.2 Structures and Facilities.

6.2.1* Strict safety practices shall be applied to all structures selected for live fire training evolutions.

6.2.2* Training center burn buildings shall be inspected visually for damage prior to live fire training evolutions.

6.2.2.1 Damage shall be documented.

6.2.2.2* The structural integrity of the building shall be evaluated and documented annually by a licensed professional engineer with burn building experience and expertise.

6.2.2.3* Part of the burn building evaluation shall include, once every five years, the removal and reinstallation of a representative area of thermal linings (if any) to inspect the hidden conditions behind the linings.

6.2.2.4 The engineer shall core solid structural concrete slabs and walls that have been exposed to temperatures in excess of 149°C (300°F) to check for hidden delaminations and to test compressive strength once every 10 years for conventional (Portland) concrete and every three years for refractory (calcium aluminate) concrete.

6.2.2.5 Where the burn building damage is severe enough to affect the safety of the students, training shall not be permitted.

6.2.3 All doors, windows and window shutters, roof scuttles and automatic ventilators, mechanical equipment, lighting, manual or automatic sprinklers, and standpipes necessary for the live fire training evolution shall be checked and operated prior to any live fire training evolution to ensure they operate correctly.

6.2.4* All safety devices, such as thermometers, oxygen and toxic and combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.

6.2.5 Training center burn buildings shall be left in a safe condition upon completion of live fire training evolutions.

6.2.6 Debris hindering the access or egress of fire fighters shall be removed prior to the beginning of the next training exercises.

6.2.7 In preparation for live fire training, an inspection of the structure shall be made to determine that the floors, walls, stairs, and other structural components are capable of withstanding the weight of contents, participants, and accumulated water.

6.2.8 Property adjacent to the training site that could be affected by the smoke from the live fire training evolution, such as railroads, airports or heliports, and nursing homes, hospitals, or other similar facilities, shall be identified.

6.2.9 The persons in charge of the properties described in 6.2.8 shall be informed of the date and time of the evolution.

6.2.10* Streets or highways in the vicinity of the training site shall be surveyed for potential effects from live fire training evolutions, and safeguards shall be taken to eliminate any possible hazard to motorists.

6.2.11 Pedestrian traffic in the vicinity of the training site shall be kept clear of the operations area of the live burn by the use of fire lines.

6.2.12 Awareness of weather conditions, wind velocity, and wind direction shall be maintained, including a final check for possible changes in weather conditions immediately before actual ignition.

6.2.13 The water supply for any individual live fire training evolution shall be assessed based on the extent of the evolutions to be performed.

6.2.13.1 Consideration shall be given to the control and extinguishment of the fire and the provision of necessary backup lines to protect personnel.

6.2.13.2 The minimum water supply and delivery for live fire training evolutions shall meet the criteria identified in NFPA 1142, *Standard on Water Supplies for Suburban and Rural Fire Fighting*.

6.2.13.3 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand determined in accordance with 6.2.13.2 shall be available to handle exposure protection or unforeseen situations.

6.2.13.4* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

Exception: A single source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

6.2.14 Areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.

6.2.14.1 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations.

6.2.14.2 Consideration shall be given to locating this area in order to facilitate prompt response of apparatus in the event of an emergency.

6.2.14.3 Where required or necessary, parking areas for police vehicles or for the press shall be designated.

6.2.14.4 A parking area for an ambulance or an emergency medical services vehicle shall be designated.

6.2.14.5 Consideration shall be given to locating this area to facilitate prompt response in the event of a personal injury to participants in the evolution.

6.2.14.6 Consideration shall be given to the designation and layout of ingress/egress routes in order to ensure their availability in the event of an emergency.

6.2.15 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants.

6.2.15.1 All facets of each evolution to be conducted shall be discussed in the preburn briefing, and assignments shall be made for all crews participating in the training session.

6.2.15.2 The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed during the preburn briefing.

6.2.15.3 A preburn plan shall be prepared and shall be utilized during the preburn briefing sessions.

6.2.15.4 All features of the training areas and structure shall be indicated on the preburn plan.

6.2.16 Prior to conducting any live fire training, all participants shall be required to conduct a walk-through of the structure in order to have a knowledge of and familiarity with the layout of the building and to facilitate any necessary evacuation of the building.

6.2.17 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.

6.2.17.1 Control measures such as ropes, signs, and fire line markings shall be posted to indicate the perimeter of the operations area.

6.2.17.2 Visitors who are allowed within the operations area perimeter to observe operations shall be escorted at all times.

6.2.17.3 Visitors who are allowed within the operations area perimeter shall be equipped with and shall wear complete protective clothing according to manufacturer's instructions and in accordance with 6.4.17.1 through 6.4.17.7.

6.2.18 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.

6.3 Fuel Materials.

6.3.1 The fuels that are utilized in live fire training evolutions shall have known burning characteristics that are as controllable as possible.

6.3.2 Unidentified materials, such as debris found in or around the structure that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be permitted to be used.

6.3.3 Fuel materials shall be used only in the amounts necessary to create the desired fire size.

6.3.4* Pressure-treated wood, rubber, and plastic, and straw or hay treated with pesticides or harmful chemicals shall not be permitted to be used.

6.3.5 The fuel load shall be limited to avoid conditions that could cause an uncontrolled flashover or backdraft.

6.3.6* The use of flammable or combustible liquids, as defined in NFPA 30, *Flammable and Combustible Liquids Code*, shall not be permitted to be used in live fire training evolutions in structures.

Exception: Limited quantities of combustible liquid with a flash point above 38°C (100°F) shall be permitted to be used in a training center burn building that has been specifically engineered to accommodate this fuel.

6.3.7* The instructor-in-charge shall assess the selected fire room environment for factors that can affect the growth, development, and spread of the fire.

6.3.8* The instructor-in-charge shall document fuel loading including all of the following:

- (1) Furnishings
- (2) Wall and floor coverings and ceiling materials
- (3) Type of construction of the structure, including type of roof and combustible void spaces
- (4) Dimensions of room

6.3.9* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard.

6.3.10 The exercise shall continue only when the actions have been taken to reduce the hazard.

6.4 Safety.

6.4.1 A safety officer shall be appointed for all live fire training evolutions.

6.4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.

6.4.3 The responsibilities of the safety officer shall include, but shall not be limited to, the following:

- (1) Prevention of unsafe acts
- (2) Elimination of unsafe conditions

6.4.4 The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.

6.4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

6.4.6 The safety officer shall be knowledgeable in the operation and location of safety features available within the burn building, such as emergency shutoff switches, gas shutoff valves, and evacuation alarms.

6.4.7* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary.

6.4.7.1 Backup lines shall be provided to ensure protection for personnel on training attack lines.

6.4.7.2 Each hoseline shall be capable of delivering a minimum of 360 L/min (95 gpm).

6.4.7.3 The instructor-in-charge shall assign the following personnel:

- (1) One instructor to each functional crew, which shall not exceed five students
- (2) One instructor to each backup line
- (3) Additional personnel to backup lines to provide mobility
- (4) One additional instructor for each additional functional assignment

6.4.8* Additional safety personnel, as deemed necessary by the safety officer, shall be located strategically within the structure to react to any unplanned or threatening situation or condition.

6.4.9 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.

6.4.10* A building evacuation plan shall be established, including an evacuation signal to be demonstrated to all participants in an interior live fire training evolution.

6.4.11 Emergency medical services shall be available on site to handle injuries.

6.4.12 Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.

6.4.13 A search of the structure shall be conducted to ensure that no unauthorized persons, animals, or objects are in the building immediately prior to ignition.

6.4.14 No person(s) shall play the role of a victim inside the building.

6.4.15 Fires shall not be located in any designated exit paths.

6.4.16 The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.

6.4.17 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA).

6.4.17.1 All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn according to manufacturer's instruction and are in serviceable condition.

6.4.17.2 Protective coats, trousers, hoods, footwear, helmets, and gloves shall have been manufactured to meet the requirements of NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*.

6.4.17.3 Self-contained breathing apparatus (SCBA) shall have been manufactured to meet the requirements of NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus for the Fire Service*.

6.4.17.4* Where station or work uniforms are worn by any participant, the station or work uniform shall have been manufactured to meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Fire and Emergency Services*.

6.4.17.5 Personal alarm devices shall have been manufactured to meet the requirements of NFPA 1982, *Standard on Personal Alert Safety Systems (PASS)*.

6.4.17.6 All students, instructors, safety personnel, and other personnel shall wear all protective clothing and equipment specified in this chapter according to manufacturer's instructions whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.

6.4.17.7* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from an SCBA air supply whenever operating under one or more of the following conditions:

- (1) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (2) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both
- (3) In any atmosphere that can become oxygen deficient or contaminated, or both
- (4) Below ground level

6.4.18 One person who is not a student shall be designated as the "ignition officer" to control the materials being burned.

6.4.18.1 The ignition officer shall wear full protective clothing, including self-contained breathing apparatus (SCBA), as required in 6.4.17.1 through 6.4.17.7, when performing this control function.

6.4.18.2 A charged hoseline shall accompany the ignition officer when he or she is igniting any fire.

6.4.18.3* The decision to ignite the training fire shall be made by the instructor-in-charge in coordination with the safety officer.

6.4.18.4 The fire shall be ignited by the ignition officer in the presence of and under the direct supervision of the safety officer.

6.5 Instructors.

6.5.1 All instructors shall be qualified to deliver fire fighter training according to the authority having jurisdiction.

6.5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.

6.5.3 Additional instructors shall be designated when factors such as extreme temperatures or large groups are present, and classes of long duration are planned.

6.5.4 The instructor-in-charge shall be responsible for full compliance with this standard.

6.5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn according to manufacturer's instructions.

6.5.6 Instructors shall take a head count when entering and exiting the building during an actual attack evolution conducted in accordance with this standard.

6.5.7 Instructors shall monitor and supervise all assigned students closely during the live fire training evolution.

6.5.8 The instructor-in-charge shall consider the circumstances of each training session and make provisions for the rest and rehabilitation of members operating at the scene, including medical evaluation and treatment, food and fluid replenishment, and relief from climate conditions, in accordance with the circumstances of the training session. (*See Annex D.*)

6.5.9 Where concurrent, multiple, live fire training evolutions are being conducted in a specifically designed burn building, the identity of the instructor-in-charge shall be clear to all participants.

6.5.10 It shall be the instructor-in-charge's responsibility to coordinate overall burn building fireground activities to ensure proper levels of safety.

Chapter 7 Exterior Props

7.1 Student Prerequisites.

7.1.1* Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the job performance requirements for Fire Fighter I in NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, related to the following subjects:

- (1) Safety
- (2) Fire behavior
- (3) Portable extinguishers
- (4) Personal protective equipment
- (5) Ladders
- (6) Fire hose, appliances, and streams
- (7) Overhaul
- (8) Water supply
- (9) Ventilation
- (10) Forcible entry

7.1.2* Students participating in a live fire training evolution who have received the required minimum basic training from other than the authority having jurisdiction shall not be permitted to participate in any live fire training evolution without presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 7.1.1.

7.2 Structures and Facilities.

7.2.1* Strict safety practices shall be applied to all exterior props selected for live fire training evolutions.

7.2.2 For outside training, care shall be taken to select areas that limit the hazards to both personal safety and the environment.

7.2.3 The training site shall be flat and open without obstructions that can interfere with fire-fighting operations.

7.2.4 Where using live training fires outside, the ground cover shall be such that it does not contribute to the fire.

7.2.5 The ground cover shall be impervious and of such topography that the runoff from live fire does not enter municipal, private, or public waters or other sensitive areas.

7.2.6 Exterior props shall be inspected visually for damage prior to live fire training evolutions.

7.2.6.1 Damage to exterior props shall be documented.

7.2.6.2 The structural integrity of the props shall be evaluated and documented annually.

7.2.7 All safety devices, such as thermometers, oxygen and toxic and combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.

7.2.8 Exterior props shall be left in a safe condition upon completion of live fire training evolutions.

7.2.9 Debris hindering the access of fire fighters shall be removed prior to the beginning of the next training exercise.

7.2.10 All required permits to conduct live fire training evolutions shall be obtained.

7.2.11 The permits specified in this chapter shall be provided to outside, contract, or other separate training agen-

cies by the authority having jurisdiction upon the request of those agencies.

7.2.12 Adjacent buildings or property that might become ignited and involved in fire shall be protected or removed.

7.2.13 Utility services adjacent to the live burn site shall be removed or protected.

7.2.14 Trees, brush, and surrounding vegetation that create a hazard to participants shall be removed.

7.2.15 Combustible materials, other than those intended for the live fire training evolution, shall be removed or stored in a protected area to preclude accidental ignition.

7.2.16 Property adjacent to the training site that could be affected by the smoke from the live fire training evolution, such as railroads, airports or heliports, and nursing homes, hospitals, or other similar facilities, shall be identified.

7.2.17 The persons in charge of the properties described in 7.2.16 shall be informed of the date and time of the evolution.

7.2.18* Streets or highways in the vicinity of the training site shall be surveyed for potential effects from live fire training evolutions and safeguards shall be taken to eliminate possible hazards to motorists.

7.2.19 Pedestrian traffic in the vicinity of the training site shall be kept clear of the operations area of the live burn, and fire lines shall be established for this purpose.

7.2.20 Awareness of weather conditions, wind velocity, and wind direction shall be maintained, including a final check for possible changes in weather conditions immediately before actual ignition.

7.2.21 The water supply for any individual live fire training evolution shall be assessed based on the extent of the evolution to be performed.

7.2.21.1 Consideration shall be given to the control and extinguishment of the fire and the provision of necessary backup lines to protect personnel.

7.2.21.2 The minimum water supply and delivery for the live fire training evolutions shall meet the criteria identified in NFPA 1142, *Standard on Water Supplies for Suburban and Rural Fire Fighting*.

7.2.21.3 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand determined in accordance with 7.2.21.2 shall be available to handle exposure protection or unforeseen situations.

7.2.21.4* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

Exception: A single source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

7.2.22 Areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.

7.2.22.1 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations.

7.2.22.2 Consideration shall be given to locating this parking area in order to facilitate response of apparatus in the event of an emergency.

7.2.22.3 Where required or necessary, parking areas for police or press vehicles shall be designated.

7.2.22.4 A parking area for an ambulance or an emergency medical services vehicle shall be designated.

7.2.22.5 Consideration shall be given to locating this parking area to facilitate prompt response in the event of personal injury to participants in the evolution.

7.2.22.6 Consideration shall be given to the designation and layout of ingress/egress routes in order to ensure their availability in the event of an emergency.

7.2.23 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants.

7.2.23.1 All facets of each evolution to be conducted shall be discussed and assignments shall be made for all crews participating in the training session.

7.2.23.2 The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed in the preburn briefing.

7.2.23.3 A preburn plan shall be prepared and utilized during the preburn briefing sessions.

7.2.23.4 All features of the training areas and structure shall be indicated on the plan.

7.2.24 Prior to conducting any live fire training, all participants shall have a knowledge of and familiarity with the prop or props being used for the evolution.

7.2.25 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.

7.2.25.1 Control measures such as ropes, signs, and fire line markings shall be used to indicate the perimeter of the operations area.

7.2.25.2 Visitors who are allowed within the operations area perimeter shall be escorted at all times.

7.2.25.3 Visitors who are allowed within the operations area perimeter shall be equipped with and shall wear complete protective clothing according to manufacturer's instructions and in accordance with 7.4.16 through 7.4.16.7.

7.2.26 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.

7.2.27 There shall be room provided around all props so that there is space for all attack lines as well as backup lines to operate freely.

7.3 Fuel Materials.

7.3.1 The fuels that are utilized in live fire training evolutions shall have known burning characteristics that are as controllable as possible.

7.3.2 Unidentified materials, such as debris found in or around the site that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be permitted to be used.

7.3.3* Fuel materials shall be used only in the amounts necessary to create the desired fire size.

7.3.4 Pressure-treated wood, rubber, and plastic, and straw or hay treated with pesticides or harmful chemicals shall not be permitted to be used.

7.3.5* The instructor-in-charge shall assess the selected fire room environment for factors that can affect the growth, development, and spread of the fire.

7.3.6* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard.

7.3.7 The exercise shall continue only when actions have been taken to reduce the hazard.

7.3.8 Props used for outside live fire training shall be designed specifically for the evolution to be performed.

7.3.9* All props that use pressure to move fuel to the fire shall be equipped with remote fuel shutoffs outside of the safety perimeter but within sight of the prop and the entire field of attack for the prop.

7.3.10 During the entire time the prop is in use, the remote shutoff shall be continuously attended by safety personnel trained in its operation.

7.3.11 Liquefied petroleum gas props shall be equipped with all safety features as described in NFPA 58, *Liquefied Petroleum Gas Code*, and NFPA 59, *Utility LP-Gas Plant Code*.

7.3.12 Where the evolution involves the failure of a safety feature, the failed part shall be located downstream from the properly functioning safety feature.

7.3.13 Measures shall be taken where using flammable or combustible liquids to prevent runoff from contaminating the surrounding area.

7.3.14 There shall be oil separators for cleaning the runoff water.

7.3.15* Vehicles used as props for live fire training shall have all fluid reservoirs, tanks, shock absorbers, drive shafts, and other gas-filled closed containers removed, vented, or drained prior to any ignition.

7.3.16 For flammable metal fires, there shall be a sufficient quantity of the proper extinguishing agent available so that all attack crews have an adequate supply as well as a 150 percent reserve for the use of the backup crews.

7.4 Safety.

7.4.1 A safety officer shall be appointed for all live fire training evolutions.

7.4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.

7.4.3 The responsibilities of the safety officer shall include, but shall not be limited to, the following:

- (1) Prevention of unsafe acts
- (2) Elimination of unsafe conditions

7.4.4 The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.

7.4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

7.4.6 Backup lines shall be provided to ensure protection for personnel on training attack lines.

7.4.7* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary.

7.4.7.1 Each hoseline shall be capable of delivering a minimum of 360 L/min (95 gpm).

7.4.7.2 The instructor-in-charge shall assign the following personnel:

- (1) One instructor to each functional crew, which shall not exceed five students
- (2) One instructor to each backup line
- (3) Additional personnel to backup lines to provide mobility
- (4) One additional instructor for each additional functional assignment
- (5) One safety person to each manually activated safety station

7.4.8* Additional safety personnel, as deemed necessary by the safety officer, shall be located strategically within the area to react to any unplanned or threatening situation or condition.

7.4.9 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.

7.4.10 Emergency medical services shall be available on site to handle injuries.

7.4.11 Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.

7.4.12 One person who is not a student shall be designated to control the materials being burned and to ignite the training fire in the presence of and under the direct supervision of a safety officer.

7.4.12.1 The person designated to control the materials being burned and to ignite the training fire shall wear full protective clothing including self-contained breathing apparatus (SCBA) as required in 7.4.16.1 through 7.4.16.7 of this standard.

7.4.12.2 The decision to ignite the training fire shall be made by the instructor-in-charge, in coordination with the safety officer.

7.4.13 No person(s) shall play the role of a victim inside the building.

7.4.14 Fires shall not be located in any designated exit paths.

7.4.15 The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.

7.4.16 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA).

7.4.16.1 All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn according to manufacturer's instructions and are in serviceable condition.

7.4.16.2 Protective coats, trousers, hoods, footwear, helmets, and gloves shall have been manufactured to meet the requirements of NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*.

Exception: For outside fires, those persons who do not engage in or are not exposed to the hazards of structural fire fighting shall be permitted to use helmets that meet federal OSHA requirements.

7.4.16.3 Self-contained breathing apparatus (SCBA) shall have been manufactured to meet the requirements of NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus for the Fire Service*.

7.4.16.4* Where station or work uniforms are worn by any participant, the station or work uniform shall have been manufactured to meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Fire and Emergency Services*.

7.4.16.5 Personal alarm devices shall have been manufactured to meet the requirements of NFPA 1982, *Standard on Personal Alert Safety Systems (PASS)*.

7.4.16.6 All students, instructors, safety personnel, and other personnel shall wear all protective clothing and equipment specified in this chapter according to manufacturer's instructions whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.

7.4.16.7* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from an SCBA air supply whenever operating under one or more of the following conditions:

- (1) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (2) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both
- (3) In any atmosphere that can become oxygen deficient or contaminated, or both
- (4) Below ground level

7.5 Instructors.

7.5.1 All instructors shall be qualified to deliver fire fighter training according to the authority having jurisdiction.

7.5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.

7.5.3 Additional instructors shall be designated when factors such as extreme temperatures or large groups are present, and classes of long duration are planned.

7.5.4 The instructor-in-charge shall be responsible for full compliance with this standard.

7.5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn according to manufacturer's instructions.

7.5.6 Instructors shall take a head count when entering and exiting the area during an actual attack evolution conducted in accordance with this standard.

7.5.7 Instructors shall monitor and supervise all assigned students closely during the live fire training evolution.

7.5.8 The instructor-in-charge shall consider the circumstances of each training session and make suitable provisions for the rest and rehabilitation of members operating at the scene, including medical evaluation and treatment, food and fluid replenishment, and relief from climate conditions, in accordance with the circumstances of the training session. (*See Annex D.*)

7.5.9 Instructors responsible for conducting live fire training evolutions with a gas-fueled training system shall be trained in the complete operation of the system.

7.5.10 The training of instructors shall be performed by an individual authorized by the gas-fueled training system manufacturer.

Chapter 8 Exterior Class B Fires

8.1 Student Prerequisites.

8.1.1* Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the job performance requirements for Fire Fighter I in NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, related to the following subjects:

- (1) Safety
- (2) Fire behavior
- (3) Portable extinguishers
- (4) Personal protective equipment
- (5) Ladders
- (6) Fire hose, appliances, and streams
- (7) Overhaul
- (8) Water supply
- (9) Ventilation
- (10) Forcible entry

8.1.2* Students participating in a live fire training evolution who have received the required minimum basic training from other than the authority having jurisdiction shall not be permitted to participate in any live fire training evolution without presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 8.1.1.

8.2 Facilities.

8.2.1* Strict safety practices shall be applied to all props and areas selected for live fire training evolutions.

8.2.2 For outside training, care shall be taken to select areas that limit the hazards to both personal safety and the environment.

8.2.3 The training site shall be flat and open without obstructions that can interfere with fire-fighting operations.

8.2.4 Where using live training fires outside, the ground cover shall be such that it does not contribute to the fire.

8.2.5 The ground cover shall be impervious and of such topography that the runoff from live fire does not enter municipal, private, or public waters or other sensitive areas.

8.2.6 The burn area shall be inspected visually for damage prior to live fire training evolutions.

8.2.7 Damage in the burn area shall be documented.

8.2.8 All safety devices, such as thermometers, oxygen and toxic and combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.

8.2.9 Props shall be left in a safe condition upon completion of live fire training evolutions.

8.2.10 Debris hindering the access of fire fighters shall be removed prior to the beginning of the next training exercise.

8.2.11 All required permits to conduct live fire training evolutions shall be obtained.

8.2.12 The permits specified in this chapter shall be provided to outside, contract, or other separate training agencies by the authority having jurisdiction upon the request of those agencies.

8.2.13 Adjacent buildings or property that might become ignited shall be protected properly or removed.

8.2.14 Utility services adjacent to the live burn site shall be removed or protected.

8.2.15 Trees, brush, and surrounding vegetation that create a hazard to participants shall be removed.

8.2.16 Combustible materials, other than those intended for the live fire training evolution, shall be removed or stored in a protected area to preclude accidental ignition.

8.2.17 Property adjacent to the training site that could be affected by the smoke from the live fire training evolution, such as railroads, airports or heliports, and nursing homes, hospitals, or other similar facilities, shall be identified.

8.2.18 The persons in charge of the properties described in 8.2.17 shall be informed of the date and time of the evolution.

8.2.19* Streets or highways in the vicinity of the training site shall be surveyed for potential effects from live fire training evolutions and safeguards shall be taken to eliminate possible hazards to motorists.

8.2.20 Pedestrian traffic in the vicinity of the training site shall be kept clear of the operations area of the live burn, and fire lines shall be established for this purpose.

8.2.21 Awareness of weather conditions, wind velocity, and wind direction shall be maintained, including a final check for possible changes in weather conditions immediately before actual ignition.

8.2.22 The water supply for any individual live fire training evolution shall be assessed based on the extent of the evolution to be performed.

8.2.22.1 Consideration shall be given to the proper control and extinguishment of the fire and the provision of necessary backup lines to protect personnel.

8.2.22.2 The minimum water supply and delivery for the live fire training evolutions shall meet the criteria identified in NFPA 1142, *Standard on Water Supplies for Suburban and Rural Fire Fighting*.

8.2.22.3 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand determined in accordance with 8.2.22.2 shall be available to handle exposure protection or unforeseen situations.

8.2.22.4* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

Exception: A single source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

8.2.23 Adequate areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.

8.2.23.1 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations.

8.2.23.2 Consideration shall be given to locating this parking area in order to facilitate prompt response of apparatus in the event of an emergency.

8.2.23.3 Where required, parking areas for police or press vehicles shall be designated.

8.2.23.4 A parking area for an ambulance or an emergency medical services vehicle shall be designated in an area to facilitate prompt response in the event of personal injury to participants in the evolution.

8.2.23.5 Consideration shall be given to the designation and layout of ingress/egress routes in order to ensure their availability in the event of an emergency.

8.2.24 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants.

8.2.24.1 All facets of each evolution to be conducted shall be discussed, and assignments shall be made for all crews participating in the training session.

8.2.24.2 The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed in the preburn briefing.

8.2.24.3 A preburn plan shall be prepared and shall be utilized during the preburn briefing sessions.

8.2.24.4 All features of the training areas shall be indicated on the plan.

8.2.25 Prior to conducting any live fire training, all participants shall have a knowledge of and familiarity with the prop or props being used for the evolution.

8.2.26 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.

8.2.26.1 Control measures such as ropes, signs, and fire line markings shall be used to indicate the perimeter of the operations area.

8.2.26.2 Visitors who are allowed within the operations area perimeter shall be escorted at all times.

8.2.26.3 Visitors who are allowed within the operations area perimeter shall wear complete protective clothing according to manufacturer's instructions in accordance with 8.4.16.1 through 8.4.16.7.

8.2.27 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for

the start of the training fire, shall be removed from the operations area.

8.2.28 There shall be room provided around all props so that there is space for all attack lines as well as backup lines to operate freely.

8.3 Fuel Materials.

8.3.1 The fuels that are utilized in live exterior Class B fire training evolutions shall have known burning characteristics that are as controllable as possible.

8.3.2 Unidentified materials found in or around the structure that could burn in unanticipated ways, react violently, or create environmental or health hazards shall not be permitted to be used.

8.3.3* Fuel materials shall be used only in the amounts necessary to create the desired fire size.

8.3.4* The instructor-in-charge shall assess the selected fire environment for factors that can affect the growth, development, and spread of the fire.

8.3.5* The instructor-in-charge shall document fuel loading.

8.3.6* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard.

8.3.7 The exercise shall continue only when actions have been taken to reduce the hazard.

8.3.8 Props used for outside live fire training shall be designed specifically for the evolution to be performed.

8.3.9* All props that use pressure to move fuel to the fire shall be equipped with remote fuel shutoffs outside of the safety perimeter but within sight of the prop and the entire field of attack for the prop.

8.3.10 During the entire time the prop is in use, the remote shutoff shall be continuously attended by safety personnel trained in its operation.

8.3.11 Liquefied petroleum gas props shall be equipped with all safety features as described in NFPA 58, *Liquefied Petroleum Gas Code*, and NFPA 59, *Utility LP-Gas Plant Code*.

8.3.12 Where the evolution involves the failure of a safety feature, the failed part shall be located downstream from the properly functioning safety feature.

8.3.13 Measures shall be taken where using flammable or combustible liquids to prevent runoff from contaminating the surrounding area.

8.3.14 There shall be oil separators for cleaning the runoff water.

8.4 Safety.

8.4.1 A safety officer shall be appointed for all live fire training evolutions.

8.4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.

8.4.3 The responsibilities of the safety officer shall include, but shall not be limited to, the following:

- (1) Prevention of unsafe acts
- (2) Elimination of unsafe conditions

8.4.4 The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.

8.4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

8.4.6 The safety officer shall be knowledgeable in the operation and location of safety features available, such as emergency shutoff switches, gas shutoff valves, and evacuation alarms.

8.4.7* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary.

8.4.7.1 Each hoseline shall be capable of delivering a minimum of 360 L/min (95 gpm).

8.4.7.2 Backup lines shall be provided to ensure adequate protection for personnel on training attack lines.

8.4.8 The instructor-in-charge shall assign the following personnel:

- (1) One instructor to each functional crew, which shall not exceed five students
- (2) One instructor to each backup line
- (3) Additional personnel to backup lines to provide mobility
- (4) One additional instructor for each additional functional assignment
- (5) One safety person to each manually activated safety station

8.4.9 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.

8.4.10 Emergency medical services shall be available on site to handle injuries.

8.4.11 Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.

8.4.12 One person who is not a student shall be designated to control the materials being burned and to ignite the training fire in the presence of and under the direct supervision of a safety officer.

8.4.12.1 The person designated to control the materials being burned and to ignite the training fire shall wear full protective clothing including self-contained breathing apparatus (SCBA) as required in 8.4.16.1 through 8.4.16.7 of this standard.

8.4.12.2 The decision to ignite the training fire shall be made by the instructor-in-charge, in coordination with the safety officer.

8.4.13 No person(s) shall play the role of a victim inside the building.

8.4.14 Fires shall not be located in any designated exit paths.

8.4.15 The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.

8.4.16 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA).

8.4.16.1 All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn according to manufacturer's instructions and are in serviceable condition.

8.4.16.2* Protective coats, trousers, hoods, footwear, helmets, and gloves shall have been manufactured to meet the requirements of NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*.

Exception: For outside fires, those persons who do not engage in or are not exposed to the hazards of structural fire fighting shall be permitted to use helmets that meet federal OSHA requirements.

8.4.16.3 Self-contained breathing apparatus (SCBA) shall have been manufactured to meet the requirements of NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus for the Fire Service*.

8.4.16.4* Where station or work uniforms are worn by any participant, the station or work uniform shall have been manufactured to meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Fire and Emergency Services*.

8.4.16.5 Personal alarm devices shall have been manufactured to meet the requirements of NFPA 1982, *Standard on Personal Alert Safety Systems (PASS)*.

8.4.16.6 All students, instructors, safety personnel, and other personnel shall wear all protective clothing and equipment specified in this chapter according to manufacturer's instructions whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.

8.4.16.7* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from an SCBA air supply whenever operating under one or more of the following conditions:

- (1) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (2) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both
- (3) In any atmosphere that can become oxygen deficient or contaminated, or both
- (4) Below ground level

8.5 Instructors.

8.5.1 All instructors shall be deemed qualified to deliver fire fighter training by the authority having jurisdiction.

8.5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.

8.5.3 Additional instructors shall be designated when factors such as extreme temperatures or large groups are present, and classes of long duration are planned.

8.5.4 The instructor-in-charge shall be responsible for full compliance with this standard.

8.5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn according to manufacturer's instructions.

8.5.6 The instructor-in-charge shall consider the circumstances of each training session and make suitable provisions for the rest and rehabilitation of members operating at the scene, including medical evaluation and treatment, food and fluid replenishment, and relief from climate conditions, in accordance with the circumstances of the training session. (*See Annex D.*)

8.5.7 Instructors responsible for conducting live fire training evolutions with a gas-fueled training system shall be trained in the complete operation of the system.

8.5.8 The training of instructors shall be performed by an individual authorized by the gas-fueled training system manufacturer.

Chapter 9 Reports and Records

9.1 General.

9.1.1 The following records and reports shall be maintained on all live fire training evolutions in accordance with the requirements of this standard:

- (1) An accounting of the activities conducted
- (2) A listing of instructors present and their assignments
- (3) A listing of all other participants
- (4) Documentation of unusual conditions encountered
- (5) Any injuries incurred and treatment rendered
- (6) Any changes or deterioration of the structure
- (7) Documentation of the condition of the premises and adjacent area at the conclusion of the training exercise

9.1.2* For acquired buildings, records pertaining to the structure shall be completed.

9.1.3 Upon completion of the training session, an acquired building shall be formally turned over to the control of the property owner; the process shall include the completion of a standard form indicating the transfer of authority for the building.

9.1.4 A post-training critique session, complete with documentation, shall be conducted to evaluate student performance and to reinforce the training that was covered.

Annex A Explanatory Material

Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.

A.1.2 Drills conducted to familiarize fire fighters with the proper use of self-contained breathing apparatus in a smoke environment should not be conducted under live fire conditions.

A.3.2.1 Authority Having Jurisdiction (AHJ). The phrase “authority having jurisdiction,” or its acronym AHJ, is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory

authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

A.3.3.2.2 Training Center Burn Building. It does not include a structure that is used primarily for training in the use of Self-Contained Breathing Apparatus (SCBA) where only smoke conditions are created, without a live fire, and the trainee is not subjected to risk of the effects of fire other than the smoke produced.

A.4.1.1 The following job performance requirements from NFPA 1001 should be used as guidance related to the list of subjects in 4.1.1:

- (1) 3-2.3 Radio use
- (2) 3-3.1 SCBA
- (3) 3-3.3 Forcible entry
- (4) 3-3.4 Safety, extinguishers, personnel accountability
- (5) 3-3.5 Ground ladders
- (6) 3-3.7 Fire extinguishment
- (7) 3-3.8 Search and rescue
- (8) 3-3.9 Structural fire fighting
- (9) 3-3.10 Horizontal ventilation
- (10) 3-3.11 Vertical ventilation
- (11) 3-3.12 Overhaul
- (12) 3-3.14 Water supply
- (13) 3-3.15 Fire extinguishers
- (14) 3-3.16 Scene illumination
- (15) 3-5.3 Tool maintenance
- (16) 3-5.4 Fire hose care and maintenance

A.4.1.2 The type of written documentation required can vary, depending upon the instructor’s familiarity with the student participants’ level of training from outside agencies. All student participants from outside agencies should be allowed to participate only as official representatives of an established organization. Prior documentation should be required in order to facilitate planning of the training session.

A.4.2.1 Where training facility burn buildings are available, they should be used instead of acquired structures.

A.4.2.2 The permits required for the exercise can include the following:

- (1) Air quality
- (2) Water runoff
- (3) Water usage
- (4) Burning
- (5) Traffic

Other permits could be required and thorough research of required permits should be completed prior to acceptance of the building for use for training.

A.4.2.3 Information pertaining to building ownership should be reviewed by the legal counsel of the authority having jurisdiction prior to accepting the structure.

A.4.2.5 Information regarding the written permission of the building owner should be reviewed by the legal counsel of the authority having jurisdiction prior to accepting the structure.

A.4.2.7 Information regarding cancellation of insurance by the building owner should be reviewed by the legal counsel

of the authority having jurisdiction prior to accepting the structure.

A.4.2.9 Care should be exercised in the neutralization of hazards posed by closed tanks and vessels. The vessel or its contents can pose a hazard that should be eliminated. Appropriate references should be consulted or assistance should be obtained based on the specific circumstances encountered. The area within the tank should be filled with dry sand as a preferred means of rendering the internal atmosphere inert. Under no circumstances should water or other liquids be utilized as a means of inerting a tank or other closed vessel.

A.4.2.10.5 Low-density combustible fiberboard has been implicated as a major factor in the following rapidly spreading fires that resulted in fatalities:

- (1) Our Lady of the Angels School (Chicago, IL, 1958)
- (2) Hartford Hospital (Hartford, CT, 1961)
- (3) Opemiska Social Club (Chapais, Quebec, 1980)
- (4) Boulder Fire Department training fire (Boulder, CO, 1982)

Unconventional interior finishes include burlap, carpeting, and artificial turf.

A.4.2.10.6 The collapse of overhead structural members can result from the combined effect of the weight of both live and dead overhead loads as well as the loss of structural integrity caused by fire. Linoleum is a potential fuel source, particularly after being preheated by repeated fire exposure and thus can contribute to an unanticipated increase in fire intensity.

A.4.2.11.2 Roof ventilation openings can consist of precut panels or hinged covers.

A.4.2.20 Such safeguards can include street closings, traffic rerouting, signs, and police traffic control.

A.4.2.22 Severe weather could require the participants to respond to other incidents, or could expose trainees to danger if training during severe weather. Wind velocity can contribute to spreading the fire within the training structure or throughout a neighborhood, or wind direction could cause smoke problems in the neighborhood.

A.4.2.23.3 Reliability should be considered when determining what constitutes valid separate sources. The intent of this paragraph is to prevent the simultaneous loss of both attack lines and backup lines in the event of a pump or water supply failure. Where a public water supply system is used, two pumpers on two different hydrants should be used. Two pumpers drafting from the same pond or river also are appropriate, provided the source contains sufficient usable water. Where tankers or folding tanks, or both, are used, two separate pumpers should be used to supply the attack and backup lines.

A.4.3.3 Acceptable Class A materials include pine excelsior, wooden pallets, straw, hay, and other ordinary combustibles.

A.4.3.4 An excessive fuel load can contribute to conditions that create unusually dangerous fire behavior. This can jeopardize structural stability, egress, and the safety of participants.

A.4.3.7 The instructor-in-charge is concerned with the safety of participants and the assessment of conditions that can lead to rapid, uncontrolled burning, commonly referred to as "flashover." Flashover can trap, injure, and kill fire fighters. Conditions known to be variables affecting the attainment of flashover are as follows:

- (1) The heat release characteristics of materials used as primary fuels
- (2) The preheating of combustibles
- (3) The combustibility of wall and ceiling materials
- (4) The room geometry (e.g., ceiling height, openings to rooms)

In addition, the arrangement of the initial materials to be ignited, particularly the proximity to walls and ceilings, and the ventilation openings are important factors to be considered when assessing the potential fire growth.

A.4.3.8 Plotting the expected avenues of firespread and the time factors for expected buildup of the fire provides an extra degree of safety for the participants of the exercise. Voids can result in sudden and unexpected vertical spread of the fire and trap participants by cutting off exit routes, or can result in unexpected weakening of the structural members, leading to collapse. To compensate for this potential hazard, the instructor-in-charge should prescribe primary and secondary exit paths for participants in the exercises.

A.4.3.9 Incidents of injuries and deaths during live fire training exercises indicate that fire growth dynamics were not considered or were inaccurately assessed prior to the beginning of the exercises. Fire growth is typically linear until the flame height reaches the ceiling; thereafter, rapid acceleration can be expected. It might be necessary to remove combustible wall and ceiling materials, reduce the amount of furnishings, or take other similar measures to reduce rapid fire growth. Careful consideration should be given to the presence of combustible void spaces, and steps should be taken to ensure that the fire is not able to gain unexpected growth in such areas.

A.4.4.2 Severe weather presents the potential for health and safety hazards to all persons attending and participating in an exercise. Extreme heat can cause heat exhaustion or heat stroke, and extreme cold can cause frostbite, hypothermia, or slippery surfaces. An impending severe storm can bring lightning or high winds. Such situations warrant the careful consideration of limiting activity, waiting for a storm to pass, or postponing the exercise.

A.4.4.6 A minimum flow rate of 360 L/min (95 gpm) is necessary in order to provide adequate quantities of water to cover the planned evolution plus a reserve for unanticipated emergencies. The appropriate quantity and exact flow rates that are needed for fire control and extinguishment should be calculated in advance, and certain factors such as equipment, manpower, fire area, and topography should be taken into consideration. Knowledge of the hoseline sizes, types of nozzles, type of fire stream to be utilized, and principles of fire attack and deployment aid in determining the exact flow rates that are necessary.

A.4.4.8 The additional safety personnel can be necessary to watch for signs of fire in voids, concealed spaces, and exit paths, or combinations thereof, at acquired structures. Where fire is discovered in any of these areas, the operation should cease as a training exercise and should be treated as a working structure fire.

A.4.4.10 Participants involved in the live fire training evolutions should be instructed to report to a predetermined location for a roll call if evacuation of the building is signaled. Instructors should immediately report any personnel not accounted for to the instructor-in-charge. Examples of an evacuation signal that could be used include a whistle, apparatus air horn, or high-low electronic siren.

A.4.4.17.4 Clothing worn under protective clothing can degrade and cause injury to the wearer, even without damaging the protective clothing. All wearers of protective clothing should be aware of the dangers of clothing made from certain all-synthetic materials that can melt and adhere to and burn the wearer even while wearing protective clothing that meets NFPA standards. Any clothing, such as shirts, pants, underwear, and sweatshirts worn under protective clothing, should meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Fire and Emergency Services*, whenever possible, or clothing should be selected, at a minimum, for the fabric's ability to resist ignition. Fire-retardant fabrics and all-natural fibers should be considered.

A.4.4.17.7 No person should be allowed to breathe smoke, toxic vapors or fumes, products of combustion, or other contaminated atmospheres or be exposed to an oxygen-deficient atmosphere.

A.4.4.18.3 The gas-fueled training systems that are available can provide the instructors with the ability to ignite the fires from a remote control room. Igniting a fire in this manner can present a safety risk to unsuspecting personnel within the burn building. It is important for the instructor located in the control room to keep in constant communication with the instructor present within the burn building. This communication is critical when initiating a fire and throughout the training exercise.

A.4.5.2 It is important that the participating student-to-instructor ratio be monitored so it does not exceed the span of control necessary to provide proper supervision of trainees.

A.5.1.1 The following job performance requirements from NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, should be used as guidance related to the list of subjects in 5.1.1:

- (1) 3-2.3 Radio use
- (2) 3-3.1 SCBA
- (3) 3-3.3 Forcible entry
- (4) 3-3.4 Safety, extinguishers, personnel accountability
- (5) 3-3.5 Ground ladders
- (6) 3-3.7 Fire extinguishment
- (7) 3-3.8 Search and rescue
- (8) 3-3.9 Structural fire fighting
- (9) 3-3.10 Horizontal ventilation
- (10) 3-3.11 Vertical ventilation
- (11) 3-3.12 Overhaul
- (12) 3-3.14 Water supply
- (13) 3-3.15 Fire extinguishers
- (14) 3-3.16 Scene illumination
- (15) 3-5.3 Tool maintenance
- (16) 3-5.4 Fire hose care and maintenance

A.5.1.2 See A.4.1.2.

A.5.2.1 These practices vary greatly in the degree of application where comparing burn building structures to acquired structures. By nature, burn buildings have been designed specifically for the purpose of repeated live fire training evolutions and include safeguards that become unacceptably hazardous only through misuse or improper maintenance.

A.5.2.2 There should be ongoing concern for the progressive damage to burn buildings associated with fire intensity during live fire training evolutions. Excessive fire intensity can result in accelerated destruction of the training center burn build-

ing and can increase the risk to personnel to an unacceptable level.

A.5.2.2.2 Routine maintenance is important to providing a safe, durable burn building for live fire training. Periodic engineering evaluations are one step in that process. Burn buildings present unique engineering problems that are not taught to engineers in college or in their daily practice of engineering office buildings, schools, and fire stations. Before a registered (licensed) Professional Engineer (P.E.) understands "burn building engineering," it takes significant efforts on the part of the P.E. to learn how burn buildings are used, how repetitive live fire training affects structural and non-structural elements within the burn building, and what materials have been proven to work (or not work) within such a harsh environment. This effort typically requires both research/educational efforts and experience with burn building projects.

Because the required evaluation is for structural integrity, the P.E. performing the evaluation should be a structural engineer or teamed with a structural engineer to perform the evaluation. Many states do not license P.E.s by discipline, meaning that "P.E." could mean structural engineer or some other engineering discipline, such as electrical, mechanical, fire protection, or aeronautical. State laws require P.E.s to offer engineering services for only those branches of engineering for which they are qualified. Therefore, a P.E. who is an electrical engineer or fire protection engineer with no structural qualifications would not be allowed, under law, to evaluate the structural integrity of a burn building.

Note that a P.E. with refractive materials experience and expertise, but not burn building experience and expertise, might not have sufficient understanding of how refractory concrete performs in a burn building environment. Many P.E.s with refractive materials experience have gained that experience working with industrial applications, where furnaces are heated and cooled slowly. Certain applications of refractory concrete work well under those furnace conditions. However, the same applications of refractory concrete at times work poorly in the burn building environment, where rapid heating, cooling, and thermal shock deteriorate refractory concrete differently than a furnace application would. Many P.E.s with only refractive materials experience, but no burn building experience, do not know this. As a result, the requirement for burn building experience and expertise has been added to the standard. In many cases, the P.E. retained to evaluate the integrity can also, under the same contract, be required to make recommendations for how to repair, maintain, or improve the burn building.

The phrase "with burn building experience and expertise" must be interpreted by each entity following its own local and state laws and guidelines. The intent is for the P.E. to have performed at least one burn building project previously, so that the entity hiring the P.E. will benefit from the educational and research efforts performed, and experience gained, by the P.E. for the previous burn building project(s). This could include a previous burn building evaluation, the repair or renovation to an existing burn building, or the design of a new burn building. In many cases, it would be acceptable for a P.E. without burn building experience or expertise to perform the evaluation as long as he or she has teamed with a P.E. with burn building experience or expertise.

Although the standard requires only the "structural integrity" to be evaluated annually, it is advisable to have the non-

structural elements evaluated at the same time. Illustrative examples include the following:

- (1) A spray-on refractory concrete thermal lining is not a structural element. It is a concrete material on the ceiling intended to protect the structural concrete. Exposure to live fire training can cause it to wear out over time. Portions of it can loosen and fall out, creating a safety concern for occupants. Even though it is not structural, it is good to have the P.E. evaluate the condition of the lining concrete and advise on its repairs and/or maintenance in order to enhance training safety.
- (2) Doors in burn buildings at times do not operate properly, sticking shut during training and creating safety problems relating to emergency egress. The P.E. could evaluate this and make recommendations for repairs.
- (3) A rusted hinge at a second floor window shutter could cause the shutter to fall to the ground below. The P.E. could evaluate the burn building shutters and make recommendations for necessary repairs to enhance safety and durability.

A.5.2.2.3 Heat can soak through thermal linings and reach the protected structure, especially if the linings are cracked or otherwise require maintenance when live fire training occurs. This heat could damage the structure, a hidden condition that would otherwise go undetected if the panels are not occasionally removed to expose the hidden conditions.

A.5.2.4 Some training center burn buildings might utilize propane-fueled fires in lieu of Class A–fueled fires and still create a realistic fire training experience. Propane-fueled fires produce less smoke and other by-products than ordinary Class A combustibles and, therefore, create less of a negative environmental impact. Such fires also negate the need to clean up large amounts of burned materials at the end of the exercise, because no such materials are used. Such buildings might incorporate emergency shutdown switches and other electronic devices to monitor burn evolutions, which should provide an increased level of safety for fire fighters.

A.5.2.5 Some training center burn buildings utilize gas-fueled fires in lieu of Class A–fueled fires. Gas-fueled fires produce less smoke and other by-products than ordinary Class A combustibles and, therefore, create less of a negative environmental impact. Such fires also negate the need to clean up large amounts of burned materials at the end of the exercise, because no such materials are used. Such buildings incorporate emergency shutdown switches, ventilation systems, and other electronic devices to monitor burn evolutions that should provide an increased level of safety for fire fighters.

A.5.2.10.4 See A.4.2.23.3.

A.5.3.3 Propane and liquefied natural gas remain in the liquid state only when they are stored and distributed under pressure. When either of these gases is released, the difference in the storage and atmospheric pressures can cause the liquid to convert quickly to a gas. During this conversion, liquid propane, for example, can expand 272.7 times its volume. With such a high expansion rate, a leaking liquid propane pipe has the potential to cause the space to reach an explosive level.

A.5.3.5 See A.4.3.7.

A.5.3.6 See A.4.3.9.

A.5.4.2 See A.4.4.2.

A.5.4.7 See A.4.4.6.

A.5.4.8 See A.4.4.8.

A.5.4.10 See A.4.4.10.

A.5.4.17.4 See A.4.4.17.4.

A.5.4.17.7 See A.4.4.17.7.

A.5.4.18 See A.4.4.18.3.

A.5.5.2 See A.4.5.2.

A.6.1.1 The following job performance requirements from NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, should be used as guidance related to the list of subjects in 6.1.1:

- (1) 3-2.3 Radio use
- (2) 3-3.1 SCBA
- (3) 3-3.3 Forcible entry
- (4) 3-3.4 Safety, extinguishers, personnel accountability
- (5) 3-3.5 Ground ladders
- (6) 3-3.7 Fire extinguishment
- (7) 3-3.8 Search and rescue
- (8) 3-3.9 Structural fire fighting
- (9) 3-3.10 Horizontal ventilation
- (10) 3-3.11 Vertical ventilation
- (11) 3-3.12 Overhaul
- (12) 3-3.14 Water supply
- (13) 3-3.15 Fire extinguishers
- (14) 3-3.16 Scene illumination
- (15) 3-5.3 Tool maintenance
- (16) 3-5.4 Fire hose care and maintenance

A.6.1.2 See A.4.1.2.

A.6.2.1 These practices vary greatly in the degree of application where comparing burn building structures to acquired structures. By nature, burn buildings have been designed specifically for the purpose of repeated live fire training evolutions and include safeguards that become unacceptably hazardous only through misuse or improper maintenance.

A.6.2.2 See A.5.2.2.

A.6.2.2.2 See A.5.2.2.2.

A.6.2.2.3 Heat can soak through thermal linings and reach the protected structure, especially if the linings are cracked or otherwise require maintenance when live fire training occurs. This heat could damage the structure, a hidden condition that would otherwise go undetected if the panels are not occasionally removed to expose the hidden conditions.

A.6.2.4 See A.5.2.4.

A.6.2.10 Such safeguards can include street closings, traffic rerouting, signs, and police traffic control.

A.6.2.13.4 See A.4.2.23.3.

A.6.3.4 See A.4.3.3.

A.6.3.6 Where combustible liquids are used in a training center burn building, safety precautions should include, but should not be limited to, the following:

- (1) Fuel is contained in a noncombustible container.
- (2) A qualified person verifies that the rate of heat release does not result in unsafe conditions for the students, instructors, or structure.

- (3) A system is in place to prevent overflow of the container when fire-fighting water is applied.
- (4) A system is in place to prevent splashing of the fuel.
- (5) A method is in place to control unburned vapors.

A.6.3.7 See A.4.3.7.

A.6.3.8 See A.4.3.8.

A.6.3.9 See A.4.3.9.

A.6.4.2 See A.4.4.2.

A.6.4.7 See A.4.4.6.

A.6.4.8 See A.4.4.8.

A.6.4.10 See A.4.4.10.

A.6.4.17.4 See A.4.4.17.4.

A.6.4.17.7 See A.4.4.17.7.

A.6.4.18.3 See A.4.4.18.3.

A.6.5.2 See A.4.5.2.

A.7.1.1 The following job performance requirements from NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, should be used as guidance related to the list of subjects in 7.1.1:

- (1) 3-2.3 Radio use
- (2) 3-3.1 SCBA
- (3) 3-3.3 Forcible entry
- (4) 3-3.4 Safety, extinguishers, personnel accountability
- (5) 3-3.5 Ground ladders
- (6) 3-3.7 Fire extinguishment
- (7) 3-3.8 Search and rescue
- (8) 3-3.9 Structural fire fighting
- (9) 3-3.10 Horizontal ventilation
- (10) 3-3.11 Vertical ventilation
- (11) 3-3.12 Overhaul
- (12) 3-3.14 Water supply
- (13) 3-3.15 Fire extinguishers
- (14) 3-3.16 Scene illumination
- (15) 3-5.3 Tool maintenance
- (16) 3-5.4 Fire hose care and maintenance

A.7.1.2 See A.4.1.2.

A.7.2.1 These practices vary greatly, depending on the evolutions performed and the location where performed. Props that are specifically designed for live fire training represent different challenges than props that are acquired for training. Acquired props were never designed to withstand repeated burning and might present unexpected reactions when exposed to fire.

A.7.2.18 Such safeguards can include street closings, traffic rerouting, signs, and police traffic control.

A.7.2.21.4 See A.4.2.23.3.

A.7.3.3 A fire should not be larger than is necessary for the evolution. It should be understood that it is not necessary to have large fires to teach many of the basic evolutions and tactics. Where the objective of the training session is to train in the use of master streams or multiple attack lines, larger fires might be necessary. The key element is to maintain a fire that is controllable using the available resources.

A.7.3.5 See A.4.3.7.

A.7.3.6 See A.4.3.9.

A.7.3.9 The safety person at the remote shutoff should have the authority to shut off the fuel supply to the prop when, in the safety person's judgment, the prop has malfunctioned, the fire has gone dangerously out of control, or the extinguishment team is in jeopardy.

A.7.3.15 The list of the items to be removed prior to a vehicle burn evolution should consist of, but should not be limited to, bumper compression cylinders, shock absorbers, fuel tanks, drive shafts, batteries, and brake shoes (asbestos). The oil pan, transmission, and differential drain plugs should be removed, and the fluids should be drained and disposed of properly.

A.7.4.2 See A.4.4.2.

A.7.4.7 See A.4.4.6.

A.7.4.8 See A.4.4.8.

A.7.4.16.4 See A.4.4.17.4.

A.7.4.16.7 See A.4.4.17.7.

A.7.5.2 See A.4.5.2.

A.8.1.1 See A.4.1.1.

A.8.1.2 See A.4.1.2.

A.8.2.1 See A.5.2.1.

A.8.2.19 Such safeguards can include street closings, traffic rerouting, signs, and police traffic control.

A.8.2.22.4 See A.4.2.23.3.

A.8.3.3 See A.4.3.4.

A.8.3.4 See A.4.3.7.

A.8.3.5 See A.4.3.8.

A.8.3.6 See A.4.3.9.

A.8.3.9 See A.7.3.9.

A.8.4.2 See A.4.4.2.

A.8.4.7 See A.4.4.6.

A.8.4.16.2 Protective trousers might be susceptible to wicking where used with flammable and combustible liquids. Precautions should be taken to prevent protective trouser contact with flammable or combustible liquids.

Leather boots might be susceptible to degradation when contact is made with flammable or combustible liquids. Precautions should be taken to prevent leather boots from coming in contact with flammable or combustible liquids.

A.8.4.16.4 See A.4.4.17.4.

A.8.4.16.7 See A.4.4.17.7.

A.8.5.2 See A.4.5.2.

A.9.1.2 Figure A.9.1.2(a) shows a standard notice of cancellation or nonrenewal of insurance. Figure A.9.1.2(b) shows a sample release form that can be used with acquired buildings. The exact form should be approved by local officials.

NOTICE OF CANCELLATION OR NONRENEWAL			
of _____			
KIND OF POLICY			
POLICY NO.	ISSUED THROUGH AGENCY OR OFFICE AT:	CANCELLATION OR TERMINATION WILL TAKE EFFECT AT: (DATE)	DATE OF NOTICE
(HOUR-STANDARD TIME)			
INSURANCE COMPANY:			
NAME AND ADDRESS OF INSURED:			
(Applicable item is marked <input checked="" type="checkbox"/>)			
CANCELLATION	<input type="checkbox"/> You are hereby notified in accordance with the terms and conditions of the above-mentioned policy that your insurance will cease at and from the hour and date mentioned above. If the premium has been paid, premium adjustment will be made as soon as practicable after cancellation becomes effective. If the premium has not been paid, a bill for the premium earned to the time of cancellation will be forwarded in due course.		
	<input type="checkbox"/> You are hereby notified in accordance with the terms and conditions of the above-mentioned policy that your insurance will cease at and from the hour and date mentioned above due to nonpayment of premium. A bill for the premium earned to the time of cancellation will be forwarded in due course.		
NONRENEWAL	<input type="checkbox"/> You are hereby notified in accordance with the terms and conditions of the above-mentioned policy that the above-mentioned policy will expire effective at and from the hour and date mentioned above and the policy will NOT be renewed.		
IMPORTANT NOTICE	<input type="checkbox"/> In compliance with the Fair Credit Reporting Act (Public Law 91-508), you are hereby informed that the action taken above is being taken wholly or partly because of information contained in a consumer report from the following consumer reporting agency:		
_____ NAME			
_____ ADDRESS			
GU 8811b (Ed. 3-73) Uniform Printing & Supply Div.	INSURED'S COPY Authorized Representative	

FIGURE A.9.1.2(a) Standard Notice of Cancellation or Nonrenewal of Insurance Form.

Release Form

_____ Fire Department

Address _____

City _____ State _____

Date _____

Having agreed with the Building Official, City of _____,

_____ ,

that a structure owned by me and located at _____

_____ is unfit for human habitation

and is beyond rehabilitation, I further agree that the structure should be demolished. In order that demolition may be accomplished, I give my consent to the

City of _____

to demolish, by burning or other means, the said structure.

I further release the City of _____

_____ from any claim for loss resulting from such demolition.

Owner/Agent

Owner/Agent

Witness

FIGURE A.9.1.2(b) Sample Release Form.

Annex B Live Fire Evolution Sample Checklist

This annex is not a part of the requirements of this NFPA document but is included for informational purposes only.

B.1 Permits, Documents, Notifications, Insurance.

- 1. Written documentation received from owner:
 - Permission to burn structure
 - Proof of clear title
 - Certificate of insurance cancellation
 - Acknowledgment of post-burn property condition

- 2. Local burn permit received
- 3. Permission obtained to utilize fire hydrants
- 4. Notification made to appropriate dispatch office of date, time, and location of burn
- 5. Notification made to all affected police agencies:
 - Received authority to block off roads
 - Received assistance in traffic control
- 6. Notification made to owners and users of adjacent property of date, time, and location of burn
- 7. Liability insurance obtained covering damage to other property
- 8. Written evidence of prerequisite training obtained from participating students from outside agencies

B.2 Preburn Planning.

- 1. Preburn plans made, showing the following:
 - Site plan drawing, including all exposures
 - Building plan, including overall dimensions
 - Floor plan detailing all rooms, hallways, and exterior openings
 - Location of command post
 - Position of all apparatus
 - Position of all hoses, including backup lines
 - Location of emergency escape routes
 - Location of emergency evacuation assembly area
 - Location of ingress and egress routes for emergency vehicles
- 2. Available water supply determined
- 3. Required fire flow determined for the burn building and exposure buildings
- 4. Required reserve flow determined (50 percent of fire flow)
- 5. Apparatus pumps obtained that meet or exceed the required fire flow for the building and exposures
- 6. Separate water sources established for attack and backup hoselines
- 7. Periodic weather reports obtained
- 8. Parking areas designated and marked:
 - Apparatus staging
 - Ambulances
 - Police vehicles
 - Press vehicles
 - Private vehicles
- 9. Operations area established and perimeter marked
- 10. Communications frequencies established, equipment obtained

B.3 Building Preparation.

- 1. Building inspected to determine structural integrity
- 2. All utilities disconnected (acquired buildings only)
- 3. Highly combustible interior wall and ceiling coverings removed
- 4. All holes in walls and ceilings patched
- 5. Materials of exceptional weight removed from above training area (or area sealed from activity)

- 6. Ventilation openings of adequate size precut for each separate roof area
- 7. Windows checked and operated, openings closed
- 8. Doors checked and operated, opened or closed, as needed
- 9. Building components checked and operated:
 - Roof scuttles
 - Automatic ventilators
 - Mechanical equipment
 - Lighting equipment
 - Manual or automatic sprinklers
 - Standpipes
- 10. Stairways made safe with railings in place
- 11. Chimney checked for stability
- 12. Fuel tanks and closed vessels removed or adequately vented
- 13. Unnecessary inside and outside debris removed
- 14. Porches and outside steps made safe
- 15. Cisterns, wells, cesspools, and other ground openings fenced or filled
- 16. Hazards from toxic weeds, hives, and vermin eliminated
- 17. Hazardous trees, brush, and surrounding vegetation removed
- 18. Exposures such as buildings, trees, and utilities removed or protected
- 19. All extraordinary exterior and interior hazards remedied
- 20. Fire "sets" prepared:
 - Class A materials only
 - No flammable or combustible liquids
 - No contaminated materials

B.4 Preburn Procedures.

- 1. All participants briefed:
 - Building layout
 - Crew and instructor assignments
 - Safety rules
 - Building evacuation procedure
 - Evacuation signal (demonstrate)
- 2. All hoselines checked:
 - Sufficient size for the area of fire involvement
 - Charged and test flowed
 - Supervised by qualified instructors
 - Adequate number of personnel
- 3. Necessary tools and equipment positioned
- 4. Participants checked:
 - Approved full protective clothing
 - Self-contained breathing apparatus
 - Adequate SCBA air volume
 - All equipment properly donned

B.5 Post-Burn Procedures.

- 1. All personnel accounted for
- 2. Remaining fires overhauled, as needed
- 3. Building inspected for stability and hazards where more training is to follow (*see Section B.3, Building Preparation*)
- 4. Training critique conducted
- 5. Records and reports prepared, as required:
 - Account of activities conducted

- List of instructors and assignments
- List of other participants
- Documentation of unusual conditions or events
- Documentation of injuries incurred and treatment rendered
- Documentation of changes or deterioration of training center burn building
- Acquired building release
- Student training records
- Certificates of completion
- 6. Building and property released to owner, release document signed

Annex C Responsibilities of Personnel

This annex is not a part of the requirements of this NFPA document but is included for informational purposes only.

C.1 Instructor-in-Charge.

- 1. Plan and coordinate all training activities
- 2. Monitor activities to ensure safe practices
- 3. Inspect building integrity prior to each fire
- 4. Assign instructors:
 - Attack hoselines
 - Backup hoselines
 - Functional assignments
 - Teaching assignments
- 5. Brief instructors on responsibilities:
 - Accounting for assigned students
 - Assessing student performance
 - Clothing and equipment inspection
 - Monitoring safety
 - Achieving tactical and training objectives
- 6. Assign coordinating personnel, as needed:
 - Emergency medical services
 - Communications
 - Water supply
 - Apparatus staging
 - Equipment staging
 - Breathing apparatus
 - Personnel welfare
 - Public relations
- 7. Ensure adherence to this standard by all persons within the training area

C.2 Safety Officer.

- 1. Prevent unsafe acts
- 2. Eliminate unsafe conditions
- 3. Intervene and terminate unsafe acts
- 4. Supervise additional safety personnel, as needed
- 5. Coordinate lighting of fires with instructor-in-charge
- 6. Ensure compliance of participants' personal equipment with applicable standards:
 - Protective clothing
 - SCBA
 - Personal alarm devices, where used
- 7. Ensure that all participants are accounted for, both before and after each evolution

C.3 Instructor.

- 1. Monitor and supervise assigned students (no more than five per instructor)
- 2. Inspect students' protective clothing and equipment
- 3. Account for assigned students, both before and after evolutions

C.4 Student.

- 1. Acquire prerequisite training
- 2. Become familiar with building layout
- 3. Wear approved full protective clothing
- 4. Wear approved self-contained breathing apparatus
- 5. Obey all instructions and safety rules
- 6. Provide documentation of prerequisite training, where from an outside agency

Annex D Heat Exhaustion and Heat Stroke in Training

This annex is not a part of the requirements of this NFPA document but is included for informational purposes only.

D.1 The two most serious heat-related illnesses are heat exhaustion and heat stroke. The following material is excerpted from the NIOSH document *Occupational Exposure to Hot Environments, Revised Criteria*.

Symptoms of heat exhaustion include fatigue, nausea, headache, dizziness, pallor, weakness, and thirst. Factors that predispose a person to heat exhaustion include sustained exertion in the heat, failure to replace the water lost in sweat, and lack of acclimatization. Heat exhaustion responds readily to prompt treatments such as moving to a cooler environment, resting in a recumbent position, and taking fluids by mouth.

Heat stroke is the more serious of the heat-related illnesses and is considered a medical emergency. Symptoms of heat stroke include hot, red, dry skin, a rectal temperature of 40°C (104°F) or above, confusion, possible convulsions or loss of consciousness, or any combination of these symptoms. Factors that predispose a person to heat stroke include sustained exertion in the heat by unacclimatized workers, lack of physical fitness, obesity, recent alcohol intake, dehydration, individual susceptibility, and chronic cardiovascular disease. Heat stroke should be treated immediately. Treatments to reduce body temperature rapidly include immersing in chilled water, rinsing with alcohol, wrapping in a wet sheet, or fanning with cool, dry air, or any combination of these treatments. A physician's care is necessary to treat possible secondary disorders such as shock or kidney failure. While heat exhaustion cases greatly outnumber heat stroke cases, every case of heat exhaustion should be treated as having the potential to develop into heat stroke.

Acclimatization is a physiological adaptation to heat stress that occurs over a short period of time. After acclimatization has occurred, the body sweats more while losing less salt and can maintain a lower core temperature and lower cardiovascular demands. A person becomes acclimatized to a certain work intensity and temperature with repeated exposures to that

work load and temperature. Formal acclimatization procedures might not be necessary for all fire fighters; however, training drills should be held outdoors regularly so that seasonal acclimatization can occur. For additional protection against heat stress, fire fighters might want to perform their regular aerobic training activities outdoors, especially during the spring and summer.

The metabolic demands of fire fighting range from 60 percent to 100 percent of maximum aerobic capacity. Tasks such as stair climbing, roof venting, and rescue operations, when performed in full gear, have an energy cost of 85 percent to 100 percent of maximum capacity and lead to near maximum heart rates.

It is clear from these estimates that a high level of cardiovascular fitness is an advantage in performing fire-fighting tasks. The higher level of fitness allows a longer work period and provides a greater reserve in case of an unexpected increase in work demands or in extreme environmental conditions.

There are fire incidents during which even the fittest, most acclimatized fire fighter is exposed to significant heat stress. For this reason, many fire departments have adopted formal procedures for on-scene rehabilitation and have incorporated them into their manuals for standard operating procedures. The general goals of rehabilitation are as follows:

- (1) To provide physical and mental rest, allowing the fire fighter to recuperate from demands of emergency operations and adverse environmental conditions
- (2) To revitalize fire fighters by providing fluid replacement and food as needed
- (3) To provide medical monitoring, including treatment of injuries, to determine if and when fire fighters are able to return to action

Annex E Informational References

E.1 Referenced Publications. The following documents or portions thereof are referenced within this standard for informational purposes only and are thus not part of the requirements of this document unless also listed in Chapter 2.

E.1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, 1997 edition.

NFPA 1975, *Standard on Station/Work Uniforms for Fire and Emergency Services*, 1999 edition.

E.1.2 Other Publications.

E.1.2.1 NIOSH Publications. National Institute for Occupational Health and Safety, 1600 Clifton Road, Atlanta, GA 30333.

NIOSH Publication No. 86-113, *Occupational Exposure to Hot Environments, Revised Criteria*, 1986.

E.2 Informational References. The following documents or portions thereof are listed here as informational resources only. They are not a part of the requirements of this document.

NFPA 1041, *Standard for Fire Service Instructor Professional Qualifications*, 2002 edition.

NFPA 1402, *Guide to Building Fire Service Training Centers*, 2002 edition.

E.3 References for Extracts. (Reserved)

Index

© 2002 National Fire Protection Association. All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document that it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of NFPA.

- A-**
- Acquired buildings** Chap. 4
 Definition 3.3.2.1
 Fuels for 4.3, A.4.3.3 to A.4.3.4, A.4.3.7 to A.4.3.9
 Instructors for 4.5, A.4.5.2
 Procurement of 9.1.2, A.9.1.2
 Return to property owner 9.1.3
 Safety of 4.4, A.4.4
 Student prerequisites for 4.1, A.4.1.1 to A.4.1.2
 Utilization of structures 4.2, A.4.2
- Acquired props** *see also* Props, exterior
 Definition 3.3.1
 Vehicles as 7.3.15, A.7.3.15
- Alarm devices, personal, use of**
 In acquired buildings 4.4.17.5
 In Class B exterior fires 8.4.16.5
 For exterior props 7.4.16.5
 In gas-fired training center buildings 5.4.17.5
 In non-gas-fired training center buildings 6.4.17.5
- Application of standard** 1.3
- Authority having jurisdiction (definition)** 3.2.1, A.3.2.1
- B-**
- Backup hose lines**
 For acquired buildings 4.4.6 to 4.4.7, A.4.4.6
 For Class B exterior fires 8.2.22.1, 8.2.22.4, 8.2.28, 8.4.7.2, A.8.2.22.4
 For exterior props 7.2.21.1, 7.2.21.4, 7.2.27, 7.4.6 to 7.4.7, A.7.2.21.4, A.7.4.7
 For gas-fired training center buildings 5.2.10.1, 5.2.10.4, 5.2.16, 5.4.7, A.5.2.10.4, A.5.4.7
 For non-gas-fired training center buildings 6.2.13.1, 6.2.13.4, 6.4.7, A.6.2.13.4, A.6.4.7
- Building preparation checklist** B.3
- Buildings** *see specific types, e.g.,* Acquired buildings
- C-**
- Checklist, live fire evolution** Annex B
- Class B exterior fires, training evolutions** Chap. 8
 Facilities 8.2, A.8.2.1, A.8.2.19, A.8.2.22.4
 Fuels 8.3, A.8.3.3 to A.8.3.6, A.8.3.9
 Instructors 8.5, A.8.5.2, A.8.5.6
 Safety 8.4, A.8.4.2, A.8.4.7, A.8.4.16
 Student prerequisites 8.1, A.8.1.1 to A.8.1.2
- Clothing, protective** *see* Protective clothing
- Combustible liquids** *see* Flammable and combustible liquids
- Communications, fireground** *see* Firegrounds, communications at
- Critique session, post-training** 9.1.4
- D-**
- Definitions** Chap. 3
- Demonstrations (definition)** 3.3.3
- E-**
- Emergency medical services**
 At acquired buildings 4.4.11
 At Class B exterior fires 8.4.10
 For exterior props 7.4.10
 At gas-fired training center buildings 5.4.11
 At non-gas-fired training center buildings 6.4.11
- Evacuation plan** A.4.4.10
 Acquired buildings 4.4.10, A.4.4.10
 Gas-fired training center buildings 5.4.10, A.5.4.10
 Non-gas-fired training center buildings 6.4.10, A.6.4.10
- Evolution (definition)** 3.3.4
- Exposure fires**
 Acquired buildings 4.2.14 to 4.2.20, A.4.2.20
 Class B exterior fires 8.2.13 to 8.2.19, A.8.2.19
 Exterior props 7.2.12 to 7.2.18, A.7.2.18
 Non-gas-fired training center buildings 6.2.8 to 6.2.10, A.6.2.10
- Exterior props** *see* Props, exterior
- F-**
- Fire exposures** *see* Exposure fires
- Firegrounds, communications at**
 Acquired buildings 4.4.9
 Class B exterior fires 8.4.9
 Exterior props 7.4.9
 Gas-fired training center buildings 5.4.9
 Non-gas-fired training center buildings 6.4.9
- Fire growth** A.4.3.8 to A.4.3.9
- Fires**
 Exterior Class B *see* Class B exterior fires, training evolutions
 Live (definition) 3.3.7
- Fire service training facilities** *see* Acquired buildings; Gas-fired training center buildings; Non-gas-fired training center buildings
 Exterior props at *see* Props, exterior
 Outside *see* Class B exterior fires, training evolutions
- Flammable and combustible liquids**
 Runoff from 7.3.13 to 7.3.14, 8.3.13 to 8.3.14
 Use of 4.3.6, 6.3.6, A.6.3.6
- Flammable gas** 5.3.3, 5.4.20, A.5.3.3
- Flashover** A.4.3.7
- Fuels, use of**
 Acquired buildings 4.3, A.4.3.3 to A.4.3.4, A.4.3.7 to A.4.3.9
 Class B exterior fires 8.3, A.8.3.3 to A.8.3.6, A.8.3.9
 Exterior props 7.3, A.7.3
 Gas-fired training center buildings 5.3, A.5.3.3, A.5.3.5 to A.5.3.6
 Non-gas-fired training center buildings 6.3, A.6.3.4, A.6.3.6 to A.6.3.9
- G-**
- Gas-fired training center buildings** Chap. 5
 Fuels for 5.3, A.5.3.3, A.5.3.5 to A.5.3.6
 Instructors for 5.5, A.5.5.2, A.5.5.8
 Safety at 5.4, A.5.4
 Structures and facilities 5.2, A.5.2
 Student prerequisites for 5.1, A.5.1.1 to A.5.1.3
- Ground cover** 7.2.4 to 7.2.5, 8.2.4 to 8.2.5
- H-**
- Hazards, training** *see also* Safety
 Acquired buildings 4.2.9 to 4.2.11, A.4.2.9 to A.4.2.11
 Training center burn buildings 5.2.1 to 5.2.2, A.5.2.1 to A.5.2.2
- Heat exhaustion and heat stroke** Annex D
- I-**
- Ignition**
 Acquired buildings 4.2.27, 4.4.18, A.4.4.18.3

Class B exterior fires	8.2.27, 8.4.12	Props, exterior	Chap. 7; <i>see also</i> Acquired props
Exterior props	7.2.26, 7.4.12	At Class B exterior fires	8.2.9, 8.3.8 to 8.3.11, A.8.3.9
Gas-fired training center buildings	5.2.15, 5.4.18 to 5.4.20, A.5.4.18	Fuels for	7.3, A.7.3
Non-gas-fired training center buildings	6.2.18, 6.4.18, A.6.4.18.3	Fuel shutoffs for	7.3.9, 8.3.9 to 8.3.10, A.7.3.9, A.8.3.9
Ignition officers	4.4.18, 6.4.18, A.4.4.18.3, A.6.4.18.3	Instructors for	7.5, A.7.5.2, A.7.5.8
Instructor-in-charge		Safety for	7.4, A.7.4
Definition	3.3.6	Structures and facilities	7.2, A.7.2
Identification of	5.5.11, 6.5.9	Student prerequisites for	7.1, A.7.1.1 to A.7.1.2
Responsibilities	A.4.3.7, C.1	Protective clothing	
For acquired buildings	4.3.7 to 4.3.9, 4.4.6 to 4.4.7, 4.4.18.3, 4.5.4, 4.5.8, A.4.3.7 to A.4.3.9	For acquired buildings	4.2.26.3, 4.4.17, 4.4.18.1, 4.5.5, A.4.4.17.4, A.4.4.17.7
For Class B exterior fires	8.3.4 to 8.3.6, 8.4.7 to 8.4.8, 8.5.4, 8.5.6, A.8.3.4 to A.8.3.6, A.8.4.7, A.8.5.6	For Class B exterior fires	8.2.26.3, 8.4.12.1, 8.4.16, A.8.4.16
For exterior props	7.3.5 to 7.3.6, 7.3.12.2, 7.4.7, 7.5.4, 7.5.8, A.7.3.5 to A.7.3.6, A.7.4.7, A.7.5.8	For exterior props	7.2.25.3, 7.4.12.1, 7.4.16, 7.5.5, A.7.4.16
For gas-fired training center buildings	5.3.5 to 5.3.6, 5.4.7, 5.4.18, 5.5.4, 5.5.8, 5.5.12, A.5.3.5 to A.5.3.6, A.5.4.7, A.5.4.18, A.5.5.8	For gas-fired training center buildings	5.2.14.3, 5.4.17, 5.5.5, A.5.4.17
For non-gas-fired training center buildings	6.3.7 to 6.3.8, 6.4.7, 6.4.18.3, 6.5.4, 6.5.8, 6.5.10, A.6.3.7 to A.6.3.8, A.6.4.18.3, A.6.5.8	For non-gas-fired training center buildings	6.2.17.3, 6.4.17, 6.4.18.1, 6.5.5, A.6.4.17
Instructors	A.4.5.2, C.3; <i>see also</i> Instructor-in-charge	Purpose of standard	1.2
For acquired buildings	4.5, A.4.5.2	-R-	
For Class B exterior fires	8.5, A.8.5.2, A.8.5.6	Records and reports	Chap. 9, A.9.1.2
Definition	3.3.5	Acquired buildings	4.4.12
For exterior props	7.5, A.7.5.2, A.7.5.8	Class B exterior fires	8.4.11
For gas-fired training center buildings	5.5, A.5.5.2, A.5.5.8	Exterior props	7.4.11
For non-gas-fired training center buildings	6.5, A.6.5.2, A.6.5.8	Gas-fired training center buildings	5.4.12
Insurance, acquired buildings	4.2.7, A.4.2.7, A.9.1.2, B.1	Non-gas-fired training center buildings	6.4.12
		Referenced publications	Chap. 2, Annex E
		-S-	
-L-		Safety	
Liquefied natural gas (LNG)	5.3.4, A.5.3.3	Acquired buildings	4.2.9 to 4.2.13, 4.2.27, 4.4, A.4.2.9 to A.4.2.11, A.4.4
Live fires (definition)	3.3.7	Class B exterior fires	8.2.1 to 8.2.10, 8.2.20, 8.2.25 to 8.2.28, 8.4, A.8.4.2, A.8.4.7, A.8.4.16
LP-Gas	7.3.11, 8.3.11	Exterior props	7.2.1 to 7.2.9, 7.2.19, 7.2.24 to 7.2.25 to 7.2.27, 7.4, A.7.2.1, A.7.4
		Gas-fired training center buildings	5.2.1 to 5.2.8, 5.2.13 to 5.2.15, 5.4, A.5.2.1 to A.5.2.2, A.5.2.4 to A.5.2.5, A.5.4
-M-		Non-gas-fired training center buildings	6.2.1 to 6.2.7, 6.2.11, 6.2.16 to 6.2.18, 6.4, A.6.2.1 to A.6.2.4, A.6.4
Metal fires	7.3.16	Spectators	<i>see</i> Spectators and pedestrians, safety of
		Safety officers	
-N-		For acquired buildings	4.4.1 to 4.4.5, 4.4.17.1, 4.4.18.3 to 4.4.18.4, A.4.4.2
Non-gas-fired training center buildings	Chap. 6	For Class B exterior fires	8.4.1 to 8.4.6, 8.4.16.1, A.8.4.2
Fuels for	6.3, A.6.3.4, A.6.3.6 to A.6.3.9	Definition	3.3.9
Instructors for	6.5, A.6.5.2, A.6.5.8	For exterior props	7.4.1 to 7.4.5, 7.4.12.2, 7.4.16.1, A.7.4.2
Safety at	6.4, A.6.4	For gas-fired training center buildings	5.4.1 to 5.4.6, 5.4.8, 5.4.17.1, A.5.4.2
Structures and facilities	6.2, A.6.2	For non-gas-fired training center buildings	6.4.1 to 6.4.6, 6.4.17.1, 6.4.18.3, A.6.4.2, A.6.4.18.3
Student prerequisites for	6.1, A.6.1.1 to A.6.1.2	Responsibilities	C.2
		SCBA	<i>see</i> Self-contained breathing apparatus (SCBA)
-O-		Scope of standard	1.1
Owners, acquired buildings		Self-contained breathing apparatus (SCBA)	
Determination of	4.2.3 to 4.2.4, A.4.2.3	In acquired buildings	4.4.17, 4.4.18.1, A.4.4.17.7
Method of returning property to owner	4.2.6, 9.1.3	In Class B exterior fires	8.4.12.1, 8.4.16.7
Permission from	4.2.5, A.4.2.5, A.9.1.2, B.1	Drills	A.1.2
		For exterior props	7.4.12.1, 7.4.16, A.7.4.16.7
-P-		In gas-fired training center buildings	5.4.17, A.5.4.17.7
Participants (definition)	3.3.8	In non-gas-fired training center buildings	6.4.17, 6.4.18.1, A.6.4.17.7
Permits	B.1	Reason for	A.4.4.17.7
Acquired buildings	4.2.2, 4.2.5, 4.2.8, A.4.2.2, A.4.2.5	Shall (definition)	3.2.2
Class B exterior fires	8.2.11 to 8.2.12	Should (definition)	3.2.3
Exterior props	7.2.10 to 7.2.11	Site, training	7.2.2 to 7.2.5, 8.2.2 to 8.2.5
Preburn briefing session	B.4	Spectators and pedestrians, safety of	
Acquired buildings	4.2.25	At acquired buildings	4.2.21, 4.2.26
Class B exterior fires	8.2.24	At Class B exterior fires	8.2.20, 8.2.26
Exterior props	7.2.23	At exterior props	7.2.19, 7.2.25
Gas-fired training center buildings	5.2.12		
Non-gas-fired training center buildings	6.2.15		
Preburn planning and procedures checklists	B.2, B.4		
Propane	5.3.3, A.5.3.3		

At gas-fired training center buildings 5.2.8, 5.2.14
 At non-gas-fired training center buildings 6.2.11, 6.2.17
Structures *see specific structure*
Students
 Definition 3.3.10
 Responsibilities C.4
 Training prerequisites
 For acquired buildings 4.1, A.4.1.1 to A.4.1.2
 For Class B exterior fires 8.1
 For exterior props 7.1
 For gas-fired training center buildings 5.1
 For non-gas-fired training center buildings 6.1

-T-

Training center burn buildings *see also* Gas-fired training center buildings; Non-gas-fired training center buildings
 Definition 3.3.2.2, A.3.3.2.2
 Preference for A.4.2.1
Training requirements *see* Students
Training site 7.2.2 to 7.2.5, 8.2.2 to 8.2.5

-U-

Uniforms, station or work
 In acquired buildings 4.4.17.4, A.4.4.17.4
 In Class B exterior fires 8.4.16.4, A.8.4.16.4
 At exterior props 7.4.16.4, A.7.4.16.7

In gas-fired training center buildings 5.4.17.4, A.5.4.17.4
 Hazards from A.4.4.17.4
 In non-gas-fired training center buildings 6.4.17.4, A.6.4.17.4

-V-

Vehicles

Parking/staging
 At acquired buildings 4.2.24
 At Class B exterior fires 8.2.23
 At exterior props 7.2.22
 At gas-fired training center buildings 5.2.11
 At non-gas-fired training center buildings 6.2.14
 As props 7.3.15, A.7.3.15

-W-

Water supplies

Acquired buildings 4.2.23, A.4.2.23.3
 Class B exterior fires 8.2.22, A.8.2.22.4
 Exterior props 7.2.21, A.7.2.21
 Gas-fired training center buildings 5.2.10, A.5.2.10.4
 Non-gas-fired training center buildings 6.2.13, A.6.2.13.4

Weather conditions

Acquired structures 4.2.22, A.4.2.22
 Class B fires 8.2.21
 Exterior props, use of 7.2.20, 7.4.15
 Gas-fired training buildings 5.2.9, 5.4.16
 Non-gas-fired training buildings 6.2.12

Formal Interpretation

NFPA 1403

Standard on Live Fire Training Evolutions

1997 Edition

Reference: 5.2.11.4, 6.2.14.4, 8.2.23.4, 4.4.11, 7.4.10, and 8.4.10

F.I. No.: 1403-97-2

Question 1: Is it the intent of 5.2.11.4, 6.2.14.4 and 8.2.23.4 that an ambulance, which is capable of transporting possibly injured participants, be physically located on site during live fire training?

Answer: No.

Question 2: Does the requirement of 4.4.11, 7.4.10 and 8.4.10 "Emergency Medical Services shall be available on site to handle injuries..." require a staffed ambulance capable of patient transport to be available on site during actual live fire burns?

Answer: No.

Issue Edition: 1997

Reference: 3-2.16, 5-2.23, 6-2.23, 3-4.12, 5-4.10 and 6-4.10

Issue Date: April 23, 2002

Effective Date: May 13, 2002