

GRADATION REQUIREMENTS			
Percent Smaller			
Size, inch	Revetment	Class 1	Class 2
30			100
24		100	85-100
18	100	85-100	60-80
12	90-100	35-50	20-40
6	20-40	10-30	0-20
3	0-10	0-10	0-10
Minimum Depth of Riprap	18 inch	24 inch	30 inch

Note: The material shall be coarse aggregate, Class F or higher. It shall be in accordance with the above requirements and such that the maximum dimension of individual pieces shall not be greater than three times the minimum dimension. See Section 904 of the Standard Specifications for more information.

RIPRAP GRADATION REQUIREMENTS

Figure 38-6I