

203-R-651 USE OF RECYCLED CONCRETE PAVEMENT FOR EMBANKMENT CONSTRUCTION

(Adopted 10-20-16)

The Standard Specifications are revised as follows:

SECTION 203, AFTER LINE 680, INSERT AS FOLLOWS:

Recycled concrete pavement may be used in embankment construction. The recycled material shall meet the requirements of B borrow in accordance with 211.02 or rock embankment in accordance with 203.20.

The recycled concrete pavement may only be placed below the pavement underdrains and shall be constructed in accordance with 203.23. The recycled concrete pavement shall not be used within 2 ft of the water table. Proofrolling in accordance with 203.26 shall be performed to cover the whole grade for every 5 ft of fill. Any rut greater than 1/2 in. shall be corrected as directed.

A geotextile in accordance with 918.02 shall be placed prior to the placement of other material when the material is finer than recycled material. A minimum 18 in. encasement suitable for vegetation growth shall be constructed in accordance with 203.09.
