

605-R-787 CURBING

(Adopted 02-15-24)

The Standard Specifications are revised as follows:

SECTION 605, BEGIN LINE 8, DELETE AND INSERT AS FOLLOWS:

**605.02 Materials**

Materials shall be in accordance with the following:

Coarse Aggregate, Class D or Higher, Size No. 53 .....	904.03
<del>Concrete .....</del>	<del>502</del>
Joint Materials .....	906
Joint Mortar .....	907.12
Precast Concrete Curbing .....	905.04
Reinforcing Bars .....	910.01

*Concrete shall be in accordance with 502 except the minimum modulus of rupture shall be 550 psi at 28 days.*

---

---