

708-R-766 PNEUMATICALLY PLACED MORTAR

(Adopted 08-17-23)

The Standard Specifications are revised as follows:

SECTION 708, BEGIN LINE 10, DELETE AND INSERT AS FOLLOWS:

708.02 Materials

Materials shall be in accordance with the following:

Deformed and Smooth Steel WWR	910.01(a), 910.01(b)5
Fine Aggregate	904.02(d)
Fly Ash	901.02
Portland Cement.....	901.01(b)
Water	913.01

WWR shall consist of wire, size W 1.2 ~~or approximately No. 12 gauge~~ or larger, *or D 1 or larger*, spaced and welded at intervals greater than or equal to 2 in., and no greater than 4 in.

SECTION 910, BEGIN LINE 17, DELETE AND INSERT AS FOLLOWS:

WWR used for pneumatically placed mortar will be accepted by a ~~Type A~~ Certification, *Other* in accordance with 916.02(f). ~~When shipped to the project site, the reinforcing bars and WWR shall be accompanied by the type of certifications specified in ITM 301 and in accordance with 916~~*This certification shall accompany the WWR when it is shipped to the project site.*