PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC

ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394

FACILITY BP PRODUCTS NORTH AMERICA INC.

LOCATION WHITING

ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*

Revised: **DISCHARGE MONITORING REPORT** *(DMR)*

PERMIT NUMBER	DISCHARGE NUMBER
IN0000108	001A

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	11	01	05	TO	11	30	05

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

IN0000108001A1105

For Any Questions call Jeff Ewick at 317-233-0676

*** NO DISCHARGE ☐ ***

NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
CHROMIUM, HEXAVALENT (AS CR) 01032 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	<0.5	<0.6	(26)	********	<0.005	<0.005	(19)	0	WEEKLY	COMP 24
	PERMIT REQUIREMENT	12.01 MO AVG	48 DAILY MX	LBS/DY		REPORT MO AVG	REPORT DAILY MX	MG/L		WEEKLY	COMP 24
CHROMIUM, TOTAL (AS CR) 01034 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	<0.9	<1.1	(26)	********	<0.01	<0.01	(19)	0	WEEKLY	COMP 24
	PERMIT REQUIREMENT	28.9 MO AVG	68.56 DAILY MX	LBS/DY		REPORT MO AVG	REPORT DAILY MX	MG/L		WEEKLY	COMP 24
PHENOLICS, TOTAL RECOVERABLE 32730 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	<0.98	<1.28	(26)	********	<0.01	<0.01	(19)	0	THREE/ WEEK	COMP 24
	PERMIT REQUIREMENT	20.33 MO AVG	73.01 DAILY MX	LBS/DY		REPORT MO AVG	REPORT DAILY MX	MG/L		THREE/ WEEK	COMP 24
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	11.6	15.4	(03)	********	********	********		0	DAILY	CONTIN
	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD				********		DAILY	CONTIN
FLOW, TOTAL 82220 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	349.1	(3R)	********	********	********		0	ONCE/ MONTH	RCOTOT
	PERMIT REQUIREMENT		REPORT MO TOTAL	MGAL				********		ONCE/ MONTH	
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J. Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

Daniel J. Sajkowski

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE AREA CODE	TELEPHONE NUMBER	DATE MO	DATE DAY	DATE YEAR
219	473-3179	12	28	05

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

1 004 135 0 0004 9538 4 4 0 6

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC
ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394
FACILITY BP PRODUCTS NORTH AMERICA INC.
LOCATION WHITING
ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
Revised: **DISCHARGE MONITORING REPORT** *(DMR)*

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

IN0000108	001A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	12	01	05	TO	12	31	05

IN0000108001A1205

For Any Questions call Jeff Ewick at 317-233-0676

*** NO DISCHARGE ☐ ***

NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	121	200	(26) LBS/DY	********	1.0	2.1	(19) MG/L	0	5 TIMES /WEEK	COMP 24
	PERMIT REQUIREMENT	4181 MO AVG	8164 DAILY MX			REPORT MO AVG	REPORT DAILY MX			5 TIMES/WEEK	COMP 24
OXYGEN DEMAND, CHEM. (LOW LEVEL) (COD) 00335 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	3760	5074	(26) LBS/DY	********	32	53	(19) MG/L	0	THREE/	COMP 24
	PERMIT REQUIREMENT	30323 MO AVG	58427 DAILY MX			REPORT MO AVG	REPORT DAILY MX			THREE/WEEK	COMP 24
PH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	********	********	7.4	********	8.0	(12) SU	0	THREE/ WEEK	GRAB
	PERMIT REQUIREMENT				6.0 MINIMUM		9.0 MAXIMUM				
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	882	1790	(26) LBS/DY	********	7.4	33.0	(19) MG/L	0	5 TIMES /WEEK	COMP 24
	PERMIT REQUIREMENT	3646 MO AVG	5694 DAILY MX			REPORT MO AVG	REPORT DAILY MX			5 TIMES/WEEK	COMP 24
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC 00560 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	<46	112	(26) LBS/DY	********	< 0.4	0.8	(19) MG/L	0	WEEK/ * DAYS	GRAB
	PERMIT REQUIREMENT	1368 MO AVG	2600 DAILY MX			REPORT MO AVG	REPORT DAILY MX			WEEK/DAYS	GRAB
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	<78	660	(26) LBS/DY	********	< 0.64	5.46	(19) MG/L	0	5 TIMES /WEEK	COMP 24
	PERMIT REQUIREMENT	1010 MO AVG	2060 DAILY MX			REPORT MO AVG	REPORT DAILY MX				
SULFIDE, TOTAL (AS S) 00745 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	<0.3	1.2	(26) LBS/DY	********	< 0.00	0.01	(19) MG/L	0	WEEKLY	COMP 24
	PERMIT REQUIREMENT	20.1 MO AVG	51.4 DAILY MX			REPORT MO AVG	REPORT DAILY MX			WEEKLY	COMP 24

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J. Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
AREA CODE	NUMBER	MO	DAY	YEAR
219	473-3179	1	24	06

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

* Due to low flows on 12/27/05 the oil and grease results was an average of two grab samples as opposed to the routine three samples. The evening sample volume was not sufficient enough to include.

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

INDUSTRIAL MAJOR, LAKE COUNTY

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC

ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394

FACILITY BP PRODUCTS NORTH AMERICA INC.

LOCATION WHITING

ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*

Revised **DISCHARGE MONITORING REPORT** *(DMR)*

IN0000108	001A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	12	01	05	TO	12	31	05

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

+ I N 0 0 0 0 1 0 8 0 0 1 A 1 2 0 5 +

For Any Questions call Jeff Ewick at 317-233-0676

*** **NO DISCHARGE** ☐ ***

NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
CHROMIUM, HEXAVALENT (AS CR) 01032 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	<0.6	<0.7	(26) LBS/DY	********	<0.005	<0.005	(19) MG/L	0	WEEKLY	COMP 24
	PERMIT REQUIREMENT	2.01 MO AVG	4.48 DAILY MX			REPORT MO AVG	REPORT DAILY MX			WEEKLY	COMP 24
CHROMIUM, TOTAL (AS CR) 01034 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	<1.2	<1.3	(26) LBS/DY	********	<0.01	<0.01	(19) MG/L	0	WEEKLY	COMP 24
	PERMIT REQUIREMENT	23.9 MO AVG	68.53 DAILY MX			REPORT MO AVG	REPORT DAILY MX			WEEKLY	COMP 24
PHENOLICS, TOTAL RECOVERABLE 32730 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	<1.16	<1.41	(26) LBS/DY	********	<0.01	<0.01	(19) MG/L	0	THREE/ WEEK	COMP 24
	PERMIT REQUIREMENT	20.33 MO AVG	78.01 DAILY MX			REPORT MO AVG	REPORT DAILY MX			THREE/ WEEK	COMP 24
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	14.5	18.8	(03) MGD	********	********	********	********	0	DAILY	CONTIN
	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX							DAILY	CONTIN
FLOW, TOTAL 82220 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	450.9	(3R) MGAL	********	********	********	********	0	ONCE/ MONTH	RCOTOT
	PERMIT REQUIREMENT		REPORT MO TOTAL							ONCE/ MONTH	RCOTOT
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT			TELEPHONE		DATE		
Authorized Agent: Daniel J. Sajkowski Business Unit Leader	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT	219	473-3179	1	24	06
TYPED OR PRINTED			AREA CODE	NUMBER	MO	DAY	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC

ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394

FACILITY BP PRODUCTS NORTH AMERICA INC.

LOCATION WHITING

ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*

Revised: **DISCHARGE MONITORING REPORT** *(DMR)*

IN0000108	002A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	12	01	05	TO	12	31	05

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

For Any Questions call Jeff Ewick at 317-233-0676

*** NO DISCHARGE ☐ ***

NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	********		********	17	21	(04)	0	5 TIMES /WEEK	CONTIN
	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	DEG.C			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 7 0 0 INTAKE FROM STREAM	SAMPLE MEASUREMENT	********	********		********	13	13	(04)	0	5 TIMES /WEEK	CONTIN
	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	DEG.C			
WASTE HEAT REJECTION RATE 00179 2 0 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	195	376	(05)	********	********	********		0	5 TIMES /WEEK	CONTIN
	PERMIT REQUIREMENT	700 MO AVG	2000 MX DA AV	MBTU/ HR				********			
PH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	********		8.1	********	8.3	(12)	0	THREE/ WEEK	GRAB
	PERMIT REQUIREMENT			********	MINIMUM		MAXIMUM	SU		THREE/ WEEK	GRAB
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC 00560 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	********		********	<0.3	<0.3	(19)	0	THREE/ WEEK	GRAB
	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L		THREE/ WEEK	GRAB
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC 00560 2 0 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	********	********		********	<0.3	<0.3	(19)	0	THREE/ WEEK	GRAB
	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L		THREE/ WEEK	GRAB
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC 00560 7 0 0 INTAKE FROM STREAM	SAMPLE MEASUREMENT	********	********		********	<0.3	<0.3	(19)	0	THREE/ WEEK	GRAB
	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L		THREE/ WEEK	GRAB

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J.Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
219	473-3179	1	24	06
AREA CODE	NUMBER	MO	DAY	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

INDUSTRIAL MAJOR LAKE COUNTY

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC

ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394

FACILITY BP PRODUCTS NORTH AMERICA INC.

LOCATION WHITING

ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM ***(NPDES)***

Revised: **DISCHARGE MONITORING REPORT** ***(DMR)***

IN0000108	002A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	12	01	05	TO	12	31	05

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

* 1 N 0 0 0 0 1 0 8 0 0 2 A 1 2 0 5 *

For Any Questions call Jeff Ewick at 317-233-0676

*** **NO DISCHARGE** ☐ ***

NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	********	********		********	2	2	(19)	0	5 TIMES /WEEK	GRAB
00680 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L			
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	********	********		********	0	0	(19)	0	5 TIMES /WEEK	GRAB
00680 2 0 0 EFFLUENT NET VALUE	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L			
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	********	********		********	2	2	(19)	0	5 TIMES /WEEK	GRAB
00680 7 0 0 INTAKE FROM STREAM	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	74.5	76.9	(03)	********	********	********		0	DAILY	CONTIN
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD				********			
CHLORINE, TOTAL RESIDUAL	SAMPLE MEASUREMENT	********	********		********	0.05	0.05	(19)	0	WEEKLY	GRAB
50060 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L			
FLOW, TOTAL	SAMPLE MEASUREMENT	********	2308.2	(3R)	********	********	********		0	ONCE/ MONTH	RCOTOT
82220 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT		REPORT MO TOTAL	MGAL				********			
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J. Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
219	473-3179	1	24	06
AREA CODE	NUMBER	MO	DAY	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC
ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394
FACILITY BP PRODUCTS NORTH AMERICA INC.
LOCATION WHITING
ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM ***(NPDES)***
Revised: **DISCHARGE MONITORING REPORT** ***(DMR)***

IN0000108	003A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	12	01	05	TO	12	31	05

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

IN0000108003A1205

For Any Questions call Jeff Ewick at 317-233-0676

*** **NO DISCHARGE** [X] ***

NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
PH	SAMPLE MEASUREMENT	********	********		No discharge	********	No discharge	(12)	0	*	*
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********	MINIMUM		MAXIMUM	SU			
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC	SAMPLE MEASUREMENT	********	********		********	No discharge	No discharge	(19)	0	*	*
00560 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********		REPORT MO AVG	DAILY MX	MG/L			
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	********	********		********	No discharge	No discharge	(19)	0	*	*
00680 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********		REPORT MO AVG	110 DAILY MX	MG/L			
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J. Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
219	473-3179	1	24	06
AREA CODE	NUMBER	MO	DAY	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

* Required to sample on 1st discharge of week. Outfall 003 was closed the entire month of December.

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC
ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394
FACILITY BP PRODUCTS NORTH AMERICA INC.
LOCATION WHITING
ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM ***(NPDES)***
Revised: **DISCHARGE MONITORING REPORT** ***(DMR)***

IN0000108	004A
PERMIT NUMBER	**DISCHARGE NUMBER**

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	12	01	05	TO	12	31	05

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

IN0000108004A1205

For Any Questions call Jeff Ewick at 317-233-0676

*** **NO DISCHARGE** [X] ***

NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
PH	SAMPLE MEASUREMENT	********	********		No discharge	********	No discharge	(12)	0	*	*
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********	6 MINIMUM		9 MAXIMUM	SU		DAILY MX	GRAB
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC	SAMPLE MEASUREMENT	********	********		********	No discharge	No discharge	(19)	0	*	*
00560 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********		REPORT MO.AVG	15.0 DAILY MX	MG/L		ONCE MONTH	GRAB
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	********	********		********	No discharge	No discharge	(19)	0	*	*
00680 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********		REPORT MO.AVG	110 DAILY MX	MG/L		WEEKLY	GRAB
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J. Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
219	473-3179	1	04	06
AREA CODE	NUMBER	MO	DAY	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

* Required to sample on 1st discharge of week. Outfall 004 was closed the entire month of December.

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

BP PRODUCTS NORTH AMERICA Inc., WHITING REFINERY
2815 INDIANAPOLIS BLVD., WHITING, INDIANA 46394

PERMIT NO IN0000108 OUTFALL 001 Dec-05 DEC PROCESS WATER EFFLUENT

PARAMETER	FLOW	BOD		COD		pH	TSS		OIL		NH3-N		SULFIDE	
CODE	Q50050	Q00310		Q00340		C00400	Q00547		Q00550		Q00610		Q00745	
SAMPLE TYPE														
PERMIT	CONT	24		24		GRAB	24		3/DAY		24		24	
ACTUAL	CONT	24		24		GRAB	24		3/DAY		24		24	
FREQUENCY														
PERMIT	CONT	5/7		3/7		3/7	5/7		5/7		5/7		1/7	
ACTUAL	CONT	5/7		3/7		3/7	5/7		5/7		5/7		1/7	
LIMITS: AVG			4161		30323			3646		1368		1030		23.1
MAX			8164		58427	6.5-9		5694		2600		2060		51.4
DATE	MG/D	mg/l	LB/D	mg/l	LB/D	pH	mg/l	LB/D	mg/l	LB/D	mg/l	LB/D	mg/l	LB/D
1	13.7	1.1	126	35	3999	—	3.2	366	0.3	34	—	—	—	—
2	14.0	—	—	—	—	7.6	—	—	<0.3	<35	<0.10	<12	—	—
3	15.9	—	—	—	—	—	—	—	—	—	<0.10	<13	—	—
4	15.5	1.1	142	29	3749	—	5.2	672	—	—	—	—	—	—
5	16.3	1.1	150	—	—	7.7	8.8	1196	0.4	54	<0.10	<14	<0.00	<0.0
6	16.8	0.9	126	36	5044	—	9.4	1317	0.8	112	<0.10	<14	—	—
7	16.0	1.5	200	—	—	7.7	12.8	1708	0.6	80	<0.10	<13	—	—
8	14.7	1.3	159	32	3923	—	14.6	1790	0.8	98	—	—	—	—
9	16.9	—	—	—	—	7.4	—	—	0.3	42	<0.10	<14	—	—
10	18.8	—	—	—	—	—	—	—	—	—	<0.10	<16	—	—
11	16.9	1.0	141	27	3806	—	4.8	677	—	—	—	—	—	—
12	16.7	0.9	125	—	—	7.7	5.4	752	0.4	56	<0.10	<14	<0.00	<0.0
13	15.9	0.9	119	28	3713	—	3.2	424	<0.3	<40	<0.10	<13	—	—
14	15.3	0.9	115	—	—	7.7	8.8	1123	<0.3	<38	3.25	415	—	—
15	14.8	0.9	111	32	3950	—	4.4	543	<0.3	<37	—	—	—	—
16	14.5	—	—	—	—	7.7	—	—	<0.3	<36	5.46	660	—	—
17	14.7	—	—	—	—	—	—	—	—	—	1.07	131	—	—
18	14.0	1.3	152	31	3620	—	6.2	724	—	—	—	—	—	—
19	13.8	1.2	138	—	—	7.5	5.0	575	0.4	46	<0.10	<12	<0.00	<0.0
20	13.9	0.8	93	28	3246	—	4.4	510	0.3	35	<0.10	<12	—	—
21	15.2	0.8	101	—	—	7.7	5.8	735	0.3	38	<0.10	<13	—	—
22	15.6	1.4	182	39	5074	—	8.4	1093	0.3	39	—	—	—	—
23	13.8	—	—	—	—	7.9	—	—	0.3	35	<0.10	<12	—	—
24	13.5	—	—	—	—	—	—	—	—	—	<0.10	<11	—	—
25	13.4	0.2	22	32	3576	—	6.6	738	—	—	—	—	—	—
26	14.1	0.2	24	—	—	7.8	6.6	776	<0.3	<35	<0.10	<12	0.01	1.2
27	3.5	2.1	61	53	1547	—	33.0	963	0.4	12	<0.10	<3	—	—
28	11.5	1.3	125	—	—	7.5	8.8	844	<0.3	<29	<0.10	<10	—	—
29	12.8	1.3	139	34	3630	—	9.4	1003	<0.3	<32	—	—	—	—
30	14.2	—	—	—	—	8	—	—	0.5	59	0.87	103	—	—
31	14.2	—	—	—	—	—	—	—	—	—	1.65	195	—	—
AVERAGE	14.5	1.0	121	32	3760	7.7	7.4	882	<0.4	<46	<0.64	<78	<0.00	<0.3
HIGHEST VAL.	18.8	2.1	200	53	5074	8.0	33.0	1790	0.8	112	5.46	660	0.01	1.2
LOWEST VAL.	3.5	0.2	22	27	1547	7.4	3.2	366	<0.3	12	<0.10	<3	<0.00	<0.0
OVER LIMIT			0		0	0		0		0		0		0
TOTAL	450.9													

CERTIFIED OPERATOR : David J. Olen NO. 14118 exp. 6/30/06 DATE : 1-16-06 ENVIRONMENTAL ENGINEER : Richard A. Harris

–MEANS NOT TESTED THIS DATE

BP PRODUCTS NORTH AMERICA, Inc., WHITING REFINERY
2815 INDIANAPOLIS BLVD., WHITING, INDIANA 46394

PERMIT NO IN0000108 OUTFALL 001 Dec-05 DEC PROCESS WATER EFFLUENT

PARAMETER	HX. CHRM	TL.CHRM	PHENOL	SELENIUM	ORTHO-P	FECAL C.
CODE	Q01032	Q00034	Q32730	CO1147	C00670	**
SAMPLE TYPE						
PERMIT	24	24	24	24	–	GRAB
ACTUAL	24	24	24	24	24	GRAB
FREQUENCY						
PERMIT	1/7	1/7	3/7	2/YR	–	5/7
ACTUAL	1/7	1/7	3/7	2/YR	2/7	5/7

LIMITS:	AVG.	2.01		23.90						200
	MAX.	4.48		68.53						400
DATE	mg/l	LB/D	mg/l	LB/D	mg/l	LB/D	ug/l	LB/D	MG/L	COLONIES
1	—	—	—	—	<0.01	<1.14			0.35	—
2	—	—	—	—	—	—			—	—
3	—	—	—	—	—	—			—	—
4	—	—	—	—	<0.01	<1.29			0.82	—
5	—	—	—	—	—	—			—	—
6	—	—	—	—	<0.01	<1.40			—	—
7	<0.005	<0.7	<0.01	<1.3	—	—			—	—
8	—	—	—	—	<0.01	<1.23			0.99	—
9	—	—	—	—	—	—			—	—
10	—	—	—	—	—	—			—	—
11	—	—	—	—	<0.01	<1.41			0.78	—
12	—	—	—	—	—	—			—	—
13	—	—	—	—	<0.01	<1.33			—	—
14	<0.005	<0.6	<0.01	<1.3	—	—			—	—
15	—	—	—	—	<0.01	<1.23			0.54	—
16	—	—	—	—	—	—			—	—
17	—	—	—	—	—	—			—	—
18	—	—	—	—	<0.01	<1.17			0.66	—
19	—	—	—	—	—	—			—	—
20	—	—	—	—	<0.01	<1.16			—	—
21	<0.005	<0.6	<0.01	<1.3	—	—			—	—
22	—	—	—	—	<0.01	<1.30			0.50	—
23	—	—	—	—	—	—			—	—
24	—	—	—	—	—	—			—	—
25	—	—	—	—	<0.01	<1.12			1.13	—
26	—	—	—	—	—	—			—	—
27	—	—	—	—	<0.01	<0.29			—	—
28	<0.005	<0.5	<0.01	<1.0	—	—			—	—
29	—	—	—	—	<0.01	<1.07			0.70	—
30	—	—	—	—	—	—			—	—
31	—	—	—	—	—	—			—	—
AVERAGE	<0.005	<0.6	<0.01	<1.2	<0.01	<1.16			0.71	0
HIGHEST VAL.	<0.005	<0.7	<0.01	<1.3	<0.01	<1.41			1.13	
LOWEST VAL.	<0.005	<0.5	<0.01	<1.0	<0.01	<0.29			0.35	
OVER LIMIT		0		0		0				0

CERTIFIED OPERATOR: David J. Olsen NO. 14118 exp. 6/30/06 DATE: 1-16-06 AUTHORIZED AGENT: Richard A. Harris

–MEANS NOT TESTED THIS DATE

**FECAL COLIFORM ARE LIMITED FROM APRIL 1 TO OCT. 1 WHEN REFINERY SANITARY SEWERS ARE DISCHARGING TO AMOCO WWTP.

BP PRODUCTS NORTH AMERICA Inc., WHITING REFINERY
2815 INDIANAPOLIS BLVD., WHITING, INDIANA 46394

PERMIT NO IN0000108 OUTFALL 002 Dec-05 DEC COOLING WATER EFFLUENT

PARAMETER	FLOW	IN-TEMP	OUT-TEMP	HEAT	pH	IN-OIL	OUT-OIL	DELTA OIL	IN-TOC	OUT-TOC	DELTA-TOC	RESID-CL
CODE	Q50050		C00010	C99003	C00400		C00550		C99680	C00680		
SAMPLE TYPE												
PERMIT	CONT	CONT	CONT	CONT	GRAB	GRAB	GRAB	GRAB	GRAB	GRAB	GRAB	GRAB
ACTUAL	CONT	CONT	CONT	CONT	GRAB	GRAB	GRAB	GRAB	GRAB	GRAB	GRAB	GRAB
FREQUENCY												
PERMIT	CONT	5/7	5/7	5/7	3/7	3/7	3/7	3/7	5/7	5/7	5/7	1/7
ACTUAL	CONT	CONT	CONT	CONT	3/7	3/7	3/7	5/7	5/7	5/7	5/7	1/7
LIMITS: AVG.				1.70								
MAX.				2.00	7-9			5			5	.05
DATE	MG/D	DEG C	DEG C	GBTU/HR	pH	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l
1	75.2	13	21	0.376	—	—	—	—	2	2	0	—
2	75.9	13	19	0.285	8.3	<0.3	<0.3	<0.3	2	2	0	—
3	75.3	13	19	0.282	—	—	—	—	—	—	—	—
4	74.3	13	19	0.279	—	—	—	—	—	—	—	—
5	75.4	13	19	0.283	8.2	<0.3	<0.3	<0.3	2	2	0	—
6	76.9	12	18	0.288	—	—	—	—	2	2	0	—
7	76.1	12	18	0.285	8.2	<0.3	<0.3	<0.3	2	2	0	0.05
8	75.5	13	17	0.189	—	—	—	—	2	2	0	—
9	75.0	13	16	0.141	8.1	<0.3	<0.3	<0.3	2	2	0	—
10	75.3	13	16	0.141	—	—	—	—	—	—	—	—
11	74.9	13	16	0.140	—	—	—	—	—	—	—	—
12	74.7	13	16	0.140	8.2	<0.3	<0.3	<0.3	2	2	0	—
13	73.8	13	16	0.138	—	—	—	—	2	2	0	—
14	73.8	13	16	0.138	8.1	<0.3	<0.3	<0.3	2	2	0	0.05
15	73.6	13	16	0.138	—	—	—	—	2	2	0	—
16	73.7	13	16	0.138	8.1	<0.3	<0.3	<0.3	2	2	0	—
17	74.4	13	15	0.093	—	—	—	—	—	—	—	—
18	76.4	13	15	0.095	—	—	—	—	—	—	—	—
19	75.3	13	15	0.094	8.1	<0.3	<0.3	<0.3	2	2	0	—
20	74.9	13	15	0.094	—	—	—	—	2	2	0	—
21	75.9	13	15	0.095	8.2	<0.3	<0.3	<0.3	2	2	0	0.05
22	69.4	13	16	0.130	—	—	—	—	2	2	0	—
23	75.3	13	17	0.188	8.3	<0.3	<0.3	<0.3	2	2	0	—
24	74.1	13	17	0.185	—	—	—	—	—	—	—	—
25	73.9	13	18	0.231	—	—	—	—	—	—	—	—
26	75.0	13	18	0.234	8.2	<0.3	<0.3	<0.3	2	2	0	—
27	69.4	13	18	0.217	—	—	—	—	2	2	0	—
28	73.5	13	19	0.276	8.1	<0.3	<0.3	<0.3	2	2	0	0.05
29	74.1	13	18	0.231	—	—	—	—	2	2	0	—
30	74.1	13	18	0.231	8.2	<0.3	<0.3	<0.3	2	2	0	—
31	73.1	13	19	0.274	—	—	—	—	—	—	—	—
AVERAGE	74.5	13	17	0.195	8.2	<0.3	<0.3	<0.3	2	2	0	0.05
HIGHEST VAL.	76.9	13	21	0.376	8.3	<0.3	<0.3	<0.3	2	2	0	0.05
LOWEST VAL.	69.4	12	15	0.093	8.1	<0.3	<0.3	<0.3	2	2	0	0.05
OVER LIMIT	0			0	0			0			0	0
TOTAL	2308.2											

CERTIFIED OPERATOR : David J. Olen NO. 14118 exp. 6/30/06 DATE: 1-16-06 ENVIRONMENTAL ENGINEER : Richard A. Harris

--MEANS NOT TESTED THIS DATE

BP PRODUCTS NORTH AMERICA Inc., WHITING REFINERY
2815 INDIANAPOLIS BLVD., WHITING, INDIANA 46394

PERMIT NO. IN0000108 Dec-05 DEC STORM WATER RUNOFF

----OUTFALL 004----

*** NOTE: TO BE SAMPLED AFTER EACH RAIN EVENT IF DISCHARGE OCCURS - ONCE PER WEEK

PARAMETER CODE:		pH C00400	OIL C00550	TOC C00680	
LIMITS:	MAX.	6-9	15	110	
DATA			mg/l	mg/l	
	1	-------	-------	-------	CLOSED
	2	-------	-------	-------	CLOSED
	3	-------	-------	-------	CLOSED
	4	-------	-------	-------	CLOSED
	5	-------	-------	-------	CLOSED
	6	-------	-------	-------	CLOSED
	7	-------	-------	-------	CLOSED
	8	-------	-------	-------	CLOSED
	9	-------	-------	-------	CLOSED
	10	-------	-------	-------	CLOSED
	11	-------	-------	-------	CLOSED
	12	-------	-------	-------	CLOSED
	13	-------	-------	-------	CLOSED
	14	-------	-------	-------	CLOSED
	15	-------	-------	-------	CLOSED
	16	-------	-------	-------	CLOSED
	17	-------	-------	-------	CLOSED
	18	-------	-------	-------	CLOSED
	19	-------	-------	-------	CLOSED
	20	-------	-------	-------	CLOSED
	21	-------	-------	-------	CLOSED
	22	-------	-------	-------	CLOSED
	23	-------	-------	-------	CLOSED
	24	-------	-------	-------	CLOSED
	25	-------	-------	-------	CLOSED
	26	-------	-------	-------	CLOSED
	27	-------	-------	-------	CLOSED
	28	-------	-------	-------	CLOSED
	29	-------	-------	-------	CLOSED
	30	-------	-------	-------	CLOSED
	31	-------	-------	-------	CLOSED
AVERAGE		0.0	0.0	0	
HIGHEST VAL.		0.0	0.0	0	
LOWEST VAL.		0.0	0.0	0	
OVER LIMIT		0	0	0	

CERTIFIED OPERATOR : David J. Olen NO. 14118 exp.6/30/06 DATE : 1-16-06 ENVIRONMENTAL ENGINEER : Richard A. Young

BP PRODUCTS NORTH AMERICA Inc., WHITING REFINERY
2815 INDIANAPOLIS BLVD., WHITING, INDIANA 46394

PERMIT NO. IN0000108 Dec-05 DEC STORM WATER RUNOFF

----OUTFALL 003----

*** NOTE: TO BE SAMPLED AFTER EACH RAIN EVENT IF DISCHARGE OCCURS - ONCE PER WEEK

PARAMETER		pH	OIL	TOC	
CODE:		C00400	C00550	C00680	
LIMITS:	MAX.	6-9	15	110	
DATA			mg/l	mg/l	
	1	-------	-------	-------	CLOSED
	2	-------	-------	-------	CLOSED
	3	-------	-------	-------	CLOSED
	4	-------	-------	-------	CLOSED
	5	-------	-------	-------	CLOSED
	6	-------	-------	-------	CLOSED
	7	-------	-------	-------	CLOSED
	8	-------	-------	-------	CLOSED
	9	-------	-------	-------	CLOSED
	10	-------	-------	-------	CLOSED
	11	-------	-------	-------	CLOSED
	12	-------	-------	-------	CLOSED
	13	-------	-------	-------	CLOSED
	14	-------	-------	-------	CLOSED
	15	-------	-------	-------	CLOSED
	16	-------	-------	-------	CLOSED
	17	-------	-------	-------	CLOSED
	18	-------	-------	-------	CLOSED
	19	-------	-------	-------	CLOSED
	20	-------	-------	-------	CLOSED
	21	-------	-------	-------	CLOSED
	22	-------	-------	-------	CLOSED
	23	-------	-------	-------	CLOSED
	24	-------	-------	-------	CLOSED
	25	-------	-------	-------	CLOSED
	26	-------	-------	-------	CLOSED
	27	-------	-------	-------	CLOSED
	28	-------	-------	-------	CLOSED
	29	-------	-------	-------	CLOSED
	30	-------	-------	-------	CLOSED
	31	-------	-------	-------	CLOSED
AVERAGE		0.0	0.0	0	
HIGHEST VAL.		0.0	0.0	0	
LOWEST VAL.		0.0	0.0	0	
OVER LIMIT		0	0	0	

CERTIFIED OPERATOR : David L. Olen NO. 14118 exp.6/30/06 DATE : 1-16-06 ENVIRONMENTAL ENGINEER : Richard A. Harris

bp

Daniel J. Sajkowski
Business Unit Leader
Whiting Business Unit

BP Products North America Inc.
2815 Indianapolis Boulevard
Whiting, IN 46394-0710
USA

CERTIFIED MAIL
RETURN RECEIPT REQUESTED
January 26, 2006

Indiana Department of Environmental Management
OWQ Data Management Section
100 North Senate Avenue
Indianapolis, IN 46206-6015

NPDES Permit No. 0000108, Serials 001, 002, 003, and 004

Direct 219 473 3179
Fax 219 473 3504
Mobile 219 545 5860
sajkowdj@bp.com

Effluent quality data and Discharge Monitoring Report forms from the BP Products North America Inc. - Whiting Business Unit for the month of December 2005, are attached. Effluent quality from the wastewater treatment plant for the month was excellent. I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

If you have any questions or need any additional information, please contact R. A. Harris at (219) 473-3321.

Sincerely,

Daniel J. Sajkowski
Business Unit Leader

Attachments

7004 0550 0000 3800 1302

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC.
ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BOULEVARD
WHITING IN 46394
FACILITY BP PRODUCTS NORTH AMERICA INC.
LOCATION WHITING
ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
Revised: **DISCHARGE MONITORING REPORT** *(DMR)*

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

IN0000108	001A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	01	01	05	TO	01	31	05

IN0000108001A0105

For Any Questions call Jeff Ewick at 317-233-0676

*** NO DISCHARGE ☐ ***

NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	215	470	(26) LBS/DY	********	1.6	4.3	(19) MG/L	0	5 TIME /WEEK	COMP 24
	PERMIT REQUIREMENT	[redacted]	[redacted]		[redacted]	[redacted]	[redacted]			[redacted]	[redacted]
OXYGEN DEMAND, CHEM. (LOW LEVEL) (COD) 00335 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	5440	8977	(26) LBS/DY	********	41	69	(19) MG/L	0	THREE /WEEK	COMP 24
	PERMIT REQUIREMENT	[redacted]	[redacted]		[redacted]	[redacted]	[redacted]			[redacted]	[redacted]
PH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	********	********	7.5	********	7.7	(12) SU	0	THREE /WEEK	GRAB
	PERMIT REQUIREMENT	[redacted]	[redacted]		[redacted]	[redacted]	[redacted]			[redacted]	[redacted]
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	1368	3824	(26) LBS/DY	********	10.4	35.0	(19) MG/L	0	5 TIMES /WEEK	COMP 24
	PERMIT REQUIREMENT	[redacted]	[redacted]		[redacted]	[redacted]	[redacted]			[redacted]	[redacted]
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC 00560 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	∠ 88	208	(26) LBS/DY	********	∠ 0.7	1.6	(19) MG/L	0	WEEK-DAYS	GRAB
	PERMIT REQUIREMENT	[redacted]	[redacted]		[redacted]	[redacted]	[redacted]			[redacted]	[redacted]
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	∠ 14	24	(26) LBS/DY	********	∠ 0.11	0.21	(19) MG/L	0	5 TIMES /WEEK	COMP 24
	PERMIT REQUIREMENT	[redacted]	[redacted]		[redacted]	[redacted]	[redacted]			[redacted]	[redacted]
SULFIDE, TOTAL (AS S) 00745 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	∠ 1.1	1.5	(26) LBS/DY	********	∠ 0.01	0.01	(19) MG/L	0	WEEKLY	COMP 24
	PERMIT REQUIREMENT	[redacted]	[redacted]		[redacted]	[redacted]	[redacted]			[redacted]	[redacted]

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J. Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
219	473-3179	02	24	05
AREA CODE	NUMBER	MO	DAY	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

INDUSTRIAL MAJOR LAKE COUNTY

7005 1820 0008 2659 1055

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC
ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394
FACILITY BP PRODUCTS NORTH AMERICA INC.
LOCATION WHITING
ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
Revised: **DISCHARGE MONITORING REPORT** *(DMR)*

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

IN0000108	001A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	01	01	06	TO	01	31	06

For Any Questions call Jeff Ewick at 317-233-0676

*** NO DISCHARGE ☐ ***
NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	265	584	(26) LBS/DY	********	2.2	4.8	(19) MG/L	0	5 TIMES /WEEK	COMP 24
	PERMIT REQUIREMENT	1161 MO AVG	2164 DAILY MX			REPORT MO AVG	REPORT DAILY MX				
OXYGEN DEMAND, CHEM. (LOW LEVEL) (COD) 00335 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	5776	7473	(26) LBS/DY	********	48	64	(19) MG/L	0	THREE/ WEEK	COMP 24
	PERMIT REQUIREMENT	30623 MO AVG	56842 DAILY MX			REPORT MO AVG	REPORT DAILY MX				
PH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	********	********	7.6	********	7.8	(12) SU	0	THREE/ WEEK	GRAB
	PERMIT REQUIREMENT				6.5 MINIMUM		9 MAXIMUM				
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	1293	2290	(26) LBS/DY	********	10.6	18.0	(19) MG/L	0	5 TIMES /WEEK	COMP 24
	PERMIT REQUIREMENT	3676 MO AVG	5694 DAILY MX			REPORT MO AVG	REPORT DAILY MX				
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC 00560 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	142	253	(26) LBS/DY	********	1.2	2.2	(19) MG/L	0	WEEK-DAYS	GRAB
	PERMIT REQUIREMENT	1306 MO AVG	2600 DAILY MX			REPORT MO AVG	REPORT DAILY MX				
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	<88	289	(26) LBS/DY	********	<0.71	2.59	(19) MG/L	0	5 TIMES /WEEK	COMP 24
	PERMIT REQUIREMENT	1030 MO AVG	2060 DAILY MX			REPORT MO AVG	REPORT DAILY MX				
SULFIDE, TOTAL (AS S) 00745 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	<1.2	2.4	(26) LBS/DY	********	<0.01	0.02	(19) MG/L	0	WEEKLY	COMP 24
	PERMIT REQUIREMENT	28.1 MO AVG	51.4 DAILY MX			REPORT MO AVG	REPORT DAILY MX				

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J. Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
219	473-3179	2	22	06
AREA CODE	NUMBER	MO	DAY	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

INDUSTRIAL MAJOR, LAKE COUNTY

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC

ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394

FACILITY BP PRODUCTS NORTH AMERICA INC.

LOCATION WHITING

ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*

Revised:

DISCHARGE MONITORING REPORT *(DMR)*

IN0000108	001A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	01	01	06	TO	01	31	06

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

* I N 0 0 0 0 1 0 8 0 0 1 A 0 1 0 6 *

For Any Questions call Jeff Ewick at 317-233-0676

*** NO DISCHARGE ☐ ***

NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
CHROMIUM, HEXAVALENT (AS CR) 01032 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	∠0.6	∠0.7	(26) LBS/DY	********	∠0.005	∠0.005	(19) MG/L	0	WEEKLY	COMP 24
	PERMIT REQUIREMENT	2.41 MO AVG	6.48 DAILY MX			REPORT MO AVG	REPORT DAILY MX				
CHROMIUM, TOTAL (AS CR) 01034 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	∠1.2	∠1.4	(26) LBS/DY	********	∠0.01	∠0.01	(19) MG/L	0	WEEKLY	COMP 24
	PERMIT REQUIREMENT	2.9 MO AVG	8.50 DAILY MX			REPORT MO AVG	REPORT DAILY MX				
PHENOLICS, TOTAL RECOVERABLE 32730 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	∠1.21	1.43	(26) LBS/DY	********	∠0.01	0.01	(19) MG/L	0	THREE/ WEEK	COMP 24
	PERMIT REQUIREMENT	2.08 MO AVG	7.30 DAILY MX			REPORT MO AVG	REPORT DAILY MX				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	14.7	17.2	(03) MGD	********	********	********	********	0	DAILY	CONTIN
	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX								
FLOW, TOTAL 82220 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	456.5	(3R) MGAL	********	********	********	********	0	ONCE/ MONTH	RCOTOT
	PERMIT REQUIREMENT		REPORT MO TOTA								
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J. Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
219	473-3179	2	22	06
AREA CODE	NUMBER	MO	DAY	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC

ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394

FACILITY BP PRODUCTS NORTH AMERICA INC.

LOCATION WHITING

ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*

Revised: **DISCHARGE MONITORING REPORT** *(DMR)*

PERMIT NUMBER	DISCHARGE NUMBER
IN0000108	002A

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	01	01	06	TO	01	31	06

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

* 1 N 0 0 0 0 1 0 8 0 0 2 A 0 1 0 6 *

For Any Questions call Jeff Ewick at 317-233-0676

*** NO DISCHARGE ☐ ***

NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	********	********	********	19	21	(04) DEG.C	0	5 TIMES /WEEK	CONTIN
	PERMIT REQUIREMENT					REPORT MO AVG	REPORT DAILY MX				
TEMPERATURE, WATER DEG. CENTIGRADE 00010 7 0 0 INTAKE FROM STREAM	SAMPLE MEASUREMENT	********	********	********	********	13	13	(04) DEG.C	0	5 TIMES /WEEK	CONTIN
	PERMIT REQUIREMENT					REPORT MO AVG	REPORT DAILY MX				
WASTE HEAT REJECTION RATE 00179 2 0 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	292	389	(05) MBTU/ HR	********	********	********	********	0	5 TIMES /WEEK	CONTIN
	PERMIT REQUIREMENT	700 MO AVG	2800 MX DA AV								
PH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	********	********	8.1	********	8.2	(12) SU	0	THREE/ WEEK	GRAB
	PERMIT REQUIREMENT				MINIMUM		MAXIMUM				
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC 00560 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	********	********	********	<0.5	2.9	(19) MG/L	0	THREE/ WEEK	GRAB
	PERMIT REQUIREMENT					REPORT MO AVG	REPORT DAILY MX				
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC 00560 2 0 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	********	********	********	********	<0.5	2.8	(19) MG/L	0	THREE/ WEEK	GRAB
	PERMIT REQUIREMENT					REPORT MO AVG	REPORT DAILY MX				
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC 00560 7 0 0 INTAKE FROM STREAM	SAMPLE MEASUREMENT	********	********	********	********	<0.3	<0.3	(19) MG/L	0	THREE/ WEEK	GRAB
	PERMIT REQUIREMENT					REPORT MO AVG	REPORT DAILY MX				

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J. Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE AREA CODE	TELEPHONE NUMBER	DATE MO	DATE DAY	DATE YEAR
219	473-3179	2	22	06

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC
ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394
FACILITY BP PRODUCTS NORTH AMERICA INC.
LOCATION WHITING
ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM ***(NPDES)***
Revised: **DISCHARGE MONITORING REPORT** ***(DMR)***

IN0000108	002A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	01	01	06	TO	01	31	06

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

For Any Questions call Jeff Ewick at 317-233-0676

*** NO DISCHARGE ☐ ***
NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
CARBON, TOT ORGANIC (TOC) 00680 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	********		********	2	2	(19)	0	5 TIMES /WEEK	GRAB
	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L			
CARBON, TOT ORGANIC (TOC) 00680 2 0 0 EFFLUENT NET VALUE	SAMPLE MEASUREMENT	********	********		********	0	0	(19)	0	5 TIMES /WEEK	GRAB
	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L			
CARBON, TOT ORGANIC (TOC) 00680 7 0 0 INTAKE FROM STREAM	SAMPLE MEASUREMENT	********	********		********	2	2	(19)	0	5 TIMES /WEEK	GRAB
	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	75.0	77.8	(03)	********	********	********		0	DAILY	CONTIN
	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD				********			
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	********		********	<0.05	<0.05	(19)	0	WEEKLY	GRAB
	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L			
FLOW, TOTAL 82220 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	********	2324.3	(3R)	********	********	********		0	ONCE/ MONTH	RCOTOT
	PERMIT REQUIREMENT		REPORT MO TOTAL	MGAL				********			
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J. Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
219	473-3179	2	22	06
AREA CODE	NUMBER	MO	DAY	YEAR

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC
ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394
FACILITY BP PRODUCTS NORTH AMERICA INC.
LOCATION WHITING
ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
Revised:
DISCHARGE MONITORING REPORT *(DMR)*

IN0000108	003A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	01	01	06	TO	01	31	06

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

1H00001080 3A0106

For Any Questions call Jeff Ewick at 317-233-0676

*** NO DISCHARGE ☐ ***

NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
PH	SAMPLE MEASUREMENT	********	********		7.5	********	7.8	(12)	0	WEEKLY	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********	MINIMUM			SU			
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC	SAMPLE MEASUREMENT	********	********		********	0.9	1.3	(19)	0	WEEKLY	GRAB
00560 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********		REPORT MONTHLY	REPORT DAILY MAX	MG/L			
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	********	********		********	22	29	(19)	0	WEEKLY	GRAB
00680 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********		REPORT MONTHLY	REPORT DAILY MAX	MG/L			
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J. Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
219	473-3179	2	22	06
AREA CODE	NUMBER	MO	DAY	YEAR

OMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

PERMITTEE NAME/ADDRESS *(Include Facility Name/Location if Different)*

NAME BP PRODUCTS NORTH AMERICA INC
ADDRESS WHITING REFINERY
2815 INDIANAPOLIS BLVD
WHITING IN 46394
FACILITY BP PRODUCTS NORTH AMERICA INC.
LOCATION WHITING
ATTN: DANIEL SAJKOWSKI, PLT MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
Revised: **DISCHARGE MONITORING REPORT** *(DMR)*

IN0000108	004A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	MO	DAY	YEAR		MO	DAY	YEAR
FROM	01	01	06	TO	01	31	06

MAJOR
F - FINAL
EFFLUENT

Form Approved
OMB No. 2040-000
Approval Expires 05-31-98

For Any Questions call Jeff Ewick at 317-233-0676

*** NO DISCHARGE ☐ ***
NOTE: Read Instructions before completing this form

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
PH	SAMPLE MEASUREMENT	********	********		7.6	********	7.9	(12)	0	WEEKLY	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********	MINIMUM		MAXIMUM	SU			
OIL & GREASE (FREON EXTR.-IR METH)TOT,RC	SAMPLE MEASUREMENT	********	********		********	0.8	0.9	(19)	0	ONCE/MONTH	GRAB
00560 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L			
CARBON, TOT ORGANIC (TOC)	SAMPLE MEASUREMENT	********	********		********	22	27	(19)	0	WEEKLY	GRAB
00680 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			********		REPORT MO AVG	REPORT DAILY MX	MG/L			
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
znone	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTVE OFFICER OR AUTHORIZED AGENT

Authorized Agent:
Daniel J. Sajkowski
Business Unit Leader

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowlege and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine or imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIV OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
AREA CODE	NUMBER	MO	DAY	YEAR
219	473-3179	2	22	06

COMMENTS AND EXPLANATION OF ANY VIOLATION *(Reference all attachments here)*

INDUSTRIAL MAJOR
WHITING, LAKE COUNTY

BP PRODUCTS NORTH AMERICA Inc., WHITING REFINERY
2815 INDIANAPOLIS BLVD., WHITING, INDIANA 46394

PERMIT NO IN0000108 OUTFALL 001 Jan-06 JAN PROCESS WATER EFFLUENT

PARAMETER	FLOW	BOD	COD	pH	TSS	OIL	NH3-N	SULFIDE
CODE	Q50050	Q00310	Q00340	C00400	Q00547	Q00550	Q00610	Q00745
SAMPLE TYPE								
PERMIT	CONT	24	24	GRAB	24	3/DAY	24	24
ACTUAL	CONT	24	24	GRAB	24	3/DAY	24	24
FREQUENCY								
PERMIT	CONT	5/7	3/7	3/7	5/7	5/7	5/7	1/7
ACTUAL	CONT	5/7	3/7	3/7	5/7	5/7	5/7	1/7

LIMITS:	AVG		4161		30323		3646		1368		1030		23.1
	MAX		8164		58427	6.5-9	5694		2600		2060		51.4
DATE	MG/D	mg/l	LB/D	mg/l	LB/D	pH	mg/l	LB/D	mg/l	LB/D	mg/l	LB/D	mg/l	LB/D
1	14.6	4.8	584	61	7428	—	18.0	2192	—	—	—	—	—	—
2	15.1	1.7	214	—	—	7.6	8.8	1108	1.3	164	0.57	72	0.01	1.3
3	14.8	1.6	197	46	5678	—	11.0	1358	1.2	148	0.61	75	—	—
4	14.0	1.3	152	—	—	7.6	7.4	864	1.0	117	0.56	65	—	—
5	13.3	2.3	255	47	5213	—	12.4	1375	1.4	155	—	—	—	—
6	13.5	—	—	—	—	7.7	—	—	1.6	180	1.19	134	—	—
7	13.6	—	—	—	—	—	—	—	—	—	0.98	111	—	—
8	14.0	2.2	257	64	7473	—	12.8	1495	—	—	—	—	—	—
9	13.8	1.4	161	—	—	7.7	9.8	1128	0.9	104	0.93	107	0.01	1.2
10	11.6	1.6	155	45	4353	—	8.4	813	1.2	116	0.95	92	—	—
11	12.5	1.5	156	—	—	7.7	7.4	771	1.1	115	0.26	27	—	—
12	14.4	1.5	180	50	6005	—	10.0	1201	1.3	156	—	—	—	—
13	16.1	—	—	—	—	7.7	—	—	1.4	188	0.32	43	—	—
14	17.2	—	—	—	—	—	—	—	—	—	0.27	39	—	—
15	14.1	2.8	329	50	5880	—	15.4	1811	—	—	—	—	—	—
16	14.2	2.3	272	—	—	7.8	11.8	1397	1.4	166	1.16	137	0.02	2.4
17	13.8	3.3	380	57	6560	—	13.2	1519	2.2	253	1.35	155	—	—
18	13.4	3.5	391	—	—	7.8	11.6	1296	1.5	168	2.59	289	—	—
19	13.3	2.2	244	43	4770	—	9.2	1020	1.2	133	—	—	—	—
20	14.0	—	—	—	—	7.8	—	—	1.6	187	2.23	260	—	—
21	14.0	—	—	—	—	—	—	—	—	—	1.94	227	—	—
22	14.2	3.9	462	56	6632	—	13.8	1634	—	—	—	—	—	—
23	15.7	3.1	406	—	—	7.6	10.8	1414	1.3	170	0.11	14	0.01	1.3
24	15.6	3.1	403	47	6115	—	17.6	2290	1.3	169	<0.10	<13	—	—
25	16.9	1.3	183	—	—	7.6	8.4	1184	0.8	113	<0.10	<14	—	—
26	16.3	1.5	204	40	5438	—	8.0	1088	0.7	95	—	—	—	—
27	16.1	—	—	—	—	7.7	—	—	0.7	94	<0.10	<13	—	—
28	15.9	—	—	—	—	—	—	—	—	—	<0.10	<13	—	—
29	17.1	1.3	185	36	5134	—	8.0	1141	—	—	—	—	—	—
30	16.7	1.1	153	—	—	7.6	6.0	836	0.5	70	<0.10	<14	<0.00	<0.0
31	16.7	1.3	181	30	4178	—	5.8	808	0.4	56	<0.10	<14	—	—
AVERAGE	14.7	2.2	265	48	5776	7.7	10.6	1293	1.2	142	<0.71	<88	<0.01	<1.2
HIGHEST VAL.	17.2	4.8	584	64	7473	7.8	18.0	2290	2.2	253	2.59	289	0.02	2.4
LOWEST VAL.	11.6	1.1	152	30	4178	7.6	5.8	771	0.4	56	<0.10	<13	<0.00	<0.0
OVER LIMIT			0		0	0		0		0		0		0
TOTAL	456.5													

CERTIFIED OPERATOR : David J. Olen No. 14118 exp.6/30/06 DATE : 2-17-06 ENVIRONMENTAL ENGINEER : Michael A. Hess

–MEANS NOT TESTED THIS DATE