VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

2003 E 46th St

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	12	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

2003 E 46th St

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	26	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	3	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
525.2	Alachlor	<	0.1	ug/L	0.1
525.2	Aldrin	<	0.1	ug/L	0.1
525.2	Atrazine	<	0.1	ug/L	0.1
525.2	Benzo[a]pyrene	<	0.02	ug/L	0.02
525.2	Butachlor	<	0.1	ug/L	0.1
525.2	Di(2-ethylhexyl)adipate	<	0.6	ug/L	0.6

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

2003 E 46th St

525.2	Di(2-ethylhexyl)phthalate	<	0.6	ug/L	0.6
525.2	Dieldrin	<	0.1	ug/L	0.1
525.2	Endrin	<	0.01	ug/L	0.01
525.2	gamma-BHC (Lindane)	<	0.02	ug/L	0.02
525.2	Heptachlor	<	0.04	ug/L	0.04
525.2	Heptachlor epoxide	<	0.02	ug/L	0.02
525.2	Hexachlorobenzene	<	0.1	ug/L	0.1
525.2	Hexachlorocyclopentadiene	<	0.1	ug/L	0.1
525.2	Methoxychlor	<	0.1	ug/L	0.1
525.2	Metolachlor	<	0.1	ug/L	0.1
525.2	Metribuzin	<	0.1	ug/L	0.1
525.2	Propachlor	<	0.1	ug/L	0.1
525.2	Simazine	<	0.07	ug/L	0.07
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	8.4	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	=	29.4	ug/L	---
552.2	Trichloroacetic acid	=	21	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

4141 S Madison

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	12	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

4141 S Madison

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	87	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	1.1	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	<	1	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	<	2	ug/L	2
552.2	Trichloroacetic acid	<	1	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

6925 S Harding

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	4.1	ug/L	0.5
524.2	Bromoform	=	1.1	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can
determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte
determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

6925 S Harding

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	2.4	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	3.8	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
525.2	Alachlor	<	0.1	ug/L	0.1
525.2	Aldrin	<	0.1	ug/L	0.1
525.2	Atrazine	<	0.1	ug/L	0.1
525.2	Benzo[a]pyrene	<	0.02	ug/L	0.02
525.2	Butachlor	<	0.1	ug/L	0.1
525.2	Di(2-ethylhexyl)adipate	<	0.6	ug/L	0.6

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

6925 S Harding

525.2	Di(2-ethylhexyl)phthalate	<	0.6	ug/L	0.6
525.2	Dieldrin	<	0.1	ug/L	0.1
525.2	Endrin	<	0.01	ug/L	0.01
525.2	gamma-BHC (Lindane)	<	0.02	ug/L	0.02
525.2	Heptachlor	<	0.04	ug/L	0.04
525.2	Heptachlor epoxide	<	0.02	ug/L	0.02
525.2	Hexachlorobenzene	<	0.1	ug/L	0.1
525.2	Hexachlorocyclopentadiene	<	0.1	ug/L	0.1
525.2	Methoxychlor	<	0.1	ug/L	0.1
525.2	Metolachlor	<	0.1	ug/L	0.1
525.2	Metribuzin	<	0.1	ug/L	0.1
525.2	Propachlor	<	0.1	ug/L	0.1
525.2	Simazine	<	0.07	ug/L	0.07
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	<	1	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	<	2	ug/L	2
552.2	Trichloroacetic acid	<	1	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

7430 Rockville Rd

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	10	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

7430 Rockville Rd

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	80	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	0.7	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
525.2	Alachlor	<	0.1	ug/L	0.1
525.2	Aldrin	<	0.1	ug/L	0.1
525.2	Atrazine	<	0.1	ug/L	0.1
525.2	Benzo[a]pyrene	<	0.02	ug/L	0.02
525.2	Butachlor	<	0.1	ug/L	0.1
525.2	Di(2-ethylhexyl)adipate	<	0.6	ug/L	0.6

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

7430 Rockville Rd

525.2	Di(2-ethylhexyl)phthalate	<	0.6	ug/L	0.6
525.2	Dieldrin	<	0.1	ug/L	0.1
525.2	Endrin	<	0.01	ug/L	0.01
525.2	gamma-BHC (Lindane)	<	0.02	ug/L	0.02
525.2	Heptachlor	<	0.04	ug/L	0.04
525.2	Heptachlor epoxide	<	0.02	ug/L	0.02
525.2	Hexachlorobenzene	<	0.1	ug/L	0.1
525.2	Hexachlorocyclopentadiene	<	0.1	ug/L	0.1
525.2	Methoxychlor	<	0.1	ug/L	0.1
525.2	Metolachlor	<	0.1	ug/L	0.1
525.2	Metribuzin	<	0.1	ug/L	0.1
525.2	Propachlor	<	0.1	ug/L	0.1
525.2	Simazine	<	0.07	ug/L	0.07
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	31	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	=	2.6	ug/L	2
552.2	Total HAA5	=	104.6	ug/L	---
552.2	Trichloroacetic acid	=	71	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

8907 E. 116th - McDonalds

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	7.4	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can
determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte
determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

8907 E. 116th - McDonalds

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	76	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	<	0.5	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	36	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	=	2.6	ug/L	2
552.2	Total HAA5	=	96.6	ug/L	---
552.2	Trichloroacetic acid	=	58	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

96th & Allisonville - Shell Station

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	5.2	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

96th & Allisonville - Shell Station

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	51	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	<	0.5	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	33	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	=	2.4	ug/L	2
552.2	Total HAA5	=	92.4	ug/L	---
552.2	Trichloroacetic acid	=	57	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

9750 Lakeshore Drive

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	6	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

9750 Lakeshore Drive

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	57	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	<	0.5	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
525.2	Alachlor	<	0.1	ug/L	0.1
525.2	Aldrin	<	0.1	ug/L	0.1
525.2	Atrazine	<	0.1	ug/L	0.1
525.2	Benzo[a]pyrene	<	0.02	ug/L	0.02
525.2	Butachlor	<	0.1	ug/L	0.1
525.2	Di(2-ethylhexyl)adipate	<	0.6	ug/L	0.6

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

9750 Lakeshore Drive

525.2	Di(2-ethylhexyl)phthalate	<	0.6	ug/L	0.6
525.2	Dieldrin	<	0.1	ug/L	0.1
525.2	Endrin	<	0.01	ug/L	0.01
525.2	gamma-BHC (Lindane)	<	0.02	ug/L	0.02
525.2	Heptachlor	<	0.04	ug/L	0.04
525.2	Heptachlor epoxide	<	0.02	ug/L	0.02
525.2	Hexachlorobenzene	<	0.1	ug/L	0.1
525.2	Hexachlorocyclopentadiene	<	0.1	ug/L	0.1
525.2	Methoxychlor	<	0.1	ug/L	0.1
525.2	Metolachlor	<	0.1	ug/L	0.1
525.2	Metribuzin	<	0.1	ug/L	0.1
525.2	Propachlor	<	0.1	ug/L	0.1
525.2	Simazine	<	0.07	ug/L	0.07
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	32	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	=	87	ug/L	---
552.2	Trichloroacetic acid	=	55	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Armstrong Bldg 5251 State Rd 67

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	3	ug/L	0.5
524.2	Bromoform	=	0.7	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can
determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte
determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Armstrong Bldg 5251 State Rd 67

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	2.5	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	2.3	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
525.2	Alachlor	<	0.1	ug/L	0.1
525.2	Aldrin	<	0.1	ug/L	0.1
525.2	Atrazine	<	0.1	ug/L	0.1
525.2	Benzo[a]pyrene	<	0.02	ug/L	0.02
525.2	Butachlor	<	0.1	ug/L	0.1
525.2	Di(2-ethylhexyl)adipate	<	0.6	ug/L	0.6

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Armstrong Bldg 5251 State Rd 67

525.2	Di(2-ethylhexyl)phthalate	<	0.6	ug/L	0.6
525.2	Dieldrin	<	0.1	ug/L	0.1
525.2	Endrin	<	0.01	ug/L	0.01
525.2	gamma-BHC (Lindane)	<	0.02	ug/L	0.02
525.2	Heptachlor	<	0.04	ug/L	0.04
525.2	Heptachlor epoxide	<	0.02	ug/L	0.02
525.2	Hexachlorobenzene	<	0.1	ug/L	0.1
525.2	Hexachlorocyclopentadiene	<	0.1	ug/L	0.1
525.2	Methoxychlor	<	0.1	ug/L	0.1
525.2	Metolachlor	<	0.1	ug/L	0.1
525.2	Metribuzin	<	0.1	ug/L	0.1
525.2	Propachlor	<	0.1	ug/L	0.1
525.2	Simazine	<	0.07	ug/L	0.07
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	<	1	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	<	2	ug/L	2
552.2	Trichloroacetic acid	<	1	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Bathroom Sink @ 4101 Dandy Trail

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	<	0.5	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Bathroom Sink @ 4101 Dandy Trail

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	<	0.5	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	<	0.5	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
525.2	Alachlor	<	0.1	ug/L	0.1
525.2	Aldrin	<	0.1	ug/L	0.1
525.2	Atrazine	<	0.1	ug/L	0.1
525.2	Benzo[a]pyrene	<	0.02	ug/L	0.02
525.2	Butachlor	<	0.1	ug/L	0.1
525.2	Di(2-ethylhexyl)adipate	<	0.6	ug/L	0.6

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Bathroom Sink @ 4101 Dandy Trail

525.2	Di(2-ethylhexyl)phthalate	<	0.6	ug/L	0.6
525.2	Dieldrin	<	0.1	ug/L	0.1
525.2	Endrin	<	0.01	ug/L	0.01
525.2	gamma-BHC (Lindane)	<	0.02	ug/L	0.02
525.2	Heptachlor	<	0.04	ug/L	0.04
525.2	Heptachlor epoxide	<	0.02	ug/L	0.02
525.2	Hexachlorobenzene	<	0.1	ug/L	0.1
525.2	Hexachlorocyclopentadiene	<	0.1	ug/L	0.1
525.2	Methoxychlor	<	0.1	ug/L	0.1
525.2	Metolachlor	<	0.1	ug/L	0.1
525.2	Metribuzin	<	0.1	ug/L	0.1
525.2	Propachlor	<	0.1	ug/L	0.1
525.2	Simazine	<	0.07	ug/L	0.07
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	<	1	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	<	2	ug/L	2
552.2	Trichloroacetic acid	<	1	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

CVS @ 46th & Keystone

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	13	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

CVS @ 46th & Keystone

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	48	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	2.2	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	4.3	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	=	25.3	ug/L	---
552.2	Trichloroacetic acid	=	21	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Fall Creek Treatment Plant

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	11	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Fall Creek Treatment Plant

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	23	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	3	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
525.2	Alachlor	<	0.1	ug/L	0.1
525.2	Aldrin	<	0.1	ug/L	0.1
525.2	Atrazine	<	0.1	ug/L	0.1
525.2	Benzo[a]pyrene	<	0.02	ug/L	0.02
525.2	Butachlor	<	0.1	ug/L	0.1
525.2	Di(2-ethylhexyl)adipate	<	0.6	ug/L	0.6

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Fall Creek Treatment Plant

525.2	Di(2-ethylhexyl)phthalate	<	0.6	ug/L	0.6
525.2	Dieldrin	<	0.1	ug/L	0.1
525.2	Endrin	<	0.01	ug/L	0.01
525.2	gamma-BHC (Lindane)	<	0.02	ug/L	0.02
525.2	Heptachlor	<	0.04	ug/L	0.04
525.2	Heptachlor epoxide	<	0.02	ug/L	0.02
525.2	Hexachlorobenzene	<	0.1	ug/L	0.1
525.2	Hexachlorocyclopentadiene	<	0.1	ug/L	0.1
525.2	Methoxychlor	<	0.1	ug/L	0.1
525.2	Metolachlor	<	0.1	ug/L	0.1
525.2	Metribuzin	<	0.1	ug/L	0.1
525.2	Propachlor	<	0.1	ug/L	0.1
525.2	Simazine	<	0.07	ug/L	0.07
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	8.8	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	=	29.8	ug/L	---
552.2	Trichloroacetic acid	=	21	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Firestation @ 7002 N Lafayette Rd

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	16	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Firestation @ 7002 N Lafayette Rd

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	72	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	2.6	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
525.2	Alachlor	<	0.1	ug/L	0.1
525.2	Aldrin	<	0.1	ug/L	0.1
525.2	Atrazine	<	0.1	ug/L	0.1
525.2	Benzo[a]pyrene	<	0.02	ug/L	0.02
525.2	Butachlor	<	0.1	ug/L	0.1
525.2	Di(2-ethylhexyl)adipate	<	0.6	ug/L	0.6

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Firestation @ 7002 N Lafayette Rd

525.2	Di(2-ethylhexyl)phthalate	<	0.6	ug/L	0.6
525.2	Dieldrin	<	0.1	ug/L	0.1
525.2	Endrin	<	0.01	ug/L	0.01
525.2	gamma-BHC (Lindane)	<	0.02	ug/L	0.02
525.2	Heptachlor	<	0.04	ug/L	0.04
525.2	Heptachlor epoxide	<	0.02	ug/L	0.02
525.2	Hexachlorobenzene	<	0.1	ug/L	0.1
525.2	Hexachlorocyclopentadiene	<	0.1	ug/L	0.1
525.2	Methoxychlor	<	0.1	ug/L	0.1
525.2	Metolachlor	<	0.1	ug/L	0.1
525.2	Metribuzin	<	0.1	ug/L	0.1
525.2	Propachlor	<	0.1	ug/L	0.1
525.2	Simazine	<	0.07	ug/L	0.07
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	7.7	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	=	29.7	ug/L	---
552.2	Trichloroacetic acid	=	22	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Firestation @ Ohio & West St

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	10	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Firestation @ Ohio & West St

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	80	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	0.6	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	30	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	=	103	ug/L	---
552.2	Trichloroacetic acid	=	73	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Fox and Oaklandon Rd - BP Gas Station

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	2.3	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Fox and Oaklandon Rd - BP Gas Station

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	1.6	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	2	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
525.2	Alachlor	<	0.1	ug/L	0.1
525.2	Aldrin	<	0.1	ug/L	0.1
525.2	Atrazine	<	0.1	ug/L	0.1
525.2	Benzo[a]pyrene	<	0.02	ug/L	0.02
525.2	Butachlor	<	0.1	ug/L	0.1
525.2	Di(2-ethylhexyl)adipate	<	0.6	ug/L	0.6

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Fox and Oaklandon Rd - BP Gas Station

525.2	Di(2-ethylhexyl)phthalate	<	0.6	ug/L	0.6
525.2	Dieldrin	<	0.1	ug/L	0.1
525.2	Endrin	<	0.01	ug/L	0.01
525.2	gamma-BHC (Lindane)	<	0.02	ug/L	0.02
525.2	Heptachlor	<	0.04	ug/L	0.04
525.2	Heptachlor epoxide	<	0.02	ug/L	0.02
525.2	Hexachlorobenzene	<	0.1	ug/L	0.1
525.2	Hexachlorocyclopentadiene	<	0.1	ug/L	0.1
525.2	Methoxychlor	<	0.1	ug/L	0.1
525.2	Metolachlor	<	0.1	ug/L	0.1
525.2	Metribuzin	<	0.1	ug/L	0.1
525.2	Propachlor	<	0.1	ug/L	0.1
525.2	Simazine	<	0.07	ug/L	0.07
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	1	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	=	1	ug/L	---
552.2	Trichloroacetic acid	<	1	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

McDonalds @ 6830 W 38th St

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	15	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can
determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte
determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

McDonalds @ 6830 W 38th St

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	70	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	2.4	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	18	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	=	55	ug/L	---
552.2	Trichloroacetic acid	=	37	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Pizza Hut @ 86th & Keystone (Keystone At The

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	8.1	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can
determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte
determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Pizza Hut @ 86th & Keystone (Keystone At The

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	90	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	<	0.5	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
525.2	Alachlor	<	0.1	ug/L	0.1
525.2	Aldrin	<	0.1	ug/L	0.1
525.2	Atrazine	<	0.1	ug/L	0.1
525.2	Benzo[a]pyrene	<	0.02	ug/L	0.02
525.2	Butachlor	<	0.1	ug/L	0.1
525.2	Di(2-ethylhexyl)adipate	<	0.6	ug/L	0.6

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Pizza Hut @ 86th & Keystone (Keystone At The

525.2	Di(2-ethylhexyl)phthalate	<	0.6	ug/L	0.6
525.2	Dieldrin	<	0.1	ug/L	0.1
525.2	Endrin	<	0.01	ug/L	0.01
525.2	gamma-BHC (Lindane)	<	0.02	ug/L	0.02
525.2	Heptachlor	<	0.04	ug/L	0.04
525.2	Heptachlor epoxide	<	0.02	ug/L	0.02
525.2	Hexachlorobenzene	<	0.1	ug/L	0.1
525.2	Hexachlorocyclopentadiene	<	0.1	ug/L	0.1
525.2	Methoxychlor	<	0.1	ug/L	0.1
525.2	Metolachlor	<	0.1	ug/L	0.1
525.2	Metribuzin	<	0.1	ug/L	0.1
525.2	Propachlor	<	0.1	ug/L	0.1
525.2	Simazine	<	0.07	ug/L	0.07
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	37	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	=	2.4	ug/L	2
552.2	Total HAA5	=	102.4	ug/L	---
552.2	Trichloroacetic acid	=	63	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Speedway Gas Station @ 6315 W 56th St

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	14	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Speedway Gas Station @ 6315 W 56th St

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	70	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	2.2	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	15	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	=	49	ug/L	---
552.2	Trichloroacetic acid	=	34	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Walgreens @ 62nd & Keystone

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	13	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

Walgreens @ 62nd & Keystone

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	47	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	=	2.3	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	1.5	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	<	2	ug/L	2
552.2	Total HAA5	=	2.6	ug/L	---
552.2	Trichloroacetic acid	=	1.1	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

White River North Treatment Plant

Method	Analyte	Result Flag*	Result	Units	MRL^
524.2	1,1,1,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,1-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1,2,2-Tetrachloroethane	<	0.5	ug/L	0.5
524.2	1,1,2-Trichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,1-Dichloroethylene	<	0.5	ug/L	0.5
524.2	1,1-Dichloropropylene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,3-Trichloropropane	<	0.5	ug/L	0.5
524.2	1,2,4-Trichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2,4-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,2-Dibromo-3-chloropropane (DBCP)	<	0.2	ug/L	0.2
524.2	1,2-Dibromoethane (EDB)	<	0.2	ug/L	0.2
524.2	1,2-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,2-Dichloroethane	<	0.5	ug/L	0.5
524.2	1,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,2-Xylene	<	0.5	ug/L	0.5
524.2	1,3 + 1,4-Xylene	<	0.5	ug/L	0.5
524.2	1,3,5-Trimethylbenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropane	<	0.5	ug/L	0.5
524.2	1,3-Dichloropropylene, cis & trans	<	0.5	ug/L	0.5
524.2	1,4-Dichlorobenzene	<	0.5	ug/L	0.5
524.2	2,2-Dichloropropane	<	0.5	ug/L	0.5
524.2	2-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Chlorotoluene	<	0.5	ug/L	0.5
524.2	4-Isopropyltoluene	<	0.5	ug/L	0.5
524.2	Benzene	<	0.5	ug/L	0.5
524.2	Bromobenzene	<	0.5	ug/L	0.5
524.2	Bromochloromethane	<	0.5	ug/L	0.5
524.2	Bromodichloromethane	=	6.4	ug/L	0.5
524.2	Bromoform	<	0.5	ug/L	0.5
524.2	Bromomethane	<	0.5	ug/L	0.5

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

White River North Treatment Plant

524.2	Carbon tetrachloride	<	0.5	ug/L	0.5
524.2	Chlorobenzene	<	0.5	ug/L	0.5
524.2	Chloroethane	<	0.5	ug/L	0.5
524.2	Chloroform	=	52	ug/L	0.5
524.2	Chloromethane	<	0.5	ug/L	0.5
524.2	cis-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	cis-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Dibromochloromethane	<	0.5	ug/L	0.5
524.2	Dibromomethane	<	0.5	ug/L	0.5
524.2	Dichlorodifluoromethane	<	0.5	ug/L	0.5
524.2	Dichloromethane	<	0.5	ug/L	0.5
524.2	Ethylbenzene	<	0.5	ug/L	0.5
524.2	Hexachlorobutadiene	<	0.5	ug/L	0.5
524.2	Isopropylbenzene	<	0.5	ug/L	0.5
524.2	Methyl-t-butyl ether (MTBE)	<	0.5	ug/L	0.5
524.2	Naphthalene	<	0.5	ug/L	0.5
524.2	n-Butylbenzene	<	0.5	ug/L	0.5
524.2	n-Propylbenzene	<	0.5	ug/L	0.5
524.2	sec-Butylbenzene	<	0.5	ug/L	0.5
524.2	Styrene	<	0.5	ug/L	0.5
524.2	tert-Butylbenzene	<	0.5	ug/L	0.5
524.2	Tetrachloroethylene	<	0.5	ug/L	0.5
524.2	Toluene	<	0.5	ug/L	0.5
524.2	trans-1,2-Dichloroethylene	<	0.5	ug/L	0.5
524.2	trans-1,3-Dichloropropylene	<	0.5	ug/L	0.5
524.2	Trichloroethylene	<	0.5	ug/L	0.5
524.2	Trichlorofluoromethane	<	0.5	ug/L	0.5
524.2	Vinyl chloride	<	0.2	ug/L	0.2
524.2	Xylenes, Total	<	0.5	ug/L	0.5
525.2	Alachlor	<	0.1	ug/L	0.1
525.2	Aldrin	<	0.1	ug/L	0.1
525.2	Atrazine	<	0.1	ug/L	0.1
525.2	Benzo[a]pyrene	<	0.02	ug/L	0.02
525.2	Butachlor	<	0.1	ug/L	0.1
525.2	Di(2-ethylhexyl)adipate	<	0.6	ug/L	0.6

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.

VEOLIA SAMPLE RESULTS, SAMPLE DATE 09/30/2005

White River North Treatment Plant

525.2	Di(2-ethylhexyl)phthalate	<	0.6	ug/L	0.6
525.2	Dieldrin	<	0.1	ug/L	0.1
525.2	Endrin	<	0.01	ug/L	0.01
525.2	gamma-BHC (Lindane)	<	0.02	ug/L	0.02
525.2	Heptachlor	<	0.04	ug/L	0.04
525.2	Heptachlor epoxide	<	0.02	ug/L	0.02
525.2	Hexachlorobenzene	<	0.1	ug/L	0.1
525.2	Hexachlorocyclopentadiene	<	0.1	ug/L	0.1
525.2	Methoxychlor	<	0.1	ug/L	0.1
525.2	Metolachlor	<	0.1	ug/L	0.1
525.2	Metribuzin	<	0.1	ug/L	0.1
525.2	Propachlor	<	0.1	ug/L	0.1
525.2	Simazine	<	0.07	ug/L	0.07
552.2	Dibromoacetic acid	<	1	ug/L	1
552.2	Dichloroacetic acid	=	32	ug/L	1
552.2	Monobromoacetic acid	<	1	ug/L	1
552.2	Monochloroacetic acid	=	2.5	ug/L	2
552.2	Total HAA5	=	82.5	ug/L	---
552.2	Trichloroacetic acid	=	48	ug/L	1

* Result Flag. Results reported with a < symbol are below the lowest number or detection limit that the laboratory analyzing the sample can determine. The detection limit is reported instead of zero (0). Results reported with a = symbol are the actual concentrations of the the analyte determined in the sample.

^ MRL stands for method reporting limit. This is the lowest number or detection limit that the laboratory analyzing the sample can determine.