

Design Memorandum No. 07-04
Backfilling and Video Inspection for Drainage Structures

V. INFORMATION TO BE SHOWN ON PLANS

The backfill method, material, and quantity; geotextile quantity, if applicable; and **video-inspection quantity**, if applicable, **should be shown in the Structure Data Table for each pipe structure**. For metric-unit projects, the metric pipes should be shown on the plans, even though the English pipes were used to determine the backfill quantities.

We are not seeing video inspection for pipes included in plan sets, please review memo in its entirety and include quantities in the plans.