where used)
ngineer
s File

Tom Spe

**End Sections or Structural Plates**

CONTRACT / P. O. NUMBER R - - 17982

SOURCE OF MATERIAL 8624 hadoga Culvert Co., hadoga, In
(NAME OF MANUFACTURER AND LOCATION OF PLANT)

DATE SAMPLED 07 26 89 (MO DAY YEAR)

PURPOSE 73 SAMPLED FROM 1 8657 Z ® Flynn Drainage, Metamora, ILL.

| T ER | MATERIAL CODE | SPECS | LENGTH EACH (1) | UNIT | SEAL OR YELLOW CARD NO. (2) PRE | FROM | TO | NOMINAL DIAMETER OR SPAN X RISE (PIPE ONLY) | SEAM(3) | THICKNESS SPECIFIED | THICKNESS MEASURED | HEAT NUMBER | LENGT TOTA (4) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 3 1 | 8622 | 88 | 8 | L | S | 104103 | 104104 | 12 in | R | .064 | .058 | LTV 0449 | 16 |
| 3 2 | 8622 | 88 | 11 | L | S | 104105 | 104109 | 15 in | R | .064 | .061 | Wheeling A90750 | 53 |
| | 8622 | 88 | 20 | L | S | 104084 | 104088 | 18 in | R | .064 | .064 | LTV 0417 | 100 |
| | 8622 | 88 | 15 | L | S | 104089 | 104089 | 18 in | R | .064 | .064 | 0417 | 15 |
| | 8622 | 88 | 9 | L | S | 104090 | 104090 | 18 in | R | .064 | .064 | 0417 | 9 |
| | 8632 | 88 | 6 | L | S | 104091 | 104091 | 42 X 29 in | R | .064 | .064 | 0417 | 6 |
| | 8632 | 88 | 21 | L | S | 104092 | 104092 | 35 X 24 in | R | .064 | .061 | Wheeling A91655 | 21 |
| 3 8 | 8632 | 88 | 9 | L | S | 104093 | 104093 | 35 X 24 in | R | .064 | .061 | A91655 | 9 |
| 9 | | | | | | | | in | | | | | |

A - 5

: Fabricated & Coated @ Flynn Drainage (8657)

Bands 2-12" 5-15" 10-18" 1-42x29 2-35x24

ngth 231 feet Total Length Since Last Sampled 231 feet

ate Samples Submitted for Analysis 4-10-89 Analysis Received Yes No Samples Met Specifications Yes No

s covered by this report were inspected in accordance with IDOH Specifications, special provisions, and applicable AASHTO Specifications. This inspection verified that ents have been met.