



Michael R. Pence
Governor

Jerome M. Adams, MD, MPH
State Health Commissioner

STATE OF INDIANA)
)
COUNTY OF MARION)

SS: **ADMINISTRATIVE ORDER OF THE INDIANA
STATE DEPARTMENT OF HEALTH
Cause no. Gasoline Sample – Water Test
Registration Number: M2-21114**

**IN THE MATTER OF THE OPERATION OF
Dairy Mart (Circle K #2392)
2345 Covert Ave.
Evansville, Indiana 47714**

**TO: Dairy Mart (Circle K # 2392)
2345 Covert Ave
Evansville, Indiana 47714**

EMERGENCY STOP – SALE ORDER

You are **NOTIFIED** that the Division of Weights and Measures, Indiana State Department of Health, pursuant to Indiana Code 16-44-3-7 (2) and Indiana code 4-21.5-4 et seq. hereby **ORDERS YOU TO IMMEDIATELY STOP THE SALE** of motor fuel from the fuel pumps dispensing grades (89) & (93) octane motor fuel, at the facility known as **Dairy Mart** located at **2345 Covert Ave. Evansville, Indiana 47714**.

This order is based upon the following: **Circle K** is a motor fuel outlet facility engaged in the sale of retail motor fuel to the public.

On March 2, 2015 a Representative of the Division of Weights and Measures, Indiana State Department of Health conducted an inspection of Dairy Mart (Circle K#2392) facilities of the unleaded (89) & (93) octane grades of gasoline. The results of Gasoila paste test conducted on said motor fuel storage tanks reveals 5 inches of water / phase separation in the (93) unleaded storage tank which are blender pumps at this location.

ASTM Standard for unleaded fuels is no more than ¼ of inch of water in fuel storage tank.

This is a violation of the Indiana Code 16-44-3-1 et seq., and 410 IAC 12.1-2-2(a), “Standard Specification for Automotive Spark-Ignition Engine Fuel”.

YOU ARE HEREBY ORDERED TO IMMEDIATELY STOP THE SALE of (89) & (93) octane Unleaded fuels from the fuel pumps dispensing at the facility known as:
Dairy Mart (Circle K#2392) 2392 Covert Ave. Evansville, Indiana 47714

