Indiana State Department of Health
An Equal Opportunity Employer

Michael R. Pence
Governor

Jerome M. Adams, MD, MPH
State Health Commissioner

STATE OF INDIANA)
) SS:
COUNTY OF MARION)

ADMINISTRATIVE ORDER OF THE INDIANA STATE DEPARTMENT OF HEALTH
Cause no. Gasoline Sample – Water Test
Registration Number: M2-20606

IN THE MATTER OF THE OPERATION OF)
Phillips 66)
430 North Alabama St.)
Indianapolis, IN 46204)

TO: Phillips 66
430 North Alabama
Indianapolis, IN 46204

EMERGENCY STOP – SALE ORDER

You are **NOTIFIED** that the Division of Weights and Measures, Indiana State Department of Health, pursuant to Indiana Code 16-44-3-7 (2) and Indiana code 4-21.5-4 et seq. hereby **ORDERS YOU TO IMMEDIATELY STOP THE SALE** of motor fuel from the fuel pumps dispensing grades (89) & (93) octane motor fuel, at the facility known as **Phillips 66** located at **430 North Alabama St., Indianapolis, IN 46204.**

This order is based upon the following: **Phillips** 66 is a motor fuel outlet facility engaged in the sale of retail motor fuel to the public.

On **July 22, 2015** a Representative of the Division of Weights and Measures, Indiana State Department of Health conducted an inspection of **Phillips 66** facilities of the unleaded (89) & (93) octane grades of gasoline. The results of Gasoila paste test conducted on said motor fuel storage tanks reveals 3 inches of water / phase separation in the (93) unleaded storage tank which are blender pumps at this location.

ASTM Standard for unleaded fuels is no more than ¼ of inch of water in fuel storage tank.

This is a violation of the Indiana Code 16-44-3-1 et seq., and 410 IAC 12.1-2-2(a), "Standard Specification for Automotive Spark-Ignition Engine Fuel".

YOU ARE HEREBY ORDERED TO IMMEDIATELY STOP THE SALE of (89) & (93) octane Unleaded fuels from the fuel pumps dispensing at the facility known as: **Phillips 66 – 430 North Alabama St., Indianapolis, Indiana 46204.**