

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/19/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001090	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 01/13/2016
NAME OF PROVIDER OR SUPPLIER ALLIED PHYSICIANS SURGERY CENTER LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 53990 CARMICHAEL DR STE 100 SOUTH BEND, IN 46635		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 11/13/15 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 01/13/16</p> <p>Facility Number: 010984 Provider Number: 15C0001090 AIM Number: 200268420A</p> <p>At this PSR survey, Allied Physicians Surgery Center, LLC was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 416.44(b), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 21, Existing Ambulatory Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered except for the Data Room. The facility has a fire alarm system with smoke detection in the corridors.</p> <p>Quality Review completed on 01/14/16 -DA</p>	{K 000}			
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE			TITLE		(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.