

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 05/10/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PERCEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K0000	<p>A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 416.44(b).</p> <p>Survey Date: 05/10/12</p> <p>Facility Number: 005408 Provider Number: 15C0001027 AIM Number: 100103070A</p> <p>Surveyor: Mark Caraher, Life Safety Code Specialist</p> <p>At this Life Safety Code survey, Surgery Center of Eye Specialists of Indiana was found not in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 416.44(b), Life Safety from Fire and the 2000 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 21, Existing Ambulatory Health Care Occupancies.</p> <p>This facility located on the first and second floor of a two story building was determined to be of Type II (111) construction with a basement and was not sprinklered. The facility has a fire alarm system with smoke detection in corridors.</p>	K0000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE _____ TITLE _____ (X6) DATE _____

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 05/10/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 05/16/12.</p> <p>The facility was found not in compliance with the aforementioned regulatory requirements as evidenced by the following:</p>			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 05/10/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K0021	<p>416.44(b)(1) LIFE SAFETY CODE STANDARD Any door with a required fire protection rating, such as stairways, exit passageways, horizontal exits, smoke barriers, or hazardous area enclosures, if held open, is arranged to close automatically by the actuation of the manual fire alarm system and either smoke detectors arranged to detect smoke on either side of the opening or a complete automatic sprinkler system. 20.2.2.3, 21.2.2.3</p> <p>Based on observation and interview, the facility failed to ensure 1 of 4 stairwell exit doors was one hour fire rated and latched into the door frame. LSC 21.2.2.1 says the means of egress shall be limited to the types described in 39.2.2. LSC 39.2.2.2.1 says doors complying with 7.2.1 shall be provided and 7.2.1.1.1 says a door assembly shall conform to the general requirements of Section 7.1. LSC 7.1.3.2.1 states an exit required to be separated from other parts of the building shall be separated with not less than one hour fire resistance rating where the exit connects three stories or less and 7.1.3.2.1(c) requires openings in the separation shall be protected by fire door assemblies. NFPA 80, Standard for Fire Doors and Fire Windows, at 2-1.4 requires all swinging doors to be closed and latched at the time of fire and 2-1.4.1 requires the door to close and latch each time it is opened. This deficient practice affects any patient or staff exiting the second floor from the PreOp/Post Op</p>	K0021	<p>K 021 1. The practice will attempt to have the door rated by an appropriate service. If it is not possible to determine the fire rating of the door, then a new door will be purchased and installed between the stairwell and the pre/post operative area. 2. This will prevent future deficiencies. 3. Nick Hunter (Administration) responsible. 4. This deficiency will be corrected by the ongoing new process by 6/16/2012.</p>	06/16/2012

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 05/10/2012
NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA			STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PERCEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>waiting area.</p> <p>Findings include:</p> <p>Based on observation with the Administrator during a tour of the facility from 11:20 a.m. to 12:00 p.m. on 05/10/12, the stairwell exit door from the PreOp/Post Op waiting area has no fire resistance rating on the door and the door is not equipped with a positive latching device. Based on interview at the time of observation, the Administrator acknowledged the stairwell exit door from the PreOp/Post Op waiting area has no fire resistance rating and the door is not equipped with a positive latching device.</p>				

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 05/10/2012	
NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA				STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE			
K0048	<p>416.44(b)(1) LIFE SAFETY CODE STANDARD There is a written plan for the protection of all patients and for their evacuation in the event of an emergency. 20.7.1.1, 21.7.1.1</p> <p>Based on record review and interview, the facility failed to provide a complete written plan containing procedures to be followed in the event the fire alarm system has to be placed out of service for 4 hours or more in a 24 hour period in accordance with LSC, Section 9.6.1.8 which requires the authority having jurisdiction be notified and the building evacuated or an approved fire watch provided until the fire alarm system has been returned to service. This deficient practice could affect all patients, staff, and visitors.</p> <p>Findings include:</p> <p>Based on review of "Policy 51: Fire Safety" and "Policy 52: Disasters-DP02 - Fire Procedures" documentation with the Administrator during record review from 9:20 a.m. to 11:20 a.m. on 05/10/12, the facility did not have a written policy in the event the fire alarm system is out of service for four hours or more in a twenty four hour period. Based on interview at the time of record review, the Administrator acknowledged there is no written policy in the event the fire alarm system is out of service for four hours or</p>	K0048	<p>K 048 1. We will amend our current fire policies to address what to do in the event our fire alarm system is out of service for more than a four hour period. 2. Amended policy will prevent future deficiencies. 3. Nick Hunter (Administration) responsible. 4. This deficiency will be corrected by 6/16/2012.</p>	06/16/2012			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 05/10/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PERCEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	more in a twenty four hour period.			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 05/10/2012	
NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA				STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE			
K0050	<p>416.44(b)(1) LIFE SAFETY CODE STANDARD Fire drills are held at unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. 20.7.1.2, 21.7.1.2</p> <p>Based on record review and interview, the facility failed to ensure 1 of 4 quarterly fire drills included the transmission of a fire alarm signal. LSC 21.7.1.2 requires fire drills in ambulatory health care facilities to include the transmission of the fire alarm signal. This deficient practice affects all patients, staff and visitors.</p> <p>Findings include:</p> <p>Based on review of "Eye Specialists of Indiana: Fire Drill" and "Safety Committee: Quarterly Meeting 01/09/12" documentation with the Administrator during record review from 9:20 a.m. to 11:20 a.m. on 05/10/12, the fire drill conducted on 12/13/11 did not include transmission of the fire alarm signal. The Safety Committee: Quarterly Meeting documentation stated, "A fire drill was conducted on 12/13/11. Stanley Security was not notified. The alarm was not pulled because we had no way to reset the alarm. Fire drill was otherwise done to standards." Based on interview at the time of record review, the Administrator</p>	K0050	<p>K 050 1. In the future, all fire drills will include transmission of a fire alarm signal to Stanley Security. 2. Transmitting a fire alarm signal to Stanley Security will prevent future deficiencies. 3. Nick Hunter (Administration) responsible. 4. This deficiency will be corrected by 6/16/2012.</p>	06/16/2012			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 05/10/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	acknowledged the fire drill conducted on 12/13/11 did not include transmission of the fire alarm signal.			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 05/10/2012	
NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA				STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PERCEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE			
K0051	<p>416.44(b)(1) LIFE SAFETY CODE STANDARD A manual fire alarm system, not a pre-signal type, is provided to automatically warn the building occupants. Fire alarm system has initiation notification and control function. The fire alarm system is arranged to automatically transmit an alarm to summon the fire department. 20.3.4.1, 21.3.4.1</p> <p>Based on observation and interview, the facility failed to ensure 1 of 1 fire alarm systems was maintained in accordance with the applicable requirements of NFPA 72, National Fire Alarm Code. LSC 21.3.4.1 requires ambulatory health care facilities be provided with fire alarm systems in accordance with Section 9.6. LSC 9.6.1.4 requires requires fire alarm systems be installed and maintained in accordance with NFPA 72, National Fire Alarm Code. NFPA 72, 1-5.2.5.2 states connections to the light and power service shall be on a dedicated branch circuit(s). Circuit disconnecting means shall have a red marking, shall be accessible only to authorized personnel, and shall be identified as FIRE ALARM CIRCUIT CONTROL. The location of the circuit disconnecting means shall be permanently identified at the fire alarm control unit. This deficient practice could affect all patients, staff and visitors.</p> <p>Findings include:</p>	K0051	<p>1. New locks will be placed on access to the fire alarm breaker panel. 2. New locks prevent future deficiencies. 3. Nick Hunter (Administration) responsible. 4. This deficiency will be corrected by 6/16/2012</p>	06/16/2012			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 05/10/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	Based on observation with the Administrator during a tour of the facility from 11:20 a.m. to 12:00 p.m. on 05/10/12, access to the fire alarm system breaker located in the "C" panel in the hallway at the back exit for patients was not locked. Based on interview at the time of observation, the Administrator acknowledged access to the fire alarm system breaker located in the "C" panel in the hallway near the back exit for patients was not locked.			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 05/10/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K0064	<p>416.44(b)(1) LIFE SAFETY CODE STANDARD Portable fire extinguishers are provided. 20.3.5.2, 21.3.5.2</p> <p>1. Based on observation and interview, the facility failed to ensure 3 of 3 portable fire extinguishers were given maintenance at periods not more than one year apart. LSC 21.3.5.2 requires portable fire extinguishers be provided in ambulatory health care facilities in accordance with 9.7.4.1. LSC 9.7.4.1 says where required by the provisions of another section of this Code, fire extinguishers shall be installed, inspected and maintained in accordance with NFPA 10, Standard for Portable Fire Extinguishers. NFPA 10 in 4-4.1 requires extinguishers shall be subjected to maintenance not more than one year apart or when specifically indicated by a monthly inspection. 4-2.2 defines maintenance as a "thorough check" of the extinguisher. It is intended to give maximum assurance the extinguisher will operate effectively and safely. This deficient practice could affect all patients, staff and visitors.</p> <p>Findings include:</p> <p>Based on observations with the Administrator during a tour of the facility from 11:20 a.m. to 12:00 p.m. on 05/10/12, the annual maintenance tag</p>	K0064	<p>K 064 1. In the future, all fire extinguishers will be checked on a monthly basis to ensure proper operation. 2. Koorsen Fire & Security has been hired to come in on a monthly basis to inspect our fire extinguishers. 3. Nick Hunter (Administration) responsible. 4. Deficiency corrected. Date corrected 5/25/2012.</p>	05/25/2012

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 05/10/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>attached to the portable fire extinguisher located in the Attic hallway indicated the last annual maintenance procedure was performed in April 2010. The annual maintenance tag attached to the portable fire extinguishers located on the first floor by the back exit and on the second floor by the Big OR indicated the last annual maintenance procedure was performed in April 2011. Based on interview at the time of the observations, the Administrator acknowledged it had been more than one year since the most recent annual maintenance was performed for each of the aforementioned fire extinguishers.</p> <p>2. Based on observation and interview, the facility failed to inspect 3 of 3 portable fire extinguishers each month. LSC 21.3.5.2 requires portable fire extinguishers be provided in ambulatory health care facilities in accordance with 9.7.4.1. LSC 9.7.4.1 says where required by the provisions of another section of this Code, fire extinguishers shall be installed, inspected and maintained in accordance with NFPA 10, Standard for Portable Fire Extinguishers. NFPA 10 Section 4-3.4.2 requires fire extinguisher inspections at least monthly with the date of inspection and the initials of the person performing being recorded. In addition, NFPA 10, Section 4-2.1 defines</p>			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 05/10/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>inspection as a "quick check" to ensure the fire extinguisher is available and will operate. It is intended to give reasonable assurance the fire extinguisher is fully charged and operable, verifying that it is in its designated place, it has not been actuated or tampered with and there is no obvious or physical damage or condition to prevent its operation. This deficient practice could affect all patients, staff and visitors.</p> <p>Findings include:</p> <p>Based on observations with the Administrator during a tour of the facility from 11:20 a.m. to 12:00 p.m. on 05/10/12, the monthly inspection tag attached to the portable fire extinguisher located in the Attic hallway indicated the last monthly inspection was performed in September 2010. The monthly inspection tag attached to the portable fire extinguishers located on the first floor by the back exit and on the second floor by the Big OR indicated the most recent monthly inspection was performed in July 2011. Based on interview at the time of the observations, the Administrator acknowledged it had been more than one month since the most recent monthly inspection was performed for each of the aforementioned fire extinguishers.</p>			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 05/10/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PERCEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 05/10/2012	
NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA				STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE			
K0144	<p>416.44(b)(1) LIFE SAFETY CODE STANDARD Generators are inspected weekly and exercised under load for 30 minutes per month in accordance with NFPA 99. 3.4.4.1, NFPA 110, 8.4.2</p> <p>1. Based on record review and interview, the facility failed to ensure a monthly load test for the emergency generator was conducted for 12 of 12 months using one of the three following methods: under operating temperature conditions, at not less than 30% of the Emergency Power Supply (EPS) nameplate rating, or loading that maintains the minimum exhaust gas temperatures as recommended by the manufacturer. LSC 21.5.1 states utilities shall comply with the provisions of Section 9.1. LSC 9.1.3 states emergency generators shall be tested and maintained in accordance with NFPA 110. Chapter 6-4.2 of NFPA 110 requires generator sets in Level 1 and Level 2 service to be exercised at least once monthly, for a minimum of 30 minutes, using one of the following methods:</p> <p>a. Under operating temperature conditions or at not less than 30 percent of the EPS nameplate rating.</p> <p>b. Loading that maintains the minimum exhaust gas temperatures as recommended by the manufacturer.</p> <p>The date and time of day for required testing shall be decided by the owner, based on facility operations. NFPA 110,</p>	K0144	<p>K 144 1. Future documentation in the "Generator Testing Log" will include operating temperature, percentage of load capacity or minimum exhaust gas temperature(TBD as appropriate). Koorsen Fire &Security will inspect and test the emergency lighting by the generator as appropriate. This will be documented and retained in the facility. We will obtain confirmation from our gas provider that the supply comes from a reliable source. 2. These steps will prevent future deficiencies. 3. Nick Hunter (Administration) responsible. 4. These deficiencies will be corrected by 6/16/2012.</p>	06/16/2012			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 05/10/2012	
NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA				STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE			
	<p>6-3.4 requires a written record of inspections, tests, exercising and repairs shall be regularly maintained on the premises. This deficient practice could affect all patients, staff and visitors.</p> <p>Findings include:</p> <p>Based on review of "Generator Testing Log" documentation with the Administrator during record review from 9:20 a.m. to 11:20 a.m. on 05/10/12, monthly load testing documentation for the period of May 31, 2011 through April 23, 2012 show the emergency generator ran for at least thirty minutes each month for the twelve month period but the operating temperature, percentage of load capacity or minimum exhaust gas temperature was not recorded when each monthly load test was conducted. Based on interview at the time of record review, the Administrator stated no load bank testing is performed on the generator and acknowledged the operating temperature, the percentage of load capacity or minimum exhaust gas temperature was not recorded for monthly generator load testing for the period of May 31, 2011 through April 23, 2012.</p> <p>2. Based on observation and interview, the facility failed to document monthly and annual testing for 1 of 1 emergency</p>						

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 05/10/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>task lighting in and around the generator set. LSC Section 21.5.1 requires utilities shall comply with the provisions of Section 9.1. Section 9.1.3 requires emergency generators to be tested and maintained in accordance with NFPA 110, Standard for Emergency and Standby Power Systems. NFPA 110 Section 5.3.1 states the emergency power system location shall be provided with battery powered emergency lighting. The emergency lighting charging system and the normal service room lighting shall be supplied from the load side of the transfer switch. LSC Section 21.2.9.1 states emergency lighting shall be provided in accordance with Section 7.9. LSC Section 7.9.3 requires a functional test shall be conducted on every required lighting system at thirty day intervals for not less than thirty seconds. An annual test shall be conducted on every required battery powered emergency lighting system for not less than one and a half hours. Equipment shall be fully operational for the duration of the test. Written records or visual inspections and tests shall be kept by the owner for inspection by the authority having jurisdiction. This deficient practice could affect all patients, staff and visitors.</p> <p>Findings include:</p>			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 05/10/2012
NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA			STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>Based on observation with the Administrator during a tour of the facility from 11:20 a.m. to 12:00 p.m. on 05/10/12, the generator is located in the basement of the facility and is equipped with one emergency task light having battery backup power. Based on interview at the time of observation, the Administrator stated the facility does not test the battery backup task light at the generator and acknowledged no documentation of monthly and annual testing was available for review.</p> <p>3. Based on observation and interview, the facility failed to ensure the off site fuel source for the emergency generator was from a reliable source. LSC Section 21.5.1 requires utilities shall comply with the provisions of Section 9.1. Section 9.1.3 requires emergency generators to be tested and maintained in accordance with NFPA 110, Standard for Emergency and Standby Power Systems. NFPA 110, 1999 Edition, Standard for Emergency and Standby Power Systems, Chapter 3, Emergency Power Supply (EPS), 3-1.1, Energy Sources states the following energy sources shall be permitted for use for the emergency power supply (EPS):</p> <p>a) Liquid Petroleum products at atmospheric pressure</p> <p>b) Liquefied petroleum gas (liquid or vapor withdrawal)</p>				

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 05/10/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>c) Natural or synthetic gas Exception: For Level 1 installations in locations where the probability of interruption of off site fuel supplies is high (e.g., due to earthquake, flood damage or demonstrated utility unreliability), on-site storage of an alternate energy source sufficient to allow full output of the emergency power supply system (EPSS) to be delivered for the class specified shall be required, with provision for automatic transfer from the primary energy source to the alternate energy source. CMS (Centers for Medicare/Medicaid Services) require a letter of reliability from the natural gas vendor regarding the fuel supply that must contain all of the following:</p> <ol style="list-style-type: none"> 1. A statement of reasonable reliability of the natural gas delivery 2. A brief description that supports the statement regarding the reliability 3. A statement that there is a low probability of interruption of the natural gas 4. A brief description that supports the statement regarding the low probability of interruption 5. The signature of technical personnel from the natural gas vendor. <p>This deficient practice could affect all patients, staff and visitors.</p>			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001027	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 05/10/2012
NAME OF PROVIDER OR SUPPLIER SURGERY CENTER OF EYE SPECIALISTS OF INDIANA			STREET ADDRESS, CITY, STATE, ZIP CODE 1901 N MERIDIAN ST INDIANAPOLIS, IN 46202		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PERCEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>Findings include:</p> <p>Based on observation with the Administrator during a tour of the facility from 11:20 a.m. to 12:00 p.m. on 05/10/12, the off site fuel source for the emergency generator is natural gas. Based on interview at the time of observation, the Administrator, acknowledged the facility did not have a letter from their natural gas provider indicating the natural gas was from a reliable source.</p>				