

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G309	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 09/19/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER REHABILITATION CENTER DEVELOPMENTAL SERVICES	STREET ADDRESS, CITY, STATE, ZIP CODE 2107 E POWELL AVE EVANSVILLE, IN 47714
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K0000	<p>A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j).</p> <p>Survey Date: 9/19/12</p> <p>Facility Number: 000828 Provider Number: 15G309 AIM Number: 100239660</p> <p>Surveyor: Lex Brashear, Life Safety Code Specialist</p> <p>At this Life Safety Code survey, Rehabilitation Center Developmental Services was found not in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>This one story facility was sprinklered. The facility has a</p>	K0000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE _____ TITLE _____ (X6) DATE _____

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G309	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 09/19/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER REHABILITATION CENTER DEVELOPMENTAL SERVICES	STREET ADDRESS, CITY, STATE, ZIP CODE 2107 E POWELL AVE EVANSVILLE, IN 47714
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>monitored fire alarm system with smoke detection in the corridors, sleeping rooms, and common living areas. The facility has a capacity of eight and had a census of seven at the time of this survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Impractical with an E-Score of 6.0.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 09/21/12.</p> <p>The facility was found not in compliance with the aforementioned regulatory requirements as evidenced by the following:</p>			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G309		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 09/19/2012	
NAME OF PROVIDER OR SUPPLIER REHABILITATION CENTER DEVELOPMENTAL SERVICES				STREET ADDRESS, CITY, STATE, ZIP CODE 2107 E POWELL AVE EVANSVILLE, IN 47714			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE			
KS147	<p>483.470(j)(1)(i) LIFE SAFETY CODE STANDARD The administration of every resident board and care facility has in effect and available to all supervisory personnel written copies of a plan for protecting of all persons in the event of fire, for keeping persons in place, for evacuating persons to areas of refuge, and for evacuating persons from the building when necessary. The plan includes special staff response, including fire protection procedures needed to ensure the safety of any resident, and is amended or revised whenever any resident with unusual needs is admitted to the home. All employees are periodically instructed and kept informed with respect to their duties and responsibilities under the plan. Such instruction is reviewed by the staff not less than every 2 months. A copy of the plan is readily available at all times within the facility. 32.7.1, 33.7.1</p> <p>Based on record review and interview, the facility administration failed to ensure all employees are periodically instructed and kept informed with respect to their duties and responsibilities under the plan for special staff response, including fire protection procedures needed to ensure the safety of 7 of 7 clients. Such instruction is reviewed by the staff not less than every two months. This deficient practice could affect all clients.</p> <p>Findings include:</p>	KS147	<p>The manager at Powell group home is a relatively new manager and did not facilitate this training as required.</p> <p>The Powell staff will immediately be retrained on this plan and subsequently trained thereafter.</p> <p>Preventatively, the group home manager and all professional staff will be retrained to ensure that they understand the importance of implementing this training.</p>	10/05/2012			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G309	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 09/19/2012
NAME OF PROVIDER OR SUPPLIER REHABILITATION CENTER DEVELOPMENTAL SERVICES			STREET ADDRESS, CITY, STATE, ZIP CODE 2107 E POWELL AVE EVANSVILLE, IN 47714		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	Based on interview during review of the facility's Fire Safety Plan on 09/20/12 at 1:40 p.m., the Home Manager indicated employees are instructed and kept informed with respect to their duties and responsibilities under the plan for special staff response, including fire protection procedures needed to ensure the safety of any resident, however, the Home Manager indicated such instructions are not reviewed by the staff every two months. The facility was also lacking written documentation fire drills were performed during the third shift (night) of the fourth quarter of 2011 and the second quarter of 2012.				

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G309	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 09/19/2012
NAME OF PROVIDER OR SUPPLIER REHABILITATION CENTER DEVELOPMENTAL SERVICES			STREET ADDRESS, CITY, STATE, ZIP CODE 2107 E POWELL AVE EVANSVILLE, IN 47714		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
KS152	<p>483.470(j)(1)(i) LIFE SAFETY CODE STANDARD (1) The facility holds evacuation drills at least quarterly for each shift of personnel and under varied conditions to - (i) Ensure that all personnel on all shifts are trained to perform assigned tasks; (ii) Ensure that all personnel on all shifts are familiar with the use of the facility's emergency and disaster plans and procedures.</p> <p>(2) The facility must - (i) Actually evacuate clients during at least one drill each year on each shift; (ii) Make special provisions for the evacuation of clients with physical disabilities: (iii) File a report and evaluation on each drill; (iv) Investigate all problems with evacuation drills, including accidents and take corrective action: and (v) During fire drills, clients may be evacuated to a safe area in facilities certified under the Health Care Occupancies Chapter of the Life Safety Code.</p> <p>(3) Facilities must meet the requirements of paragraphs (i) (1) and (2) of this section for any live-in and relief staff that they utilize.</p> <p>Based on record review and interview, the facility failed to ensure fire drills were conducted quarterly on 1 of 3 shifts during 2 of 4 quarters. This deficient practice could affect all clients.</p> <p>Findings include:</p>	KS152	<p>All group home management and staff were retrained on holding evacuation drills quarterly and at varied times on each shift. This would include documentation of the drills as well.</p> <p>Preventatively, the group home manager will begin giving the completed fire drills to their supervisor, the group home coordinator, to review for</p>	10/05/2012	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G309	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 09/19/2012
--	---	--	---

NAME OF PROVIDER OR SUPPLIER REHABILITATION CENTER DEVELOPMENTAL SERVICES	STREET ADDRESS, CITY, STATE, ZIP CODE 2107 E POWELL AVE EVANSVILLE, IN 47714
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	Based on review of the facility's Fire Drill folder on 09/19/12 at 1:30 p.m. with the Home Manager present, the facility lacked documentation fire drills were conducted during the third shift (night) of the fourth quarter (October, November, and December) of 2011, and the second quarter of 2012 (April, May, and June) 2012. Based on interview at the time of record review, the Home Manager said there were no fire drills performed during the third shift of the fourth quarter of 2011 and the second quarter of 2012.		appropriateness.	