

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G438	X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	X3) DATE SURVEY COMPLETED 05/23/2016
--	---	---	---

NAME OF PROVIDER OR SUPPLIER REM-INDIANA INC	STREET ADDRESS, CITY, STATE, ZIP CODE 7555 GRANDVIEW DR INDIANAPOLIS, IN 46260
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0000 Bldg. 01	<p>A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j).</p> <p>Survey Date: 05/23/16</p> <p>Facility Number: 000952 Provider Number: 15G438 AIM Number: 100244640</p> <p>At this Life Safety Code survey, REM - Indiana, Inc. was found not in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2000 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>This one story building was determined to be fully sprinklered. The facility has a fire alarm system with smoke detection in corridors, sleeping rooms and in all living areas. The facility has a capacity of 6 and had a census of 6 at the time of this survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A,</p>	K 0000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G438	X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	X3) DATE SURVEY COMPLETED 05/23/2016
--	---	---	---

NAME OF PROVIDER OR SUPPLIER REM-INDIANA INC	STREET ADDRESS, CITY, STATE, ZIP CODE 7555 GRANDVIEW DR INDIANAPOLIS, IN 46260
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K S152 Bldg. 01	<p>Alternative Approaches to Life Safety, Chapter 6, rated the facility Slow with an E-Score of 3.5.</p> <p>Quality Review completed on 05/23/16 - DA</p> <p>483.470(j)(1)(i) LIFE SAFETY CODE STANDARD</p> <p>(1) The facility holds evacuation drills at least quarterly for each shift of personnel and under varied conditions to -</p> <p>(i) Ensure that all personnel on all shifts are trained to perform assigned tasks;</p> <p>(ii) Ensure that all personnel on all shifts are familiar with the use of the facility's emergency and disaster plans and procedures.</p> <p>(2) The facility must -</p> <p>(i) Actually evacuate clients during at least one drill each year on each shift;</p> <p>(ii) Make special provisions for the evacuation of clients with physical disabilities:</p> <p>(iii) File a report and evaluation on each drill;</p> <p>(iv) Investigate all problems with evacuation drills, including accidents and take corrective action: and</p> <p>(v) During fire drills, clients may be evacuated to a safe area in facilities certified under the Health Care Occupancies Chapter of the Life Safety Code.</p> <p>(3) Facilities must meet the requirements of paragraphs (i) (1) and (2) of this section for any live-in and relief staff that they utilize.</p> <p>Based on record review and interview, the facility failed to conduct fire drills under varied conditions on the third shift</p>	K S152	The staff working in the home will be retrained on Evacuation Drills, including ensuring that drills on different shifts are completed at	06/22/2016

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G438	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 05/23/2016
NAME OF PROVIDER OR SUPPLIER REM-INDIANA INC			STREET ADDRESS, CITY, STATE, ZIP CODE 7555 GRANDVIEW DR INDIANAPOLIS, IN 46260		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>for 3 of 4 quarters. This deficient practice affects all clients, staff and visitors.</p> <p>Findings include:</p> <p>Based on review of "Fire Drill" documentation with the Program Coordinator during record review from 10:30 a.m. to 11:20 a.m. on 05/23/16, fire drills conducted on the third shift on 06/09/15, 09/08/15 and 12/09/15 were conducted at, respectively, 2:45 a.m., 3:00 a.m. and 3:00 a.m. Based on interview at the time of record review, the Program Coordinator acknowledged the aforementioned third shift fire drills were not conducted under varied conditions.</p>		<p>least quarterly. An Evacuation Drill Schedule is located in the home which includes the type of drill to be completed, the date the drill is to be completed, and the time frame that the drill is to be completed in.</p> <p>All drills are turned into the Quality Assurance Manager for review. The Quality Assurance Manager will return the drill if corrections are needed. The original drill will remain in the home. The Quality Assurance Manager and Area Director will track the drills in a database and forward the database to the Area Director no less than monthly.</p> <p>Responsible Party: Home Manager, Program Director, Quality Assurance Specialist</p>		