

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  15G103	X2) MULTIPLE CONSTRUCTION A. BUILDING 02 B. WING _____	X3) DATE SURVEY COMPLETED  08/26/2013
--	---	--	---

NAME OF PROVIDER OR SUPPLIER  ADEC INC	STREET ADDRESS, CITY, STATE, ZIP CODE 1717 LONGWOOD CT GOSHEN, IN 46526
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

K020000	<p>A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j).</p> <p>Survey Date: 08/26/13</p> <p>Facility Number: 000641 Provider Number: 15G103 AIM Number: 100234120</p> <p>Surveyor: W. Chris Greeney, Life Safety Code Specialist</p> <p>At this Life Safety Code survey, ADEC, Inc. was found in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>This one story facility with a basement was fully sprinklered. The facility has a fire alarm system with smoke detection on all levels including in the corridors, in client sleeping rooms and in common living areas. The facility has a capacity of 8 and had a census of 8 at the time of this survey.</p>	K020000		
---------	--	---------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  15G103	X2) MULTIPLE CONSTRUCTION A. BUILDING 02 B. WING _____	X3) DATE SURVEY COMPLETED  08/26/2013
--	---	--	---

NAME OF PROVIDER OR SUPPLIER  ADEC INC	STREET ADDRESS, CITY, STATE, ZIP CODE 1717 LONGWOOD CT GOSHEN, IN 46526
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Prompt with an E-Score of 1.4.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 09/03/13.</p>			