

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G237	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 03/02/2016
--	---	--	---

NAME OF PROVIDER OR SUPPLIER DEVELOPMENTAL SERVICE ALTERNATIVES INC	STREET ADDRESS, CITY, STATE, ZIP CODE 3222 S 125 E SHELBYVILLE, IN 46176
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0000 Bldg. 01	<p>A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j).</p> <p>Survey Date: 03/02/16</p> <p>Facility Number: 000760 Provider Number: 15G237 AIM Number: 100243330</p> <p>At this Life Safety Code survey, Developmental Service Alternatives Inc. was found not in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>This one story facility was not sprinkled. The facility has a fire alarm system with smoke detection in the corridors and common living areas. The facility has a capacity of 8 and had a census of 8 at the time of this survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A,</p>	K 0000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G237	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 03/02/2016
--	---	--	---

NAME OF PROVIDER OR SUPPLIER DEVELOPMENTAL SERVICE ALTERNATIVES INC	STREET ADDRESS, CITY, STATE, ZIP CODE 3222 S 125 E SHELBYVILLE, IN 46176
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K S147 Bldg. 01	<p>Alternative Approaches to Life Safety, Chapter 6, rated the facility Prompt with an E-Score of .60.</p> <p>Quality Review completed on 03/07/16 - DA</p> <p>483.470(j)(1)(i) LIFE SAFETY CODE STANDARD</p> <p>The administration of every resident board and care facility has in effect and available to all supervisory personnel written copies of a plan for protecting of all persons in the event of fire, for keeping persons in place, for evacuating persons to areas of refuge, and for evacuating persons from the building when necessary. The plan includes special staff response, including fire protection procedures needed to ensure the safety of any resident, and is amended or revised whenever any resident with unusual needs is admitted to the home. All employees are periodically instructed and kept informed with respect to their duties and responsibilities under the plan. Such instruction is reviewed by the staff not less than every 2 months. A copy of the plan is readily available at all times within the facility. 32.7.1, 33.7.1</p> <p>Based on record review and interview, the facility administration failed to periodically instruct and keep employees informed with respect to their duties and responsibilities under the written emergency plan not less than every 2 months to protect 8 of 8 clients. A copy of the plan is readily available at all times within the facility. This deficient practice would affect all clients in the facility.</p>	K S147	The QIDP for the home is responsible for ensuring facility staff are periodically instructed regarding their duties and responsibilities regarding the agency emergency evacuation plans. The QIDP will receive training to ensure that she completes this instruction no less than every 2 months. She will also ensure a copy of the evacuation plan remains available to staff. She will provide evidence that	04/01/2016

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G237	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 03/02/2016
NAME OF PROVIDER OR SUPPLIER DEVELOPMENTAL SERVICE ALTERNATIVES INC			STREET ADDRESS, CITY, STATE, ZIP CODE 3222 S 125 E SHELBYVILLE, IN 46176		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>Findings include:</p> <p>Based on record review of the Developmental Services Alternatives Fire Emergency Procedure Plan on 03/02/16 at 9:15 a.m. with the residential director, the only documentation indicating employees were periodically instructed and kept informed with respect to their duties and responsibilities under the plan were Fire Drill Reports. Based on a review of Fire Drill Reports with the residential director on 03/02/16 at 9:20 a.m., there was a period of four months between fire drills dating from the fire drill conducted on 10/30/15 at 4:55 a.m. to the fire drill conducted on 02/11/16 at 8:37 p.m., and a period of four months between fire drills dating from the fire drill conducted on 04/09/15 at 9:30 a.m. and fire drill conducted on 08/19/15 at 5:04 p.m. Based on an interview with the residential director on 03/02/16 at 9:30 a.m., the residential director indicated there was no other documentation available for review to indicate employees were periodically instructed and kept informed with respect to their duties and responsibilities under the Developmental Services Alternatives Fire Emergency Procedure Plan between the four month period dating from 10/30/15 and 02/11/16, and between 04/09/15 and</p>		<p>this has been completed to the administrator. The administrator will routinely verify compliance. Responsible Party: Residential Director</p>		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G237	X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	X3) DATE SURVEY COMPLETED 03/02/2016
--	---	---	---

NAME OF PROVIDER OR SUPPLIER DEVELOPMENTAL SERVICE ALTERNATIVES INC	STREET ADDRESS, CITY, STATE, ZIP CODE 3222 S 125 E SHELBYVILLE, IN 46176
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K S152 Bldg. 01	<p>08/19/15. The lack of two month updates for employees during the two four month periods was acknowledged by the residential director at the exit conference on 03/02/16 at 10:05 a.m.</p> <p>483.470(j)(1)(i) LIFE SAFETY CODE STANDARD (1) The facility holds evacuation drills at least quarterly for each shift of personnel and under varied conditions to - (i) Ensure that all personnel on all shifts are trained to perform assigned tasks; (ii) Ensure that all personnel on all shifts are familiar with the use of the facility's emergency and disaster plans and procedures.</p> <p>(2) The facility must - (i) Actually evacuate clients during at least one drill each year on each shift; (ii) Make special provisions for the evacuation of clients with physical disabilities: (iii) File a report and evaluation on each drill: (iv) Investigate all problems with evacuation drills, including accidents and take corrective action: and (v) During fire drills, clients may be evacuated to a safe area in facilities certified under the Health Care Occupancies Chapter of the Life Safety Code.</p> <p>(3) Facilities must meet the requirements of paragraphs (i) (1) and (2) of this section for any live-in and relief staff that they utilize. Based on record review and interview, the facility failed to conduct fire drills quarterly on each shift for 3 of the last 4 calendar quarters and 3 of 3 shifts over</p>	K S152	The agency has a Professional Presence policy which includes the use of a home visit note that directs items professional staff review when in the program. The QIDP is in	04/01/2016

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G237	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 03/02/2016
NAME OF PROVIDER OR SUPPLIER DEVELOPMENTAL SERVICE ALTERNATIVES INC			STREET ADDRESS, CITY, STATE, ZIP CODE 3222 S 125 E SHELBYVILLE, IN 46176		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>the past year. This deficient practice could affect all clients.</p> <p>Findings include:</p> <p>Based on a review of Fire Drill Reports on 03/02/16 at 9:20 a.m. with the residential director, there was no record of a fire drill conducted on first shift and third shift for the first quarter of the year 2015, second shift and third shift for the second quarter of the year 2015, and first shift and third shift for the third quarter of the year 2015. Based on an interview with the residential director at the time of record review, there were no other records available to indicate the missed fire drills were conducted. This was verified by the residential director at the time of record review and acknowledged at the exit conference on 03/02/16 at 10:05 a.m.</p>		<p>the home no less than weekly and completed the form. This form has been updated to include a review of evacuation drills that have been completed and to take steps to ensure any needed drills are completed. A copy of this form is provided for review as an attachment. The QIDP will be trained on this updated expectation. The QIDP will also will retrain all staff in the home regarding the expectations for completing evacuation drills. The administrator will be copied on provided training to verify completion. The administrator is also provided copies of the completed home visit notes to verify the QIDP is reviewing and ensuring completion of required evacuation drills.</p> <p>Responsible Party: QIDP</p>		