

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G493	X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	X3) DATE SURVEY COMPLETED 09/09/2015
--	---	---	---

NAME OF PROVIDER OR SUPPLIER VOCA CORPORATION OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 4160 N CAMPBELL AVE INDIANAPOLIS, IN 46226
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0000 Bldg. 01	<p>A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j).</p> <p>Survey Date: 09/09/15</p> <p>Facility Number: 001007 Provider Number: 15G493 AIM Number: 100245090</p> <p>At this Life Safety Code survey, Voca Corporation of Indiana was found not in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2000 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>This one story building was determined to be fully sprinklered. The facility has a fire alarm system with smoke detection in corridors, all living areas and bedrooms. The facility has a capacity of 8 and had a census of 7 at the time of this survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety,</p>	K 0000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G493	X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	X3) DATE SURVEY COMPLETED 09/09/2015
--	---	---	---

NAME OF PROVIDER OR SUPPLIER VOCA CORPORATION OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 4160 N CAMPBELL AVE INDIANAPOLIS, IN 46226
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K S152 Bldg. 01	<p>Chapter 6, rated the facility Prompt with an E-Score of 0.8.</p> <p>Quality Review completed 09/10/15 - DA.</p> <p>483.470(j)(1)(i) LIFE SAFETY CODE STANDARD (1) The facility holds evacuation drills at least quarterly for each shift of personnel and under varied conditions to - (i) Ensure that all personnel on all shifts are trained to perform assigned tasks; (ii) Ensure that all personnel on all shifts are familiar with the use of the facility's emergency and disaster plans and procedures.</p> <p>(2) The facility must - (i) Actually evacuate clients during at least one drill each year on each shift; (ii) Make special provisions for the evacuation of clients with physical disabilities: (iii) File a report and evaluation on each drill: (iv) Investigate all problems with evacuation drills, including accidents and take corrective action: and (v) During fire drills, clients may be evacuated to a safe area in facilities certified under the Health Care Occupancies Chapter of the Life Safety Code.</p> <p>(3) Facilities must meet the requirements of paragraphs (i) (1) and (2) of this section for any live-in and relief staff that they utilize. Based on record review and interview, the facility failed to conduct fire drills under varied conditions on the third shift</p>	K S152	CORRECTION: <i>The facility holds evacuation drills</i>	10/09/2015

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G493	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 09/09/2015
--	---	--	---

NAME OF PROVIDER OR SUPPLIER VOCA CORPORATION OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 4160 N CAMPBELL AVE INDIANAPOLIS, IN 46226
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>for 4 of 4 quarters. This deficient practice affects all clients, staff and visitors.</p> <p>Findings include:</p> <p>Based on review of "Emergency Evacuation Drill: Fire" documentation with the Residential Manager and the Maintenance Aide during record review from 10:40 a.m. to 11:40 a.m. on 09/09/15, fire drills conducted on the third shift on 10/14/14, 11/11/14, 12/12/14, 01/13/15, 05/06/15, 07/10/15 and 08/26/15 were each conducted at 3:00 a.m. Based on interview at the time of record review, the Residential Manager acknowledged the aforementioned third shift fire drills were not conducted under varied conditions.</p>		<p><i>at least quarterly for each shift of personnel and under varied conditions.</i> Specifically, the facility will conduct additional evacuation drills on the overnight shift at varied times shift during the current quarter.</p> <p>PREVENTION:</p> <p>Professional staff will be retrained regarding the need to conduct evacuation drills at varied times on each shift for all staff each quarter. Training will also focus on proper completion of evacuation drill forms and assessment of individual drill compliance. The Operations Team will review and track all facility evacuation drill reports and follow up with professional staff as needed to assure drills occur as scheduled and follow up with the agency Safety Committee accordingly.</p> <p>Responsible Parties: QIDP, Residential Manager, Team Lead, Direct Support Professionals, Operations Team, Safety Committee</p>	