

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/24/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 013019	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 01/16/2014
NAME OF PROVIDER OR SUPPLIER CLEARVISTA LAKE HEALTH CAMPUS			STREET ADDRESS, CITY, STATE, ZIP CODE 8405 CLEARVISTA PLACE INDIANAPOLIS, IN 46256		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>INITIAL COMMENTS</p> <p>An Initial Life Safety Code Certification and State Licensure Survey for a new facility with 70 certified Comprehensive beds was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Dates: 01/16/14</p> <p>Facility Number: 013019 Provider Number: 013019 AIM Number: NA</p> <p>Surveyor: Mark Caraher, Life Safety Code Specialist</p> <p>At this Initial Life Safety Code survey, Clearvista Lake Health Campus was found in compliance with Requirements for Participation Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety From Fire and the 2000 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 18, New Health Care Occupancies and with 410 IAC 16.2-3.1-19, Environment and Physical standards of the Indiana Health Facilities Rules for Comprehensive care facilities.</p> <p>This facility located on the first floor of a two story building was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridor and in all areas open to the corridor. The facility has smoke detectors hard wired to the fire alarm system installed in all resident sleeping rooms. The facility has a capacity of 70 and had a census of 0 at the time of this visit.</p>	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/24/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 013019	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 01/16/2014
NAME OF PROVIDER OR SUPPLIER CLEARVISTA LAKE HEALTH CAMPUS		STREET ADDRESS, CITY, STATE, ZIP CODE 8405 CLEARVISTA PLACE INDIANAPOLIS, IN 46256		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 1 All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered. Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 01/23/14.	K 000		