

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155696	X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	X3) DATE SURVEY COMPLETED 08/24/2016
--	---	---	---

NAME OF PROVIDER OR SUPPLIER BRIDGEPOINTE HEALTH CAMPUS	STREET ADDRESS, CITY, STATE, ZIP CODE 1900 COLLEGE AVE VINCENNES, IN 47591
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0000 Bldg. 01	<p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 08/24/16</p> <p>Facility Number: 003237 Provider Number: 155696 AIM Number: 200374360</p> <p>At this Life Safety Code survey, Bridgepointe Health Campus was found in substantial compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detectors in the corridors, spaces open to the corridors, and all resident sleeping rooms. The facility has a capacity of 75 and had a census of 68 at the time of this</p>	K 0000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155696	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 08/24/2016
--	---	--	---

NAME OF PROVIDER OR SUPPLIER BRIDGEPOINTE HEALTH CAMPUS	STREET ADDRESS, CITY, STATE, ZIP CODE 1900 COLLEGE AVE VINCENNES, IN 47591
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0062 SS=B Bldg. 01	<p>survey.</p> <p>All areas where the residents have customary access were sprinklered and all areas providing facility services were sprinklered.</p> <p>NFPA 101 LIFE SAFETY CODE STANDARD Required automatic sprinkler systems are continuously maintained in reliable operating condition and are inspected and tested periodically. 19.7.6, 4.6.12, NFPA 13, NFPA 25, 9.7.5</p> <p>Based on observation and interview, the facility failed to ensure 1 of over 500 sprinkler heads in the facility were free of corrosion. NFPA 101 Section 9.7.5 refers to NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems. NFPA 25 2-2.1.1 requires sprinklers to be free of paint and corrosion. Any sprinkler shall be replaced that is painted or corroded. This deficient practice could affect mostly staff while in the laundry area.</p> <p>Findings include:</p> <p>Based on observation on 08/24/16 at 12:00 p.m. during a tour of the facility with Director of Plant Operations, the sprinkler head in the laundry room outside the dryers was covered with green corrosion. This was acknowledged by</p>	K 0062	<p>It is the policy of BridgePointe Health Campus to ensure that required automatic sprinkler systems are continuously maintained in reliable operating condition and are inspected and tested periodically in accordance with 19.7.6, 4.6.12, NFPA13, NFPA25, 9.7.5</p> <p>The facility has 1 sprinkler system. On 9/01/16 a visual audit was conducted on each sprinkler head in the facility to identify those that are not free of paint and/or corrosion. Ohio Valley Sprinklers, LLC will drain antifreeze system and replace identified sprinkler heads. This project is scheduled during the week of 9/12-9/16/16.</p> <p>The Director of Plant Operations (DPO) has been educated on the regulation to have sprinkler heads that are free of paint and/or corrosion. The Environmental Services Department has been</p>	09/16/2016

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155696	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 08/24/2016
NAME OF PROVIDER OR SUPPLIER BRIDGEPOINTE HEALTH CAMPUS			STREET ADDRESS, CITY, STATE, ZIP CODE 1900 COLLEGE AVE VINCENNES, IN 47591		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	Director of Plant Operations at the time of observation. 3.1-19(b)		educated on the regulation to have sprinkler heads that are free of paint and/or corrosion. The DPO will conduct a monthly visual audit of sprinkler heads in common areas and the environmental services department will conduct a visual audit of sprinkler heads in resident rooms. These audits will be completed monthly X 3 months; and quarterly thereafter. Results of this audit will be forwarded to QA committee quarterly X 12 months for review		