

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/10/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155247	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 , 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 02/09/2012
NAME OF PROVIDER OR SUPPLIER MANORCARE HEALTH SERVICES			STREET ADDRESS, CITY, STATE, ZIP CODE 8549 S MADISON AVE INDIANAPOLIS, IN 46227	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the Comparative Federal Monitoring Survey conducted on 11/30/11 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 02/09/12 Facility Number: 000151 Provider Number: 155247 AIM Number: 100284060 Surveyor: Mark Caraher, Life Safety Code Specialist At this PSR survey, Manorcare Health Services was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC). The original building was surveyed with Chapter 19, Existing Health Care Occupancies. This one story facility was determined to be of Type V (000) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and in areas open to the corridors. The facility has a capacity of 140 and had a census of 122 at the time of this visit. Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 02/09/12.	{K 000}		
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the Comparative Federal Monitoring Survey conducted on 11/30/11 was conducted by the Indiana State Department	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/10/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155247	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 , 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 02/09/2012
NAME OF PROVIDER OR SUPPLIER MANORCARE HEALTH SERVICES			STREET ADDRESS, CITY, STATE, ZIP CODE 8549 S MADISON AVE INDIANAPOLIS, IN 46227		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1 of Health in accordance with 42 CFR 483.70(a). Survey Date: 02/09/12 Facility Number: 000151 Provider Number: 155247 AIM Number: 100284060 Surveyor: Mark Caraher, Life Safety Code Specialist At this PSR survey, Manorcare Health Services was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC). The 2007 addition was surveyed with Chapter 18, New Health Care Occupancies. The 2007 addition to this one story facility was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and in resident sleeping rooms #166 through #182. The facility has a capacity of 140 and had a census of 122 at the time of this visit.	{K 000}			